

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2023/ 873

Dated: 12/12/2023

FIRE SAFETY CERTIFICATE

Certified that the **MCD Primary School**, B-3A,Janakpuri New Delhi- 110058 Comprised of ground plus one upper floor owned/occupied by MCD Primary School was issued FSC vide letter No. F6/DFS/MS/School/2021/SZ/139 dated 18/02/2021.The school building was re- inspected by the officer concerned of this department on dated 01/12/2023 in the presence of Nidhi Saxena (Principal). The School building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi, and found that the building is fit for occupancy class B 'Educational Building' with effect from ... 12/12/2023 for a period of **three years**, subject to conditions printed below.

Issued on.....12/12/2023.....at New Delhi by


 (Atul Garg)
 Director
 Delhi Fire Service


To,

The Principal,
 MCD Primary school,
 B-3A,Janakpuri, New Delhi- 110058.

Copy to:-

Director of Education
 MCD,23rd Floor,Civic Centre,
 Minto Road,New Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

- 1 Name & address of the building : MCD Primary School, B-3A, Janakpuri,
New Delhi- 110058.
2. Building is comprised of : **Ground plus one upper floor**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/2021/SZ/139 dated 18/02/2021
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011
7. Date of Inspection : 01/12/2023
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer
from the building side : Ms. Nidhi Saxena (Principal)
10. Year of Construction : 2012-13
11. Applicant's letter No : Pr/B3A /378/21/11/2023 Dated -21/11/2023

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE CIR. Dated 1.3.2011	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	09 mtrs.	MR
	Gate width	4.5	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	2 nos.	2 nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	1.5 m & .75 m	1.48 m & 1.25 m	MR
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
g. Width of Corridor	1.50 m	2.0 m	MR	
h. Door Size	1 m	1.10 m	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	Required	Natural ventilation	MR

6

4

N/15

Fire Extinguisher			
Total numbers	04 Nos.	04 Nos.	MR
types	CO ₂ & ABC	CO ₂ & ABC	MR
IS marking	ISI marked	ISI marked	MR
First-aid-Hose Reels.			
Total numbers of each floor	N.A.	N.A.	N.A.
Length of hose reel hose	N.A.	N.A.	N.A.
Nozzle diameter	N.A.	N.A.	N.A.
Automatic fire detection and alarming system.			
Type of detectors	N.A.	N.A.	N.A.
Location of main panel	N.A.	N.A.	N.A.
Location of repeater panel	N.A.	N.A.	N.A.
Alternate source of power	N.A.	N.A.	N.A.
Hooters	N.A.	N.A.	N.A.
MOEFA	N.A.	N.A.	N.A.
Public address System.	N.A.	N.A.	N.A.
0	Automatic Sprinkler System.		
basement	N.A.	N.A.	N.A.
upper floor	N.A.	N.A.	N.A.
sprinkler above false ceiling	N.A.	N.A.	N.A.
1	Internal Hydrants		
size of riser/down-comer	N.A.	N.A.	N.A.
Number of hydrants per floor	N.A.	N.A.	N.A.
Hose Box	N.A.	N.A.	N.A.
2	Yard Hydrants.		
Total number of hydrants	N.A.	N.A.	N.A.
Hose Box	N.A.	N.A.	N.A.
3	Pumping Arrangements.		
• Ground Level	N.A.	N.A.	N.A.
➤ Discharge of main Pump	N.A.	N.A.	N.A.
➤ Head of Main Pump	N.A.	N.A.	N.A.
➤ Number of main pumps	N.A.	N.A.	N.A.
➤ Jockey pump out put	N.A.	N.A.	N.A.
➤ Jockey pump head	N.A.	N.A.	N.A.
➤ Standby pump out put	N.A.	N.A.	N.A.
➤ Standby pump Head	N.A.	N.A.	N.A.
➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
➤ Pump House Access	N.A.	N.A.	N.A.
• Terrace Level			
➤ Discharge of pump	N.A.	N.A.	N.A.
➤ Head of the Pump	N.A.	N.A.	N.A.
➤ Power supply	N.A.	N.A.	N.A.
➤ Auto Starting of pump	N.A.	N.A.	N.A.

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/school/2021/SZ/139 Dt.- 18/02/2021 renewal under the circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 is recommended.

R K YADAV
9/12/2023

Signature of the Inspecting Officer

Name R K YADAV

Designation ADO (JKP)

DO (South West)

AA
5/12/23

CFO (S2) *llugh*
6/11/2023

Director

MR