

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No., F.6/DFS/MS/EH/2023/SZ/ 355

Dated: 07/12/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of **M/s The Big Chill** located at **Shop No 170 B-C, Ground floor**, DLF Avenue Saket, New Delhi 110017 in the building comprised of 03 tiers Basement, Ground plus Seven Upper floors owned/occupied by A Unit of Big Chill Café Pvt Ltd was issued FSC by this department vide letter no F6/DFS/MS/EH/2020/SZ/193 dated 30/12/2020. The restaurant premise was re-inspected by the officers concerned of this department on 04/12/2023 in the presence of Mr. Imran Khan (Manger) and found that the said restaurant premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy **Class- D "Assembly Building"** and **validity upto 31/03/2026** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 07/12/2023 at New Delhi by


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer (MCD), Public Health Department, Aurobindo Marg, Green Park, New Delhi-110016 (Ref. MHA Portal ID 2023111318459 dated 24/11/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire-fighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

INSPECTION REPORT

1	Name & Address of the Building	The Big Chill (A Unit of Big Chill Café Pvt Ltd) Shop No 170 B-C, Ground floor, DLF Avenue Saket, New Delhi 110017		
2	Type of Occupancy	Group-D Restaurant Ground floor only		
3	Building Comprised of	03 tier Basements, Ground + 07 Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/EH/2020/SZ/193 dated 30/12/2020		
6	Fire Safety Directives Letter No	DLF Place Mall,- F.6/MS/DFS/BP/2005/2073 dated 04/10/2005 & F.6/MS/DFS/BP/2019/135 dated 01/04/2019		
7	Date of Inspection	04/12/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Imran Khan (Manger)		
10	Year of construction	2006		
11	Applicant letter No.	MHA Portal ID No 2023111318459 dated 24/11/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement/ Existing Fire Protection	Provided at Site	Remarks MR/NMR
1	Access to Building.	(DLF Place Mall - F.6/DFS/MS/2022/Mall/SZ/266 Dt. 15/06/2022)		
	• Road width	9m	Provided *	MR
	• Gate width	6m	Provided *	MR
	• Width of internal road	6m	Provided *	MR
2	Number, width, type & arrangement of exits.	Restaurant at Ground floor		
	a) Number of Staircase	Restaurant at Ground floor		
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement floor.	N/A	N/A	N/A
	b) Width of Staircase	Provided & Maintained by DLF Avenue Mall		
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement floor	N/A	N/A	N/A
	c) Protection of exits	Provided & Maintained by DLF Avenue Mall		
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	d) No. of continuous staircase to terrace	N/A	N/A	N/A
	e) Width of corridor	N/A	N/A	N/A
	f) Door size	1.50 m each	2m, & 1.75 m	MR
3	Compartmentation.	Provided & Maintained by DLF Avenue Mall		
	• Fire check door.	Restt within Mall	Provided *	MR
	• Sealing of electrical shafts.	Restt within Mall	Provided *	MR
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.	Provided & Maintained by DLF Avenue Mall		
	• Basement	30 ACPH	N/A	N/A
	• Upper floors	12 ACPH	Exhaust Fans Provided	MR
5	Fire Extinguishers.	Provided & Maintained by DLF Avenue Mall		
	• Total numbers	Required	08 Nos	MR
	• Types	ABC/CO ₂	ABC & CO ₂	MR
	• ISI Marking	Required	Provided	MR
6	First Aid Hose Reels.	Provided & Maintained by DLF Avenue Mall		
	• Total numbers on each floor.	One near Restt	Provided *	MR
	• Length of hose-reel hose.	30m	Provided *	MR
	• Nozzle Diameter	5mm	Provided *	MR
7	Automatic fire detection & alarming system.	Provided & Maintained by DLF Avenue Mall		
	• Type of detectors	Required	Provided *	MR
	• Location of Main Panel	Required	Provided *	MR
	• Location of Repeater Panel	Required	Provided *	MR
	• Alternate source of power	Required	Provided *	MR
	• Hooter's location	Required	Provided *	MR


8	MOEFA	Required	Provided *	MR
9	Public Address System	N/A	Provided *	MR
10	Automatic Sprinkler System	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Basement 	Required	Provided *	MR
	<ul style="list-style-type: none"> Ground floor. 	Required	Provided *	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Size of Riser/Down-comer 	Required	Provided *	MR
	<ul style="list-style-type: none"> Number of Hydrant per floor 	One near Restt	Provided *	MR
	<ul style="list-style-type: none"> Hose box. 	One near Restt	Provided *	MR
12	Yard Hydrants.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Total number of hydrants. 	N/A	Provided *	N/A
	<ul style="list-style-type: none"> Hose box. 	N/A	Provided *	N/A
13	Pumping arrangements.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Ground Level 	Common pumping arrangements for entire bldg		
	<ul style="list-style-type: none"> Discharge of main pump. 	4500 LPM	Provided *	MR
	<ul style="list-style-type: none"> Head of main pump. 	70m	Provided *	MR
	<ul style="list-style-type: none"> Number of main pumps. 	02 Nos.	Provided *	MR
	<ul style="list-style-type: none"> Jockey Pump output. 	180 LPM	Provided *	MR
	<ul style="list-style-type: none"> Jockey Pump head. 	70m	Provided *	MR
	<ul style="list-style-type: none"> Standby Pump output. 	4500 LPM	Provided *	MR
	<ul style="list-style-type: none"> Standby Pump head. 	70m	Provided *	MR
	<ul style="list-style-type: none"> Auto Starting/Manual Stopping. 	Required	Provided *	MR
	<ul style="list-style-type: none"> Pump house access. 	Required	Provided *	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. 	450 LPM	Provided *	MR
	<ul style="list-style-type: none"> Head of pump. 	40 m	Provided *	MR
	<ul style="list-style-type: none"> Power supply. 	Required	Provided *	MR
	<ul style="list-style-type: none"> Auto starting of pump. 	Required	Provided *	MR
14	Captive water storage for fire fighting.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Underground tank capacity. 	Required	3,70,000 Ltrs	MR
	<ul style="list-style-type: none"> Draw-off connection. 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Service Inlet. 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank. 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	Required	30,000 Ltrs	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication in lift car. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's switch. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift signage. 	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location 	N/A	N/A	N/A
19	Fire Control Room.	Provided & Maintained by DLF Avenue Mall		
	<ul style="list-style-type: none"> Detector system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Flow switch panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> PA system panel. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Battery backup. 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Building floor plan. 	N/A	N/A	N/A
20	Special Fire Protection System for the Protection of special Risk, if any.	N/A	N/A	N/A


Note: - * Provided & Maintenance by the DLF Avenue Mall, Saket, New Delhi ^{N/2}


The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no 6/DFS/MS/EH/2020/SZ/193 dated 30/12/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)


Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)


Director
6/1/2023
C/1/2/23
Am BLD

Uploaded
11/12/23
