

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2023/ 594

Dated: 14/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Asian Institute of Transport Development (Asian Bhawan) Located at Road No. 205, Sector - 09, Dwarka, New Delhi - 110077, comprised of Basement + Ground + 02 Upper Floors was issued FSC vide letter No. F6/DFS/MS/SZ/2022/315, dated - 19/08/2020. The premises was re inspected by the officers concerned of this department on 05/12/2023 in the presence of Sh. R.C. Dubey (Admin Officer) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Educational" with effect from 14/12/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/12/2023 at New Delhi by.

  
(Arul Garg)  
Director  
Delhi Fire Service.  
OK  
12/12/23

Copy to:

1. The President, Asian Institute of Transport Development (Asian Bhawan) Located at Road No. 205, Sector - 09, Dwarka, New Delhi - 110077.
2. The Vice Chairman, DDA, INA, Vikas Sadan, New Delhi

**Following fire safety directives must be adhered to:-**

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

N/23

**INSPECTION REPORT**

1. Name & address of the building: Asian Institute of Transport Development (Asian Bhawan) Located at Road No. 205, Sector – 09, Dwarka, New Delhi – 110077.
2. Type of Occupancy : Educational (Basement + Ground+ 2 Upper Floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/SZ/2022/315, dated – 19/08/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2015/2395, dated 18/11/2015
6. Date of inspection : 05-12-2023
7. Name of the Inspecting Officer : Udai vir singh, ADO (DWK)
8. Name and designation of Officer from the building side : Sh. R.C. Dubey (Admin Officer)
9. Year of Construction : 2017
10. Applicant's letter No. : Form J & K, dated 20/11/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/18, N/19 & N/20	Provided at site	Remarks MR/NMR
1.	Access of building		Provided	MR
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	Provided	MR
	• Basements	04 Nos.+ Ramp	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	4x150cm	MR
	• Basements	1.5 mtr	4x150cm	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	04 Nos.	03 Nos.	MR (Being old case)
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1m to 1.5m	1m to 1.5m	MR (Being old case)
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/24

4.	Smoke managements System			
	• Basements	30 a/c charge	Exhaust fans provided	MR
	• Upper floors	12 a/c charge	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	28 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	03 Nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	2280 lpm	Provided	MR
	• Discharge of main pump	70 m	Provided	MR
	➤ Head of main pump	01 No.	Provided	MR
	➤ Number of main pumps	180 lpm	Provided	MR
	➤ Jockey pump out put	70m	Provided	MR
	➤ Jockey pump head	2280 lpm	Provided	MR
	➤ Standby Pump out put	70 m	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto starring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

Signature

N/25

14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	100000 ltr	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG Set	
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric meter	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.  
 In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No. F6/DFS/MS/SZ/2022/315, dated - 19/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer  
 Name Uday Vir Singh  
 Designation ADO/DWA

*[Signature]*  
 6/12/25

CPD (S2)  
*[Signature]*