

280

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/2023/ School 896

Dated: 15/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Bal Bhavan International School, Located at Sector - 12, Dwarka, New Delhi - 110075 comprised of Basement + Ground +2 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/School/2018/SZ/2229, dated 03/10/18. The premises was re inspected by the officer concerned of this department on 11/12/2023 in the presence of Mr. C.M Vashisht (Manager) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 15/12/2023 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/12/2023 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service.  
o/c 15/12/23

Copy to:

1. The Principal, Bal Bhavan International School, Sector - 12, Dwarka, New Delhi - 110075,
2. Directorate of Education Old Secretariat Delhi - 110054

**Following fire safety directives must be adhered to:-**

- 1 **The 3<sup>rd</sup> floor shall not be occupied without getting FSC from this department.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



## INSPECTION REPORT

1. Name & address of the building: Bal Bhavan International School, Sector-12, Dwarka, New Delhi-110075.
2. Type of Occupancy : Educational (Basement+Ground +02 Upper floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2018/SZ/2229, dated 03/10/18
5. Fire Safety directives Letter No. : . Circular. No 3298-3398 Dated 01/03/2011
6. Date of inspection : 11/12/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. C.M Vashisht (Manager)
 

No. of Students=3027  
 No. of class rooms=70  
 Plot area=16188 sqm  
 Covered area =9712 sqm
9. Year of Construction : 2004-2014
10. Applicant's letter No. BBIS/DW-12/NOC/2023/449 dated - 18/11/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/15, N/16 & N/17	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtrs	Provided	MR
	• Gate width	4.5mtrs	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	04 Nos.	Provided	MR
	• Basements	04 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr	1.53, 1.50, 1.47, 1.52m	MR Old case
	• Basements	1.5 mtr	1.53, 1.50, 1.47, 1.52m	MR Old case
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	Provided	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	01 mtr	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Exhaust Fans	MR
	• Upper floors	12 a/c per hour	Natural ventilation	MR

*[Signature]*



N/24

5.	Fire Extinguishers				
	• Total numbers	10 nos.each floor	Provided	MR	
	• Types	ABC & CO <sub>2</sub>	Provided	MR	
	• IS marking	ISI marked	ISI marked	MR	
6.	First-Aid Hose Reels				
	• Total numbers on each floor	02 Nos.	Provided	MR	
	• Length of hose reel hose	30 mtr	30 mtr	MR	
	• Nozzle diameter	5 mm	5 mm	MR	
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA	NA	
	• Location of Main Panel	NA	At reception	NA	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	Required	DG Set 125KVA	MR	
	• Hooters' Location	NA	Near staircase	NA	
8.	MOEFA	NA	Provided	NA	
9.	Public Address System	NA	Provided	NA	
10.	Automatic Sprinkler System				
	• Basements	Required	Provided	MR	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11.	Internal Hydrants:				
	• Size of riser/down- comer	NA	100 mm	NA	
	• Number of hydrants per floor	NA	02	NA	
	• Hose Box	NA	Provided	NA	
12.	Yard Hydrants				
	• Total number of hydrants	NA	01	NA	
	• Hose Box	NA	01	NA	
13.	Pumping Arrangements:				
	• Ground Level	NA	NA	NA	
	• Discharge of main pump	NA	NA	NA	
	➤ Head of main pump	NA	NA	NA	
	➤ Number of main pumps	NA	NA	NA	
	➤ Jockey pump out put	NA	NA	NA	
	➤ Jockey pump head	NA	NA	NA	
	➤ Standby Pump out put	NA	NA	NA	
	➤ Standby Pump Head	NA	NA	NA	
	➤ Auto Staring/Manual stopping	NA	NA	NA	
	➤ Pump House Access	NA	NA	NA	
	• Terrace level				
	➤ Discharge of pump	450 lpm, 180 lpm	Provided	MR	
	➤ Head of the pump	40 mtr	40 mtr	MR	
	➤ Power supply	Required	Provided	MR	
	➤ Auto starting of pump	Required	Provided	MR	
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA	
	➤ Draw off connection	NA	NA	NA	
	➤ Fire service inlet	NA	NA	NA	
	➤ Access to tank	NA	NA	NA	
	• Overhead Tank capacity	15,000 ltr	Provided	MR	
15	Exit Signage	Required	Provided	MR	

11/25

16.	Provision of Lifts	NA	NA	NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area	NA	NA	NA
	➤ Total area	NA	NA	NA
	➤ Location			
19.	Fire control room	NA	NA	NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panel	
				MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2018/SZ/2229, dated 03/10/18 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer  
 Name *Uday Singh*  
 Designation *ADP/2017*

*[Signature]* 11/12/23  
*CFO (S2)*

*[Signature]* 11/12/2023  
*Director*

*Any one*

Sir FF letter is put up for sig for  
 "DIRECTOR" 13/12/23