



No.F6/DFS/MS/School/NDZ/2023/889

Dated: 13/12/2023

FIRE SAFETY CERTIFICATE

Certified that the Green Land Public School X/2126, Street No. 4, Rajgarh Colony, Delhi-110031, building comprised of Ground + 2 upper floor (School Running at Ground + First floor) owned / occupied by Green Land Public School, was issued FSC vide letter No. F6/DFS/MS/School/2019/NDZ/2369 dated 26/12/2019. The School building was re-inspected by the officer concerned of this department on 05/12/2023 in presence of Mrs.Sushma Gupta (Head Mistress) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 13/12/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 13/12/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

o/c (u)

Copy to:-

1. The Principal, Green Land Public School X/2126, Street No. 4, Rajgarh Colony, Delhi-110031.
2. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi-110053.

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for Ground & 2 upper floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Green Land Public School at X/2126, Street No. 4, Rajgarh Colony, Delhi-110031.		
2	Building is comprised of	Ground + 2 upper floor (School Running at Ground + First floor)		
3	Type of occupancy	Group B - Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2019/NDZ/2369 dated 26/12/2019		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	05/12/2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mrs. Sushma Gupta (Head Mistress)		
10	Year of construction	1979		
11	Applicant's letter no.	Email dated 20/11/2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	8.0 mtrs.	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	01 nos.	01 nos.	MR
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	1.50 mtrs	1.20 mtrs	MR
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01no.	01 nos.	MR
E	Width of corridor	1.50 mtrs.	1.50 mtrs.	MR
F	Door size	01mtrs	01 mtrs	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	Smoke Management System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA

(w)

5.	Fire Extinguisher:			
A	Total numbers	04 nos.	06 nos.	MR
B	Types	ABC/CO ₂	ABC/CO ₂	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor	NA	NA	NA
B	Length of hose reel hose	NA	NA	NA
C	Nozzle diameter	NA	NA	NA
7	Automatic Fire Detection and Alarming System:			
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters	NA	NA	NA
8	MOEFA:	NA	NA	NA
9	Public Address System:	NA	NA	NA
10	Automatic Sprinkler System:			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
A	Size of riser/down-comer	NA	NA	NA
B	Number of hydrants per floor	NA	NA	NA
C	Hose box	NA	NA	NA
12	Yard Hydrants:			
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	NA	NA	NA
B	Head of main pump	NA	NA	NA
C	Number of main pumps	NA	NA	NA
D	Jockey pump out put	NA	NA	NA
E	Jockey pump head	NA	NA	NA
F	Standby pump out put	NA	NA	NA
G	Standby pump head	NA	NA	NA
H	Auto starting /manual stopping	NA	NA	NA
I	Pump house access	NA	NA	NA
2	Terrace Level			
A	Discharge of pump	NA	NA	NA
B	Head of the pump	NA	NA	NA
C	Power supply	NA	NA	NA
D	Auto starting of pump	NA	NA	NA

W

SP/

14	Captive Water Storage for Fire Fighting:		
A	Underground tank capacity	NA	NA
B	Draw-off connection	NA	NA
C	Fire service inlet	NA	NA
D	Access to tank	NA	NA
E	Overhead tank capacity	NA	NA
15	Exit Signage:		
16	Provision of Lifts:		
A	Pressurization of lift shaft	NA	NA
B	Pressurization of lift lobby	NA	NA
C	Communication in lift car	NA	NA
D	Firemen's grounding switch	NA	NA
E	Lift signage	NA	NA
17	Standby Power Supply:		
18	Refuge Area:		
A	Total area	NA	NA
B	Location	NA	NA
19	Fire Control Room:		
A	Detector system panel	NA	NA
B	Flow switch panel	NA	NA
C	PA system panel	NA	NA
D	Battery backup	NA	NA
E	Building floor plans	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC (Part-IV) the FSC issued vide letter no. F6/DFS/MS/School/2019/NDZ/2369 dated 26/12/2019 is recommended to be renewed.


5/12/2023

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

~~Dy. CEO(NDZ)~~

King
06/12/23

C.F.O.

Wagh
8/12/2023

Director
9/12/23

AD/LN

C.T.M. ...