

c43

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ / 877

Dated: 12/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that Sarvodaya Kanya Vidyalaya, D-Block, Janakpuri, New Delhi-110058, comprised of four blocks namely Admn. Wing, Sr. Wing, SPS Wing & SSA Block. Each block is having ground plus one upper floor, owned/occupied by Sarvodaya Kanya Vidyalaya was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ/469 dated 05/11/2020. The premise was re-inspected by the officer concerned of this department on 05/12/2023 in the presence of Smt. Anita Sardana (Principal) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed as under.


Issued on.....12/12/2023..... at New Delhi.



(Atul Garg)  
Director  
Delhi Fire Service

Copy to:-

1. The Principal,  
Sarvodaya Kanya Vidyalaya,  
D-Block, Janakpuri, New Delhi-110058
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.



Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

173

### INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, D-Block, Janakpuri, New Delhi-110058.
2. Building comprised of : 4 blocks(G+1) namely Admn. Wing, Sr. Wing, SPS Wing & SSA Block.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/469 dated 05/11/2020
6. Fire Safety directives letter No : Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011
7. Date of inspection : 05/12/2023
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers  
From the building side : Smt. Anita Sardana (Principal)
10. Year of Construction : Admn. & Sr. Wing (Before 2006), SPS Wing (Before 2011) & SSA (2017).
11. Applicant's letter No. : SKV/ D blk/364 Dated 03/11/2023

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33                                                                                                                                       | Requirement as per Dir. of Edu. Circ. dt. 01.03.2011        | Provided at site                                                                                 | Remarks MR/NMR                  |
|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------|--------------------------------------------------------------------------------------------------|---------------------------------|
| 1.     | <b>Access to building</b>                                                                                                                                                                         |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>                                                                            | Accessible (06 mtrs)<br>4.5 mtrs<br>N/A                     | 09 mtrs<br>5.8 & 3.5mtrs<br>N/A                                                                  | MR<br>MR<br>N/A                 |
| 2.     | <b>Number, Width, Type &amp; Arrangement of Exits</b>                                                                                                                                             |                                                             |                                                                                                  |                                 |
|        | a. Number of staircases                                                                                                                                                                           |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>                                                                                                             | AW-01 no., SW-02 no.'s, SPS-03 no.'s & 01 no. in SSA<br>N/A | Provided<br>N/A                                                                                  | MR<br>N/A                       |
|        | b. Width of staircases                                                                                                                                                                            |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>                                                                                                              | 1.50 m & .75 m<br>N/A                                       | 1.50 m in AW, 1.40 & 1.37 m in SW & 1.80, 1.40, 1.42 m in SPS & 1.70 m in SSA<br>N/A             | MR<br>N/A                       |
|        | c. Protection of exits                                                                                                                                                                            |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>                                                                                                     | N/A<br>N/A                                                  | N/A<br>N/A                                                                                       | N/A<br>N/A                      |
|        | d. No. of continuous staircases to terrace                                                                                                                                                        |                                                             |                                                                                                  |                                 |
|        |                                                                                                                                                                                                   | N/A                                                         | Three                                                                                            | N/A                             |
|        | e. Width of Corridor                                                                                                                                                                              |                                                             |                                                                                                  |                                 |
|        |                                                                                                                                                                                                   | 1.50 m                                                      | 1.80 to 1.70m                                                                                    | MR                              |
|        | f. Door Size                                                                                                                                                                                      |                                                             |                                                                                                  |                                 |
|        |                                                                                                                                                                                                   | 1.0 m                                                       | .95 to 1.05 m (double door) few class rooms have single door & 1.19 & .88 m (double door in SSA) | MR, being old case              |
| 3.     | <b>Compartmentation</b>                                                                                                                                                                           |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul> | N/A<br>N/A<br>N/A<br>N/A<br>N/A                             | N/A<br>N/A<br>N/A<br>N/A<br>N/A                                                                  | N/A<br>N/A<br>N/A<br>N/A<br>N/A |
| 4.     | <b>Smoke Management System</b>                                                                                                                                                                    |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>                                                                                                             | N/A<br>Required                                             | N/A<br>Natural Ventilation                                                                       | N/A<br>MR                       |
| 5.     | <b>Fire Extinguishers</b>                                                                                                                                                                         |                                                             |                                                                                                  |                                 |
|        | <ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>                                                                                          | 30 No's<br>ABC/CO <sub>2</sub> type<br>ISI marked           | Provided<br>Provided<br>ISI marked                                                               | MR<br>MR<br>MR                  |

15

h

|     |                                                                                                                                                                                                                                                                                                                                                                                      |     |          |                  |
|-----|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|----------|------------------|
| 6.  | <b>First-Aid Hose Reels</b>                                                                                                                                                                                                                                                                                                                                                          |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>                                                                                                                                                                                                                                             | N/A | N/A      | N/A              |
| 7.  | <b>Automatic fire detection and alarming system</b>                                                                                                                                                                                                                                                                                                                                  |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>                                                                                                                                                                                | N/A | N/A      | N/A              |
| 8.  | <b>MOEFA</b>                                                                                                                                                                                                                                                                                                                                                                         | N/A | N/A      | N/A              |
| 9.  | <b>Public Address System</b>                                                                                                                                                                                                                                                                                                                                                         | N/A | Provided | N/A              |
| 10. | <b>Automatic Sprinkler System</b>                                                                                                                                                                                                                                                                                                                                                    |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>                                                                                                                                                                                                                                                              | N/A | N/A      | N/A              |
| 11. | <b>Internal Hydrants</b>                                                                                                                                                                                                                                                                                                                                                             |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>                                                                                                                                                                                                                                                   | N/A | N/A      | N/A              |
| 12. | <b>Yard Hydrants</b>                                                                                                                                                                                                                                                                                                                                                                 |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>                                                                                                                                                                                                                                                                                         | N/A | N/A      | N/A              |
| 13. | <b>Pumping Arrangements</b>                                                                                                                                                                                                                                                                                                                                                          |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Ground Level                             <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> </ul> </li> </ul> | N/A | N/A      | N/A              |
|     | <ul style="list-style-type: none"> <li>Pump House Access</li> <li>Terrace level                             <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>                                                                                                           | N/A | N/A      | N/A              |
| 14. | <b>Captive Water Storage for fire fighting</b>                                                                                                                                                                                                                                                                                                                                       |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Underground tank capacity                             <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>                                                                                                                   | N/A | N/A      | N/A              |
| 15. | <b>Exit Signage.</b>                                                                                                                                                                                                                                                                                                                                                                 | N/A | N/A      | N/A              |
| 16. | <b>Provision of Lifts.</b>                                                                                                                                                                                                                                                                                                                                                           |     |          |                  |
|     | <ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>                                                                                                                                                                    | N/A | N/A      | (No Lift)<br>N/A |
| 17. | <b>Standby power supply</b>                                                                                                                                                                                                                                                                                                                                                          | N/A | N/A      | N/A              |

|     |                                                                                    |     |     |     |
|-----|------------------------------------------------------------------------------------|-----|-----|-----|
| 18. | <b>Refuge Area.</b>                                                                |     |     |     |
|     | <ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul> | N/A | N/A | N/A |
| 19. | <b>Fire Control Room</b>                                                           |     |     |     |
|     | • Detector System Panel                                                            | N/A | N/A | N/A |
|     | • Flow Switch Panel                                                                | N/A | N/A | N/A |
|     | • PA System Panel                                                                  | N/A | N/A | N/A |
|     | • Battery backup                                                                   | N/A | N/A | N/A |
|     | • Building Floor Plans                                                             | N/A | N/A | N/A |
| 20. | <b>Special Fire Protection System for Protection of special Risks, if any:</b>     |     | N/A | N/A |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2020/SZ/469 dated 05/11/2020 renewal in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education is recommended.

*R.K. Yadav*  
9/2/2023

Signature of Inspecting Officer  
Name:-R.K. Yadav  
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)  
*[Signature]* 6/11/23

(F.O/S2)  
*[Signature]* 8/12/2023  
Director  
*[Signature]* 8/12/23  
Asstt. N/S