

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/900

Dated: 18/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that M.C. Primary School Sant Ravidas Nagar (School ID No. 1253010/1253009) located at K-II, Jahangir Puri, Delhi-110033 comprised of 02 blocks, one block comprised of ground floor & second block comprised of ground + first floor only owned/occupied by M.C. Primary School Sant Ravidas Nagar was issued FSC by this department vide letter no. F6/DFS/MS/School/2019/1807 dated: 19.09.2019. The premises was inspected by the officer concerned of this department on 07.12.2023 in presence of Sh. Abhinandan Kumar (Principal) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class "Group B Educational" with effect from 18/12/2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 18/12/2023 at New Delhi

  
(Atul Garg)  
Director  
Ph:-011-23414000  
92

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, M.C. Primary School Sant Ravidas Nagar (School ID No. 1253010/1253009) located at K-II, Jahangir Puri, Delhi-110033.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : M.C. Primary School at Ravi Das Nagar, K-II, Jahangirpuri, Delhi-110033.
2. Type of Occupancy : Educational
3. Composition of building : 02 blocks, (1<sup>st</sup> block, Ground floor & 2<sup>nd</sup> block, Ground + first floor only)
4. Type of Case : Renewal
5. Details of previous FSC : F6/DFS/MS/School/2016/1664 Dated: 11.11.2016
6. Fire Safety directives letter No : Nil
7. Date of inspection : 07.12.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Abhinandan Kumar (Principal)
10. Year of Construction : 2008
11. Applicant's letter No. : Letter No. Nil dated: 20.11.2023 & DFS Dairy No.8963 dated: 21.11.2023

S. No	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular dated 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	07m	MR
	• Gate width	4.5m	3.25m	MR (old case)
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	1.5m each	1.5m each	MR
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
e. Width of Corridor	NA	NA	MR	
f. Door Size	01m	01m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	09nos	09nos	MR
	• Types	ABC/Co2	ABC-09	MR
	• ISI marking	ISI Marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			

	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	NA	NA	
		NA	NA	
		NA	NA	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-corer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	<b>Exit Signage.</b>	Required	Provided	MR

16	Provision of Lifts.		
	• Pressurization of Lift Shaft	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A
	• Communication In lift Car	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A
	• Lift Signage	N/A	N/A
17	Standby power supply	N/A	N/A
18	Refuge Area.		
	➤ Total Area	N/A	N/A
	➤ Location	N/A	N/A
19	Fire Control Room		
	• Detector System Panel	N/A	N/A
	• Flow Switch Panel	N/A	N/A
	• PA System Panel	N/A	N/A
	• Batter backup	N/A	N/A
	• Building Floor Plans	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standard on fire prevention and fire safety requirements as stipulated under the circular issued by Director of Education dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no.1807 dated:19.09.2019.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation :- ADO/RN

415  
 11/12/2023

11/12

CFO  
 Director  
 11/12/2023