

C-20



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2023 / School / WZ / 914

Dated 18 / 12 / 2023

FIRE SAFETY CERTIFICATE

Certified that the Sanskar Shiksha Kunj located at Gali No. 9 B, Main Gaunda Road, Bankner, Delhi-110040 comprised of Ground and First floor owned/occupied by Sanskar Shiksha Kunj was issued FSC by this department vide letter No F6 /DFS/MS/2020/School/WZ/545 dated 10.12.2020. The premises was re-inspected by the officer concerned of this department on 08.12.2023 in the presence of Smt. Sunita (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from18.../12.../2023 for a period of three years, subject to compliance of the conditions mentioned below:

Issued on18.../12.../2023 at New Delhi by


(Atul Garg)

Director

Ph. 011-23414000

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. Principal, Sanskar Shiksha Kunj, Gali No. 9B, Main Gaunda Road, Bankner, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Sanskar Shiksha Kunj, Gali No.-9 B, Main Gaunda Road, Bankner , Delhi-110040
2. Type of Occupancy : Educational
3. Building Comprised : Ground + First Floor.
4. Type of Case : Renewal
5. Details of Previous NOC : Letter No. F.6/DFS/MS/2020/School/WZ/545 Dated-10/12/2020
6. Fire Safety directives letter No : Dir of Edu. Cir 01/03/2011
7. Date of inspection : 08/12/2023
8. Name of Inspecting Officer : R.K. Sinha, ADO (BW)
9. Name and designation of officers From the building side : Smt. Sunita (Principal)
10. Year of Construction : 2010 & 2017
11. Applicant's letter No. : E Mail ID , Dated-05/12/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.00 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA

ke

	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
		NA	NA	NA
9.	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
		NA	NA	NA
10.	MOEFA	NA	NA	NA
10.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants	NA	NA	NA
		NA	NA	NA
13.	Pumping Arrangements	NA	NA	NA
		NA	NA	NA
13.	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping ➤ Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
13.	<ul style="list-style-type: none"> • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.	Captive Water Storage for fire fighting	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
		NA	NA	NA
16.	Provision of Lifts.	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			

	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are not under the staircase.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2020/School/WZ/545 dated 10/12/2020.

Dy CPO (WZ)

ADO (B.W)
12/12/23

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

13/12

459-N/20
13/12/23

CPO
13/12/2023
Director
13/12/23

आपको दिर 6-T लेटर में पत्र पर
आपको दिर 6-T लेटर में पत्र पर

Director (DFS)
13/12/23

ADO (B.W)