

59

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2023/SZ/ 906

Dated: 18 / 12 / 2023

FIRE SAFETY CERTIFICATE

Certified that the building of Govt. Girls Senior Secondary School, Kakrola, New Delhi-110078(School Code-1618020), comprised of Two Blocks A-block having G+1 upper floor (Old Blk.) & B-block (New Blk.) having ground plus three upper floors, owned/occupied by Govt. Girls Senior Secondary School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/412 dated 08/10/2020. The School building was re-inspected by the officer concerned of this department on 05/12/2023 in the presence of Smt. Neha Choudhary (HOS) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on.....18 / 12 / 2023..... at New Delhi.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Principal, Govt. Girls Senior Secondary School, Kakrola, New Delhi-110078.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

1. Name & address of the building : Govt. Girls Senior Secondary School ,Kakrola, New Delhi-110078.(School Code-1618020)
2. Building is comprised of : Two Blocks A-block having G+1 upper floor (Old Blk.) & (New Blk.) B-block having Ground plus three upper floors.
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : N/A
6. Fire Safety direction letter No : Nil
7. Date of Inspection : 05/12/2023
8. Name of the Inspecting officers : ADO R.K. Yadav
9. Name and designation of Officer:
From the building side : Smt. Neha Choudhary (HOS)
10. Year of Construction : A-block 2001 & B-block 2017
11. Applicant's letter No. : GGSSS/KAK/2023/1476 Dated- 16/11/2023

S. N	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m.	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	New Bldg 02 Nos.	Provided	MR
	• Basement	Old Bldg 03 Nos		
	B. Width of Staircases	N/A	N/A	N/A
	• Upper Floor	New Bldg 1.5 m each & Old Bldg 1.5 &.75 m	New Bldg 1.82 & 1.84 m & Old Bldg 1.5,1.40 & 1.41m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	New Bldg 02 Nos.	Provided	MR
	e. Width of Corridor	Old Bldg 02 Nos		
	f. Door Size	1.50 m	Provided	MR
		New Bldg 1.20 m Old Bldg 1.0 m	Provided	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	Required	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	32 nos.	Provided	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	IS I marked	Provided	MR

6	First-aid-Hose Reels.			Provided	MR
	Total numbers of each floor	New block		Provided	MR
	• Length of hose reel hose	30 m		Provided	MR
	• Nozzle diameter	05 mm		Provided	MR
7	Automatic fire detection and alarming system.				
	• Type of detectors	N/A		N/A	N/A
	• Location of main panel	N/A		N/A	N/A
	• Location of repeater panel	N/A		N/A	N/A
	• Alternate source of power	N/A		N/A	N/A
	• Hooter's location	N/A		N/A	N/A
8	MOEFA	N/A		N/A	N/A
9	Public address System.	N/A		N/A	N/A
10	Automatic Sprinkler System.				
	• Basement	N/A		N/A	N/A
	• upper floor	N/A		N/A	N/A
	• sprinkler above false ceiling	N/A		N/A	N/A
11	Internal Hydrants				
	• size of riser/down-comer	N/A		N/A	N/A
	• Number of hydrants per floor	N/A		N/A	N/A
	• Hose Box	N/A		N/A	N/A
12	Yard Hydrants.				
	• Total number of hydrants	N/A		N/A	N/A
	• Hose Box	N/A		N/A	N/A
13	Pumping Arrangements.				
	• Ground Level				
	➤ Discharge of main Pump	N/A		N/A	N/A
	➤ Head of Main Pump	N/A		N/A	N/A
	➤ Number of main pumps	N/A		N/A	N/A
	➤ Jockey pump out put	N/A		N/A	N/A
	➤ Jockey pump head	N/A		N/A	N/A
	➤ Standby pump out put	N/A		N/A	N/A
	➤ Standby pump Head.	N/A		N/A	N/A
	➤ Auto Starting /Manual stopping	N/A		N/A	N/A
	➤ Pump House Access	N/A		N/A	N/A
	• Terrace Level				
	➤ Discharge of pump	450 LPM in B-block		Provided	MR
	➤ Head of the Pump	40 M		Provided	MR
	➤ Power supply	Required		Provided	MR
	➤ Auto Starting of pump	Required		Provided	MR
14	Captive Water Storage for Fire Fighting.				
	• Underground tank capacity	N/A		N/A	N/A
	➤ Draw-off connection	N/A		N/A	N/A
	➤ Fire service inlet	N/A		N/A	N/A
	➤ Access to tank	N/A		N/A	N/A
	• Overhead Tank capacity	10,000 Ltr.		10,000 Ltrs	MR
15	Exit Signage.	Required		Provided	MR

17

W/10

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings letter issued vide letter No. F6/DFS/MS/School/2023/SZ/447 dated 04/10/2023 has been complied.

Keeping in view of the above compliance of the minimum standards of fire prevention and fire safety measures under Rule 35 of the Delhi Fire Service Rules 2010 it is recommended to grant Fire Safety Certificate.

Note:- Earlier the school was in two shifts and now restructured & separated. This case is under consideration for Govt. Girls Senior Secondary School, Kakrola, New Delhi-110078 (School Code-1618020)

Accordingly DFA is put up for approval and signature please.

Signature of the Inspecting Officer
 Name :-R.K.Yadav
 Designation:-ADO(JKP)

R.K. Yadav
 5/12/2023

DO (South West)

5/12/23

CPD(S2)

6/12/2023

Director

5/12/23

5/12/23