




GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001



No F 6 / DFS / MS / 2023 / School / WZ / 923

Dated 21-12-2023

FIRE SAFETY CERTIFICATE

Certified that the **Ambedkar School of Specialised Excellence (School ID- 1411259)** located at **Anandwas, Kohat Enclave, Delhi-110034** comprised of **Ground+ Three upper floors & 01 MP Hall in 2nd floor** owned/ occupied by **Dr. B.R. Ambedkar School** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and verified by the officer concerned of Fire Service on **13.12.2023** in the presence of **Smt. Mamta Saluja (H.O.S.)** and that the building is fit for **occupancy class Group B Educational** with effect from 21-12-2023 for a period of **03 (Three) years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21-12-2023..... at New Delhi by

(Atul Garg)

Director

Ph. 011-23414000

Atul

Copy to:-

1. The Principal, Ambedkar School of Specialised Excellence, Kohat Enclave, Delhi- 110034.
2. The Director of Education, Government of NCT of Delhi. Old Sect. Delhi-110054
3. The Assistant Engineer (E), PWD Sub Division-2, Education Electrical Edn. 1, Division (N), Sec. 16, Rohini, Delhi-110089.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : Ambedkar School of Specialised Excellence (School ID- 1411259)
Located at Anandwas, Kohat Enclave, Delhi-110034.
2. Type of Occupancy : Educational
3. Building Comprised : Ground + Three Upper Floors & 01 MP Hall in 2nd floor.
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2021/BP/School/273 dated 17.08.2021
7. Date of inspection : 13/12/2023
8. Name of Inspecting Officer : ADO, R.K.Sinha
9. Name and designation of officers
From the building side : Smt. Mamta Saluja (H.O.S.)
10. Year of Construction : 2022-23
11. Applicant's letter No. : E Mail ID , Dated-17/10/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	4.5 m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	06	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.75 m × 4, 2.25 & 2.15 m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	All	Provided	MR
	f. Door Size	1.50 m	Provided	MR
		1.20 m & for MP Hall 2 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	1@300 sqm	Provided	MR
	• Types	ABC/CO2	Provided	MR
	• IS marking	Yes	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power 	NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
	MOEFA	NA	NA	NA
	Public Address System	NA	NA	NA
1.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
1.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
2.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
3.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-	-	-
		450 lpm	Provided	MR
		40 m	40 m	MR
		Required	Provided	MR
		-	-	-
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA

	NA			
	Refuge Area.			
	> Total Area	NA	NA	NA
	> Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/School/WZ/2023/418 dated 20/09/2023.

Note:- Electric meter and electrical panel are not under the staircase.

Keeping in view of substantial compliance of the minimum standards of fire prevention and fire safety measures required under rule it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.

Rajeev Kumar Sinha
 ADO(B.D)
 14/12/23

Signature of Inspecting Officer
 Name : Rajeev Kumar Sinha
 Designation : ADO/B.W.

Du(follow)

15/12/23

CFB
Vugh
 15/12/2023

Director (M)
 15/12/23

Any ans for FT letter in pursuance of signi files

Rajeev Kumar Sinha
 ADO(B.D)
 20/12/23

Director (DFS)
 20/12/23

CO/...309
 Dated 15/12/2023