



2/118

75  
आज़ादी  
अमृत महोत्सव

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2023/ 369

Dated: 22 / 12 / 2023

**FIRE SAFETY CERTIFICATE**

Certified that the building Ms. Chilis Grill and Bar (A unit of premier restaurant Pvt. Ltd.) Located at Shop No S-8 & 9, Second Floor, Pacific Mall, Subash Nagar, New Delhi-110018, is running at 2<sup>nd</sup> floor in a Pacific Mall in building comprised of Two Basements, Ground plus Four Upper Floors & Projection room was issued FSC vide Letter No. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023. The building/premises was re inspected by the officer concerned of this department on 13/12/2023 in the presence of Sh. Harish Rawat (Incharge) and found that the said premises/building have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Services, 2010 and the premises/building is fit for occupancy class "Assembly" (Group-D) and valid upto 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions Printed Overleaf.

Issued on ..... 22/12/2023 ..... at New Delhi by.

(Acting) Director

20/12/23  
18/12/2023

Copy to:

1. The owner/occupier, Ms. Chilis Grill and Bar (A unit of premier restaurant Pvt. Ltd.) Located at Shop No S-8 & 9, Second Floor, Pacific Mall, Subash Nagar, New Delhi-110018. **Online Application ID no. 2023042107033 dated. 28/11/2023.**
2. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ( [addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in).)
3. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. ([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com))

## INSPECTION REPORT

1. Name & address of the building	Ms. Chilis Grill and Bar (A unit of premier restaurant Pvt. Ltd.) Located at Shop No. S-8 & 9, Second Floor, Pacific Mall, Subash Nagar, New Delhi-110018.
2. Type of Occupancy	Assembly (Restaurant)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/2021/WZ/11 dated 08/01/2021
5. Fire Safety directives letter No	Mall FSC No. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023
6. Date of inspection	13/12/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Harish Rawat (Incharge)
9. Year of Construction	2011 (As per prev. insp. report dated 16/12/2023)
10. Applicant's letter No.	Online application no. 2023042107033 dated. 28/11/2023

The said restaurant is running at S-8 and 9, second floor in Pacific Mall in a building comprised of two basement, ground & four upper floors & projection room was issued FSC vide letter no. F.6/DFS/MS/WZ/Mall/2023/349 dated 21/07/2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	12 m 4.5m 06 m	Provided On Main Road Provided	MR MR MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	2 NA	Provided by mall NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.5 mtr each NA	Provided by mall NA	MR NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	e. No. of continuous staircases to terrace	Required	Provided by mall	MR
	f. Width of Corridor	Required	Provided by mall	MR
	g. Door Size	Old Case	145cm & 86 cm	MR (old case)
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	Provided by mall Provided by mall Provided by mall Provided by mall Provided by mall	NA NA NA NA NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA Required	NA Provided	NA MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 Nos. CO <sub>2</sub> , ABC type ISI marked	Provided Provided Provided	MR MR MR

6	<b>First-Aid Hose Reels.</b>	<b>Common with the Mall</b>		
	• Total numbers on each floor	Required	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided & connected with the Mall	MR
	• Location of Main Panel	Required at G.F.	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	Provided by mall	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	Provided	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>	<b>Common with the Mall</b>		
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	Provided	NA
	• Hose Box	NA	Provided	NA
13	<b>Pumping Arrangements.</b>	<b>Common with the Mall</b>		
	• Ground Level			
	➤ Discharge of main Pump	2850 lpm	Common with the Mall	MR
	➤ Head of Main pump	60 MH	Common with the Mall	MR
	➤ Number of main pumps	02	Common with the Mall	MR
	➤ Jockey Pump out put	180 lpm	Common with the Mall	MR
	➤ Jockey pump head	60 MH	Common with the Mall	MR
	➤ Standby Pump out put	2850 lpm	Common with the Mall	MR
	➤ Standby Pump Head	60 MH	Common with the Mall	MR
	➤ Auto Starting/ Manual stopping	Required	Common with the Mall	MR
	➤ Pump House Access	Required	Common with the Mall	MR
	• Terrace level			
	➤ Discharge of pump	900 lpm	Common with the Mall	MR
	➤ Head of the pump	40 m	Common with the Mall	MR
	➤ Power Supply	Required	Common with the Mall	MR
	➤ Auto Starting of pump	Required	Common with the Mall	MR
14	<b>Captive Water Storage for fire fighting.</b>	<b>Common with the Mall</b>		
	• Underground tank capacity	NA	2,00,000 litres	NA
	➤ Draw-off connection	NA	Provided	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	Provided	NA
	• Overhead Tank capacity	10,000 litres	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

N/22

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room (Common With Mall)</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/EH/2021/WZ/11 dated 08/01/2021 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

31/ADO/MN  
18/12/23

~~DY CPO (W/2)~~

~~SJS~~  
18/12/2023

Signature of the Inspecting Officer  
Name: Sarabjeet Singh  
Designation: ADO (MN)

DCFO... 95...  
Date... 20/12/23...

~~dy~~  
20/12

~~cfo~~  
~~21/12/2023~~  
~~Director~~  
~~21/12/23~~

~~NS~~

Uploaded  
22/12/23

~~S~~