



No.F6/DFS/MS/School/NDZ/2023/ 924

Dated: 21/12/2023

FIRE SAFETY CERTIFICATE

Certified that the **Lovely Vista School** located at **Nirman Vihar, Delhi - 110092** building comprised of **basement, ground plus three upper floors**, owned /occupied by **Lovely Vista School** have complied with the Fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on 06.12.2023 in the presence of Mrs. Suman Khanna (Principal) and found that the building / premises is fit for occupancy class '**Educational (Group-B)**' with effect from 21/12/2023 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 and also conditions printed below.

Issued on 21/12/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.
2. The Principal, Lovely Vista School located at Nirman Vihar, Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Lovely Vista School located at Nirman Vihar, Delhi-110092.
2	Building is comprised of	Basement + Ground + 02 upper floors.
3	Type of occupancy	Educational Building
4	Type of case	New Case
5	Details of previous FSC	Nil
6	Fire safety directives letter no.	NBC Part -IV
7	Date of inspection	06.12.2023
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)
9	Name of the designation of officer from the building side	Mrs. Suman Khanna (Principal)
10	Year of construction	1988
11	Applicant's letter no.	Outdoor Diary No. 8922 dated 21.11.2023

S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR		
1	Access to Building:					
	A	Road width	6.0 mtrs.	9.0 mtrs	MR	
	B	Gate width	N/A	NA	NA	
	C	Width of internal road	N/A	N/A	N/A	
2	Number, Width, Type and Arrangement of Exits:					
	A	Number of staircases				
		a	Upper floor	02 nos.	03 nos.	MR
		b	Basement	02 nos.	03 nos.	MR
	B	Width of staircases				
		a	Upper floor	1.50 mtrs.	1.50 mtr x 02 nos. & 1.20 mtrs. x 01 no.	MR
		b	Basement	1.50 mtrs.	1.20 mtr (Ramp) x 01 no. & 1.20 mtrs. X 02 nos.	MR
	C	Protection of exits				
		a	Fire check door	N/A	N/A	N/A
		b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace				
		E	Width of corridor	1.50 mtrs.	1.80 mtrs.	MR
		F	Door size	1.0 mtrs	1.20 mtrs	MR
3	Compartmentation:					
	A	Fire check door				
		A	NA	NA	NA	
	B	Sealing of electrical shafts				
		A	NA	NA	NA	
	C	Fire rating of shaft door				
		A	N/A	N/A	N/A	
	D	Water curtain				
		A	N/A	N/A	N/A	
	E	Fire dampers				
		A	N/A	N/A	N/A	
4	Smoke Management System:					
	A	Basement				
		A	N/A	N/A	N/A	
	B	Upper floor				
		A	N/A	N/A	N/A	


(u)


5.	Fire Extinguisher:				
	A	Total numbers	10 nos.	12 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	Provided	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtrs	30 mtrs	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:		Required	Provided	MR
9	Public Address System:		N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	01 no.	01 no.	MR
	C	Hose box	01 no.	01 no.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Ground level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Terrace Level				
	A	Discharge of pump	450 LPM	450 LPM	MR
	B	Head of the pump	40 mtrs	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR


14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	10,000 ltrs.	10,000 ltrs.	MR
15	Exit Signage:			
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car.	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			


The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO (L.N)

~~Dy.CFO (NDZ)~~

 19/12/23

~~C.F.O.~~

 20/12/2023

~~Director~~

 22/12/23

F.T Letter is setup for sign. Heady
~~Director~~

 21/12/23
 nheh


 21/12/2023