



No.F6/DFS/MS/School/NDZ/2023/ 919

Dated: 21/12/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Puneet Public School running at ground two upper floors building comprised of ground plus three upper floor (two separate blocks) located at Vishwas Nagar, Delhi-110032, owned / occupied by Puneet Public School was issued Fire Safety Certificate vide letter No. F.6/DFS/MS/2008/2388 dated 21/08/2008 The School building was re-inspected by the officer concerned of this department on 06/12/2023 in presence of Mr. Yogender Singh, Manager and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. 262-263 dated 17/01/2005 issued by Director of Education and that the School building is fit for occupancy class "Educational" (Group-B) with effect from 21/12/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010. Subject to the conditions printed below.

Issued on 21/12/2023 at New Delhi by.

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

**Copy to:-**

1. The Manager  
Puneet Public School located at Vishwas Nagar, Delhi-110032
2. The Dy. Director of Education, D-Block, Anand Vihar, Delhi-110092

**Conditions for the validity of Fire Safety Certificate**

1. Fire Safety Certificate is valid for ground floor, first floor, second floor only. Applicant has submitted an undertaking that he will not use third floor for school purpose failing which this FSC should be treated null & void.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

### INSPECTION REPORT

1. Name & address of the building : Puneet Public School, located at Vishwas Nagar, Delhi-110032
2. Building is comprised of : Ground plus three upper floors (Two separate blocks) (School running is G+2 upper floors)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/2008/2388 dt- 21/08/2008
6. Fire Safety direction letter No. : Circular 262-362 dated 17/01/2005 ✓
7. Date of Inspection : 06/12/2023
8. Name of the Inspecting officers : ADO Yashwant Singh Meena
9. Name and designation of Officer from the building side : Sh. Yoginder Singh, Manager
10. Year of Construction : 1977 & 2005
11. Applicant's letter No : Nil dated 06/11/2023

Sl. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Required	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 m	06 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor (Block 01)	01 nos.	02 nos. ✓	MR
	• Upper floor (Block 02)	01 nos.	02 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor (Block 01)	1.50m	1.20 mtr & 1.02 mtr	MR
	• Upper floor (Block 02)	1.50m	1.20 mtr & 0.76 mtr	MR
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no. each block	01 no. each block	MR
	e. Width of Corridor	1.50 mtr	1.50 mtr ✓	MR
	f. Door Size	01m	01 m ✓	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers			
	• Total numbers	12 nos.	12 nos. ✓	MR
	• Types	ABC /CO <sub>2</sub>	ABC /CO <sub>2</sub>	MR
	• IS marking	ISI marked	ISI marked	MR

(u)

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor &amp; each block</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 no.	01 no.	MR
		30m	30m	MR
		05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of main panel</li> <li>Location of repeater panel</li> <li>Alternate source of power</li> <li>Hooter</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>upper floor</li> <li>sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose box</li> </ul>	100 mm	100 mm	MR
		01 no.	01 no.	MR
		01 no.	01 no.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose box</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby pump out put</li> <li>Standby pump head</li> <li>Auto starting /manual stopping</li> <li>Pump house access</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul>	220 LPM	450 LPM ✓	MR
		40m	40m ✓	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead tank capacity</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		2,500 Ltr.	5,000 Ltr. ✓	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

Note:- Building comprised of ground plus three upper floor but management has given undertaking that they will not use third for school purpose and any purpose in any case. FSC is recommended for ground to second floor only

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule the FSC issued vide letter No. F.6/DFS/MS/2008/2388 dated 21/08/2008 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

  
15/12/2023

Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO (L.N)

DY.CFO/NDZ

Dir  
18/12/23

C.F.O.

Director

18/12/23

F.T. Letter is setup for sign. Already

Director

19/12/23

m

  
19/12/2023