

C-32

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

Dated: 28/12/2023

No.F6/DFS/MS/EH/2023/NDZ/378

FIRE SAFETY CERTIFICATE

Certified that the M/s Evergreen Hospitality LLP at Tolstoy Lane – 48, Janpath, New Delhi in a building comprised of Ground + Mezzanine + 02 upper floor and **Restaurant is running at Ground + Mezzanine floor only**. The FSC was earlier granted by this department vide letter No.F6/DFS/MS/EH/2016/NDZ/932 dated 03/06/16 to the restaurant M/S Janpath Grill House. Now, the premises was re-inspected by the officers concerned of this department on 20/12/23 in the presence of Mr. Balwant and found that the said premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant premises is fit for occupancy class **Assembly Building (Group D) Restaurant running at Ground & mezzanine floor only** and valid up to 31.03.2026 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued 28/12/2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi for Online ID no.2023121619629 dated 16/12/23 & FSC issued vide letter no. 349 dated 29.11.2023 (ID no 2023110418139) shall stand null & void
2. The Addl. Commissioner of Police (Lic), 1st floor, PS Defence Colony, New Delhi for Online ID no.2023121619629 dated 16/12/23 and FSC issued vide letter no. 349 dated 29.11.2023 (ID no 2023110418139) shall stand null & void.
3. The Manager, M/s Evergreen Hospitality LLP, Tolstoy Lane – 48, Janpath, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape/ corridor shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly be prohibited.

110
INSPECTION REPORT

1. Name & address of the building:- M/s Evergreen hospitality LLP at Ground Floor & Mezzanine floor, Tolstoy, 48, Janpath, New Delhi
2. Type of occupancy:- Assembly Building
Gr. + Mezzanine + 2 upper floor
(Restaurant at Ground+ Mezzanine floor only)
3. Type of case:- renewal
4. Details of previous NOC:- F6/DFS/MS/EH/2016/NDZ/932 dated 03/06/16
5. Fire safety directives No.- N/A
6. Date of inspection:- 20/12/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
Sh. Rajinder Atwal, (DO/CD)
8. Name & designation of officer
From the building side:- Mr. Balwant
9. Year of construction:- Old
10. Applicant's letter No:- Online ID no. 2023121619629 dated 16/12/23

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	09 mtr.	18 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors (Mezz. Floor)	02 Nos.	03 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.5 mtr.	1 Nos. 1.23 mtr. 1 Nos. 0.85 mtr. 1 Nos. 1.60 mtr. Mezzanine floor	MR(old case)
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr.	2 mtr. & 1.73 mtr	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per	Natural	MR

N/11

5.	Fire Extinguishers			
	1) Total numbers	10	10	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	ISI	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	02	03	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	5 mm	5 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	Ground	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	Provided	N/A
	5) Hooter's Location	N/A	Ground floor	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors,	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Total Number of hydrants	02	03	MR
	3) Hose box each floor	02	03	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			

N/12

	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			MR

The fire protection systems provided in the said premises were randomly tested, checked and found functional at the time of inspection. Further, the FSC issued for ground floor vide letter no. F6/ DFS/MS/ EH/2023/349 dated 29.11.2023 shall stand null & void.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/2016/NDZ/932 dated 03/06/16 under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

[Handwritten Signature]
25/12/23

Name:- Rajinder Atwal
Designation:-DO(CD)

Signature of the Inspecting Officer

[Handwritten Signature]
21/12/23

Name:- Ravinder Singh
Designation:- ADO (CC)

[Handwritten Signature]
26/12/2023

C.F/O
26/12/2023

[Handwritten Signature]
21/12/23