

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
 [Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F6/DFS/MS/2023/School/934

Dated: 27/12/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Sachdeva Global School Located at Sector – 18A, Phase-II Dwarka, New Delhi – 110078 comprised of basement + Ground+3 Upper Floors was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2020/SZ/167, dated 29/04/2020. The premise was re inspected by the officer concerned of this department on 15/12/2023 in the presence of Mr Pankaj Bhatnager (Admin officer) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 262-362 Dated 17/01/2005 issued by Directorate of Education, Govt. of NCT of Delhi and found that the building is fit for occupancy class B “Educational building” with effect from 27/12/2023 for a period of three years. In accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/12/2023 at New Delhi by.


 (Atul Garg)
 Director
 Delhi Fire Service.

Copy to:

1. The Principal, Sachdeva Global School, Sector – 18A, Phase-II Dwarka, New Delhi – 110078 .
2. Directorate of Education Old Secretariat Delhi – 110054. .

Following fire safety directives must be adhered to:-

- 1 **Temporary rooms shall not be reconstruct/re-open/use for any purpose.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. www.dfs.delhigovt.nic.in.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/30

INSPECTION REPORT

1. Name & address of the building: Sachdeva Global School Located at Sector - 18A, Phase-II Dwarka, New Delhi - 110078.

2. Type of Occupancy : Educational (Basement +Ground+ 3 UFs)

3. Type of Case : Renewal

4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/167, dated 29/04/2020

5. Fire Safety directives Letter No. : F6/DFS/MS/BP/04/2178, dated 22/09/04

6. Date of inspection : 15/12/2023

7. Name of the Inspecting Officer : Sh. Udai vir singh, ADO (DWK)

8. Name and designation of Officer

from the building side: Mr. Pankaj Bhatnagar(Admin.)

Total Area = 8227.26 sqm.
Covered Area = 7137.25 sqm
Class rooms = 59
No. of students = 1911

9. Year of Construction : 2006-07

10. Applicant's letter No. : SGS/Admin./9/2023, dated 25/11/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per FSC dt. 29/04/2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	45 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	06 Nos.	Provided	MR
	• Basements	02 Nos.	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5 mtr each	5X1.5m & 1X 1.43m	MR(Being old case)
	• Basements	1.5 m each	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in BF	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	4 Nos.	Provided	MR
	e. Width Of Corridor	1.5 m	2.35m	MR
	f. Door Size	01 mtr	.97m	MR(Being old case)
3.	Compartmentation			
	• Fire check door	Required in BF	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Natural ventilation	MR


N/31




5.	Fire Extinguishers		Provided	MR
	• Total numbers	68 nos.	ABC	MR
	• Types	ABC or CO ₂	ISI marked	MR
	• IS marking	ISI marked		
6.	First – Aid Hose Reels		Provided	MR
	• Total numbers on each floor	02 Nos.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	02 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450+180 lpm	Provided	MR
	➤ Head of the pump	40 mtr each	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	50,000 ltr	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	10,000 ltr	Provided	MR
	• Overhead Tank capacity			
15.	Exit Signage	Required	Provided	MR

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	02 ABC type Fire extinguishers provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/167, dated 29/04/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.


 Sign of Inspecting Officer
 Name Uday Vir Singh
 Designation ASO/DUT

 15/12/23
 18/12/2023
 Please clarify condition no. 1 of B.E.
 DO (Safety)
 Particular to DO Safety 19/12/23
 DO Sp. Rep. 20/12/23
 200 (Dutakhe)