



No.F6/DFS/MS/NDZ/BNQT/2024/ 01

Dated: 02/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Jashan Palace Banquet Hall located at B-1/A, Main Road Wazirabad Road, Bhajanpura, Delhi - 110053, comprise of building Basement, Ground plus one upper floor, owned /occupied by M/s Jashan Palace Banquet Hall, have complied with the Fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules,2010 and verified by the officer concerned of this department on 14.12.2023 in the presence of Mr. Jugnu Sethi (Owner) and found that the building/premises is fit for occupancy class "Assembly" (Group-D) Banquet Hall with effect from 02/01/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued 02/01/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
D/C @

Copy to:-

1. The Owner, M/s Jashan Palace Banquet Hall located at B-1/A, Main Road Wazirabad Road, Bhajanpura, Delhi - 110053.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2023053009966 dated 06.12.2023.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Jashan Palace Banquet Hall located at B-1/ Main Road Wazirabad Road, Bhajanpura, Delhi - 110053.			
2	Building is comprised of	Basement + Ground + 01 upper floor only.			
3	Type of occupancy	Assembly Occupancy			
4	Type of case	New Case			
5	Details of previous FSC	Nil			
6	Fire safety directives letter no.	NBC Part -IV			
7	Date of inspection	14.11.2023			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Jugnu Sethi (Owner)			
10	Year of construction	2008-2009			
11	Applicant's letter no.	MHA Application No. 2023053009966 dated 06.12.2023			
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part -IV Requirement	Provided at site	Remarks MR/NMI	
1	Access to Building:				
	A	Road width	6.0 mtrs.	12 mtrs.	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	02 nos.	02 nos.	MR
	b	Basement	02 nos.	02 nos.	MR
	B	Width of staircases			
	a	Upper floor	2.0 mtrs. & 1.50 mtrs.	2.0 mtrs. & 1.50 mtrs.	MI
	b	Basement	2.0 mtrs. & 1.50 mtrs.	2.70 mtrs. & 1.50 mtrs.	MI
	C	Protection of exits			
	a	Fire check door	Required	Provided	MR
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor		N/A	N/A
	F	Door size	2.0 mtrs. X 02 nos.	2.0 mtrs. X 02 nos.	MR
3	Compartmentation:				
	A	Fire check door	Required	Provided	MR
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:				
	A	Basement	Required	Ventilated	MR
	B	Upper floor	Required	Provided	MR

(u)

N/10

5.	Fire Extinguisher:				
	A	Total numbers	12 nos.	14 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:				
	A	Total numbers of each floor	01 no.	01 no.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:				
	A	Type of detectors	N/A	N/A	N/A
	B	Location of main panel	N/A	N/A	N/A
	C	Location of repeater panel	N/A	N/A	N/A
	D	Alternate source of power	N/A	N/A	N/A
	E	Hooters	N/A	N/A	N/A
8	MOEFA:				
			Required	Provided	MR
9	Public Address System:				
			N/A	N/A	N/A
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	N/A	N/A	N/A
	C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:				
	A	Size of riser/down-comer	100 mm	Provided	MR
	B	Number of hydrants per floor	01 no.	Provided	MR
	C	Hose box	01 no.	Provided	MR
12	Yard Hydrants:				
	A	Total number of hydrants	N/A	N/A	N/A
	B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:				
1	Terrace Level				
	A	Discharge of main pump	N/A	N/A	N/A
	B	Head of main pump	N/A	N/A	N/A
	C	Number of main pumps	N/A	N/A	N/A
	D	Jockey pump out put	N/A	N/A	N/A
	E	Jockey pump head	N/A	N/A	N/A
	F	Standby pump out put	N/A	N/A	N/A
	G	Standby pump head	N/A	N/A	N/A
	H	Auto starting /manual stopping	N/A	N/A	N/A
	I	Pump house access	N/A	N/A	N/A
2	Ground level				
	A	Discharge of pump	900 LPM	900 LPM	MR
	B	Head of the pump	40 mtrs.	40 mtrs.	MR
	C	Power supply	Required	Provided	MR
	D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	25,000 liters.	25,000 liters	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



25/12/2023

Signature of the Inspecting Officer

Name Yashwant Singh Meena

Designation ADO (L.N)

Dy.CFO (NDZ)

KMP
28/12/23

C.F.O.

Khush
29/11/2023

Director
11/11/24

F.T Letter is put up for sign. Please

Director
9/11/24

NK

Uploaded
03/11/24

01/11/2024