



No.F6/DFS/MS/EH/NDZ/ 2023/02

Dated: 02/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **Shots Lounge and Bar (Unit of Blessworld Lounge and Bar Private Limited at Shop No. G22 & G23, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi-110032, running at ground floor only, building comprised of two basement, ground plus three upper floor, owned/occupied Blessworld Lounge and Bar Private Limited** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 20/12/2023 in the presence of Mrs. Deepika Soni (Owner) and found that the building/premises is fit for **basement & upper ground floor** of occupancy class "Assembly" (Group D) "Eating House" with effect from 02/01/2024 valid up to 31/03/2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 02/01/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

Copy to:-

1. The Owner, Shots Lounge and Bar Unit of Blessworld Lounge and Bar Private Limited at Shop No. G22 & G23, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi-110032.
2. The Joint Commissioner of police (Lic.), 1st Floor, P.S Defence Colony, New Delhi-24 w.r.t. - MHA portal ID - 2023113019037 dated 07/12/2023.

Conditions for the validity of Fire Safety Certificate:

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. Basement shall be used strictly as per Building By-Laws 1983.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	Shots Lounge and Bar Unit of Blessworld Lounge and Bar Private Limited located at Shop No. G22 & G23, Ground floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi-110032.
2.	Building is comprised of	Two Basement + Ground + 03 upper floors only. (Restaurant is Ground floor only)
3.	Type of occupancy	Eating House (Restaurant)
4.	Type of case	New Case
5.	Details of previous FSC	Nil (FSC also issued to the Cross River Mall vide letter No.F6/DFS/MS/2023/NDZ/75 dated 13/02/2023.
6.	Fire safety direction letter no.	NBC Part-IV
7.	Date of inspection	20.12.2023
8.	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9.	Name of the designation of officer from the building side	Mrs. Deepika Soni (Owner)
10.	Year of construction	2015
11.	Applicant's letter no	MHA Application No. 2023113019037 dated 07/12/2023

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
a	Road width	12 mtrs.	24 mtrs	MR
b	Gate width	4.5 mtrs.	7.0 mtrs	MR
c	Width of internal road	6.0 mtrs.	6.0 mtrs	MR
2	Number, Width, Type and Arrangement of Exits			
A	Number of staircases			
a	Upper floor	NA	NA	NA
b	Basement	NA	NA	NA
B	Width of staircases			
a	Upper floor	NA	NA	NA
b	Basement	NA	NA	NA
C	Protection of exits			
a	Fire check door	Required	Provided	MR
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	NA	NA	NA
E	Width of corridor	NA	NA	NA
F	Door size	1.50 mtr x 02 ✓	1.50 mtr x 02 ✓	MR
3	Compartmentation			
a	Fire check door	Required	Provided	MR
b	Sealing of electrical shafts	Required	Provided	MR
c	Fire rating of shaft door	NA	NA	NA
d	Water curtain	NA	NA	NA
e	Fire dampers	NA	NA	NA
4	Smoke Management System.			
a	Basement	NA	Provided	NA
b	Upper floor	Required	Provided	MR

W

5.	Fire Extinguisher			
a	Total numbers	04 nos.	04 nos.	MR
b	Types	CO ₂ & ABC	CO ₂ & ABC	MR
c	ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels. Provided In the Mall			
a	Total numbers of each floor	06 nos.	Provided by the Mall	MR
b	Length of hose reel hose	30 mtrs.	Provided by the Mall	MR
c	Nozzle diameter	05 mm	Provided by the Mall	MR
7	Automatic fire detection and alarming system.			
a	Type of detectors	Heat & Smoke	Provided	N/A
b	Location of main panel	Control Room	Provided	N/A
c	Location of repeater panel	Security Room	Provided	N/A
d	Alternate source of power	Battery & D.G Set	Provided	N/A
e	Hooter	Stair Case	Provided	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	NA	Provided	NA
10	Automatic Sprinkler System. Provided In the Mall			
a	Basement	NA	NA	NA
b	Upper floors	NA	NA	NA
c	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants Provided In the Mall			
a	Size of riser	Required	Provided by the Mall	MR
b	Number of hydrants per floor	Required	Provided by the Mall	MR
c	Hose Box	Required	Provided by the Mall	MR
12	Yard Hydrants.			
a	Total number of hydrants	NA	Provided	NA
b	Hose Box	NA	Provided	NA
13	Pumping Arrangements. Provided In the Mall			
A	Ground Level			
a	Discharge of main Pump	2850 LPM	2850 LPM	MR
b	Head of Main Pump	60 mtrs.	60 mtrs.	MR
c	Number of main pumps	02 nos.	02 nos.	MR
d	Jockey pump out put	180 LPM x 02	180 LPM x 02	MR
e	Jockey pump head	60 mtrs.	60 mtrs.	MR
f	Standby pump out put	2850 LPM	2850 LPM	MR
g	Standby pump head	60 mtrs.	60 mtrs.	MR
h	Auto starting /manual stopping	Required	Provided	MR
i	Pump House Access	Required	Provided	MR
B	Terrace Level			
a	Discharge of pump	NA	NA	NA
b	Head of the Pump	NA	NA	NA
c	Power supply	NA	NA	NA
d	Auto Starting of pump	NA	NA	NA

Shots Lounge and Bar Unit of Blessworld Lounge and Bar Private Limited located at Shop No. G22 & G23, Ground floor, Plot No. 9B & 9C Cross River Mall, CBD Shahdara, Delhi-110032.

(u)

00 /

14	Captive Water Storage for Fire Fighting.		Provided In the Mall	
	a	Underground tank capacity	N/A	2,00,000 Ltrs.
	b	Draw-off connection	N/A	Provided by the Mall
	c	Fire service inlet	N/A	Provided by the Mall
	d	Access to tank	N/A	Provided by the Mall
	e	Overhead Tank capacity	20,000 ltrs.	50,000 ltrs.
15	Exit Signage.		Required	Provided
16	Provision of Lifts.		Provided In the Mall	
	a	Pressurization of Lift Shaft	NA	Provided
	b	Pressurization of Lift lobby	NA	Provided
	c	Communication in lift car	NA	Provided
	d	Firemen's grounding switch	NA	Provided
	e	Lift Signage	NA	Provided
17	Standby power supply		Required	Provided
18	Refuge Area.			
	a	Total area	NA	NA
	b	Location	NA	NA
19	Fire Control Room			
	a	Detector system panel	NA	Provided
	b	Flow switch panel	NA	Provided
	c	PA system panel	NA	Provided
	d	Battery backup	NA	Provided
	e	Building Floor Plans	NA	Provided
20	Special Fire Protection systems for protection of special Risks, if any:		NA	Provided in all LT & HT Panels

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



27/12/2023

Signature of the Inspecting Officer
Name: - Yashwant Singh Meena
Designation: - ADO (L.N)

Dy.CFO (NDZ)

C.F.O.


28/12/23


29/12/2023

Director 
11/01/2024