



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Indl./2024/SZ/EH/04

Dated: 03/01/2024

FIRE SAFETY CERTIFICATE

Certified that M/s Taj Sats Air Catering Limited located at IGI Airport Complex, New Delhi-110037, comprised of basement, ground plus one upper floor was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Indl./2020/SZ/EH/154 dated 05/11/2020. The premise was re-inspected by the officers concerned of this department on 23/12/2023 in the presence of Sh. Ashok Surya (Chief Engineer) and observed that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "Group 'G' Industrial" (Flight Kitchen) with effect from 03/01/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/01/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Health Officer, Health Department, Municipal Corporation of Delhi, Najafgarh Zone, Near Dhansa Stand, Najafgarh, New Delhi-110043
2. The Chief Engineer, M/s Taj Sats Air Catering Ltd located at IGI Airport Complex, New Delhi-110037

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc, may be got verified from concerned authorities.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	M/s Taj Sats Air Catering Limited located at IGI Airport Complex, New Delhi-110037		
2.	Type of Occupancy	Group 'H' (Industrial Building i.e. Flight Kitchen)		
3.	Building Comprised of	Ground + One upper floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/Indl./2020/SZ/EH/154 Dt. 05/11/2020		
6.	Fire Safety directives/approval letter	Nil		
7.	Date of inspection	23/12/2023		
8.	Name of Inspecting Officer	DO (SD) Manoj Kumar Sharma & ADO (SJ) Santosh Kumar		
9.	Name and designation of Officer from building side	Sh. Ashok Surya (Chief Engineer)		
10.	Year of Construction	1983		
11.	Applicant letter No.	Email dated 05/12/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6m	9m	MR
	• Gate width	4.5m	5m	MR
	• Width of internal road	Required	Provided	MK
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos	2 Nos	MR
	• Basements	1 No + 01 ramp	1 No + 01 ramp	MR (old case)
	b. Width of staircases			
	• Upper floors	Required	1.18m (each)	MR (old case)
	• Basements	Required	1.19m & ramp-3.20m	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 No	01 No	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 ACPH	Exhaust fan provided	MK
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	80 nos.	120 nos.	MR
	• Types	ABC / CO ₂	ABC, CO ₂ & W.CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	Required	BF-01 No, GF-10 Nos & FF-07 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detector • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	Required	Smoke & Heat	MR
		Required	Provided in Basement	MR
		Required	Provided at reception	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements • Ground & Above floors • Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down- comer • Number of hydrants per floor • Hose Box 	150 mm	150 mm	MR
		Required	BF-01 No, GF-10 No & FF-07 Nos	MR
		Required	BF-01 No, GF-10 No & FF-07 Nos	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	Required	04 Nos	MR
		Required	04 Nos	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	1830 LPM	1830 LPM	MR
		70m	70m	MR
		Two	Two	MR
		180 LPM	180 LPM	MR
		70m	70m	MR
		1830 LPM	1830 LPM	MR
		70m	70m	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14		Captive water Storage for fire fighting		
	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	90,000 Ltrs	90,000 Ltrs	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltrs	10,000 Ltrs	MR
		Required	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	NA	NA	NA
		NA	NA	NA

19.	Fire control room	Required	Provided	MR
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans			MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	CO ₂ & ABC Fire Extinguishers provided in electric panel room		

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F.6/DFS/MS/Indl./2020/SZ/EH/154 Dt. 05/11/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)

Santosh Kumar
 28/12/23
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

CFO (HQ) *Wagh*
 29/12/2023
Director *Wagh*
 29/12/23
ADO (SJ)

Sir, F.T letter is pending for your signature pl.
Wagh
 2/1/24
Manoj
 02.01.24