



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2023/ 07

Dated: 04/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Gail (India) Ltd. at Plot No. 16, Bikaji Kama Place, R.K. Puram, New Delhi - 110066 comprises of two basements, lower ground, upper ground plus six upper floor owned/occupied by M/s Gail (India) Ltd. was granted FSC by this department vide letter No. F6/DFS/MS/2023/SZ/134 dated 19/02/2021. The premises was re-inspected by the officer concerned of this department on 28/12/2023 in the presence of Mr. R.B. Khandelwal DGM (Elec.), Mr. Naveen Kumar (F&S) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "Business Group-E" with effect from 04/01/2024 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 04/01/2024 at New Delhi by.


(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. Naveen Kumar, Manager (F&S),
M/s Gail (India) Ltd.,
Plot No. 16, Bikaji Kama Place, R.K. Puram, New Delhi - 110066.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT				
1	Name & address of the building	M/s Gail (India) Ltd. at Plot No. 16, Bikaji Kama Place, R.K. Puram, New Delhi - 110066		
2	Type of Occupancy	Business Building, Group - E Two Basements, Lower ground, Upper Ground Plus Six Upper floor		
3	Type of Case	Renewal		
4	Details of previous FSC	No. F6/DFS/MS/2015/SZ/134 dated 19/02/2021		
5	Fire Safety directives Letter No.	Nil		
6	Date of inspection	28/12/2023		
7	Name of the Inspecting Officer	M. K. Sharma DO/SD		
8	Name and Designation of Officer from the building side.	Mr. R.B. Khandwal DGM (Elec.) & Mr. Naveen Kumar (F&S)		
9	Year of Construction	1990		
10	Applicant's letter No./ Online Id No.	Gail/HR-Admin/01/2023 dated 05/12/2023		
Sr. No.	Minimum Standards on Fire Prevention and Fire Safety as per NBC	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building			
	1 Road Width	Approachable from north side	06 mtr.	MR
	2 Gate Width	6 mtr.	Boundary less building	MR
	3 Width of Internal Road	N/A	N/A	N/A
2	Number, Width, Type & Arrangements of exits			
	A Number of Staircase			
	1 Upper Floors	02 nos. at all levels & 03 Nos at 1 st floor	Provided	MR
	2 Basement	02 nos. + 01 ramps	Provided	MR
	B Width of Staircase			
	1 Upper Floors	1.5 & 1.2 mtr.	GF to Terrace: 1.2 m GF to terrace (excluding UGF): 1.4 m GF to 1 st floor 1.4 m	MR
	2 Basement	1.5 & 1.2 mtr.	1.06 m & 1.25 - 1.45 m	MR (Old Case)
	C Protection of Exits			
	1 Fire Check door	Required	Provided	MR
	2 Pressurization	(Vent at Top is required)	Provided	MR
	D No. of Continuous S/C to terrace	02 nos.	Provided	MR
	E Width of Corridor	N/A	N/A	N/A
	F Door Size	N/A	N/A	N/A
3	Compartmentation			
	1 Fire check door	Required	Provided	MR



N/52

	2 Sealing of electrical shafts	Required	Provided	MR
	3 Fire rating of shaft door	Required	Provided	MR
	4 Water curtain	N/A	N/A	N/A
	5 Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	1 Basements	12 a/c per hour	Provided	MR
	2 Upper floors	N/A	N/A	N/A
5	Fire Extinguishers			
	1 Total Numbers	110 Nos.	120 Nos.	MR
	2 Types	ABC & CO2	Provided	MR
	3 ISI Marking	Required	Provided	MR
6	First-Aid Hose Reel			
	1 Total number on each floor	02 nos.	02 nos. at each floor	MR
	2 Length of hose reel hose	30 m	30 m	MR
	3 Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection & Alarming System			
	1 Type of detectors	Required	Provided	MR
	2 Location of main panel	Required	LGF level	MR
	3 Location of repeater panel	N/A	N/A	N/A
	4 Alternate source of power	Required	Provided	MR
	5 Hooter's Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	1 Basement	Required	Provided	MR
	2 Upper floors	N/A	N/A	N/A
	3 Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	1 Size of riser/down-comer	150 mm	Provided	MR
	2 Number of hydrants per floor	02 nos.	02 nos.	MR
	3 Hose box	02 nos.	02 nos.	MR
12	Yard Hydrants			
	1 Total number of hydrants	02 Required	Provided	MR
	2 Hose box	02 Required	Provided	MR
13	Pumping Arrangement			
	A Ground level			
	1 Discharge of main pump	2400 LPM	Provided	MR
	2 Head of main pump	70 m	Provided	MR
	3 Number of main pump	02	Provided	MR
	4 Jockey pump out put	180 LPM	Provided	MR
	5 Jockey pump head	70 m	Provided	MR
	6 Stand by pump output	2400 LPM	Provided	MR
	7 Stand by pump head	70 m	Provided	MR
	8 Auto starting/Manual stopping	Required	Provided	MR
	B Terrace level			
	1 Discharge of pump	N/A	N/A	N/A
	2 Head of pump	N/A	N/A	N/A
	3 Power supply	N/A	N/A	N/A
	4 Auto starting of pump	N/A	N/A	N/A

Capacity of Water Storage for Fire Fighting				
14	1 Underground tank capacity	2,00,000 ltr.	Provided	MR
	2 Draw-off connection	Required	Provided	MR
	3 Fire service inlet	Required	Provided	MR
	4 Access to tank	Required	Provided	MR
	5 Over head tank capacity	50,000 ltr.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	1 Pressurization of lift shaft	(Vent at Top is required)	Provided	MR
	2 Pressurization of lift lobby	N/A	N/A	N/A
	3 Communication in lift car	Required	Provided	MR
	4 Fireman's switch	Required	Provided	MR
	5 Lift signage	N/A	N/A	N/A
17	Stand by Power Supply	Required	Provided (DG set)	MR
18	Refuge Area	Required	450 m ² protected with FCD	MR
	Total area location	Required	3 rd floor	MR
19	Fire Control Room			
	1 Detector system panel	Required	Provided	MR
	2 Flow switch panel	N/A	N/A	N/A
	3 PA system panel	Required	Provided	MR
	4 Battery backup	Required	Provided	MR
	5 Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any: Segregation of HT LT room, Transformer/DG room required.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/2015/SZ/134 dated 19/02/2021, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

M.K. Sharma
29/12/24
Signature of the Inspection Officer
Name :- M.K. Sharma
Designation:- DO/SD

CFO/HQ
at *Mugh*
21/12/24
Director
[Signature]
11/1/24

[Signature]
DO/SD

F.T. letter is put up for sig. *[Signature]*

Dir-1 DFS
[Signature]
21/12/24

[Signature]
21/12/24