



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 12

Dated: 04/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **Internet Data Centre, VSNL, Complex at Greater Kailash-I, New Delhi - 110048** comprises of **Ground plus Five Upper Floor** owned/occupied by TATA Communications was granted FSC by this department vide letter No. **F6/DFS/MS/Business/2022/SZ/40** dated **27/01/2022**. The premises was re-inspected by the officer concerned of this department on **30/12/2023** in the presence of Mr. Sunil Kumar Jha & Mr. Gaurav Gupta and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy "**Business Group-E**" with effect from **04/01/2024** for period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 04/01/2024 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Manager,
Internet Data Centre, VSNL, Complex, Greater Kailash-I, New Delhi - 110048.
2. The Executive Engineer (Bldg.) Jal Vihar, Lajpat Nagar, New Delhi - 110024.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".



N/30

INSPECTION REPORT				
1	Name & address of the building	Internet Data Centre, VSNL, Complex at Greater Kailash-I, New Delhi - 110048		
2	Type of Occupancy	Business Building, Group - E Ground Plus Five Upper floor		
3	Type of Case	Renewal		
4	Details of previous FSC	No. F6/DFS/MS/Business/2022/SZ/40 dated 27/01/2022		
5	Fire Safety directives Letter No.	Nil		
6	Date of inspection	30/12/2023		
7	Name of the Inspecting Officer	M. K. Sharma DO/SD		
8	Name and Designation of Officer from the building side	Mr. Sunil Kumar Jha & Mr. Gaurav Gupta		
9	Year of Construction	2014		
10	Applicant's letter No./ Online Id No.	email dated 14/12/2023		
Sr. No.	Minimum Standards on Fire Prevention and Fire Safety as per NBC	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building			
	1 Road Width	6 mtr.	Provided	MR
	2 Gate Width	5 mtr.	Provided	MR
	3 Width of Internal Road	6 mtr.	Provided	MR
2	Number, Width, Type & Arrangements of exits			
	A Number of Staircase			
	1 Upper Floors	4 nos.	Provided	MR
	2 Basement	N/A	N/A	N/A
	B Width of Staircase			
	1 Upper Floors	1.5 mtr.	1.82, 1.87, 1.85 & 1.9 m	MR
	2 Basement	N/A	N/A	N/A
	C Protection of Exits			
	1 Fire Check door	Required	Provided	MR
	2 Pressurization	Required (in two staircase)	Provided	MR
	D No. of Continuous S/C to terrace	04 nos.	Provided	MR
	E Width of Corridor	1.5 m	Provided	MR
	F Door Size	1 m	Provided (final exit)	MR
3	Compartmentation			
	1 Fire check door	Required	Provided	MR
	2 Sealing of electrical shafts	Required	Provided	MR
	3 Fire rating of shaft door	Required	Provided	MR
	4 Water curtain	N/A	N/A	N/A
	5 Fire Dampers	Required	Provided	MR

w



N/31

4	Smoke Management System			N/A	N/A
	1 Basements	12 a/c per hour		M.V. Provided	MR
	2 Upper floors	12 a/c per hour			
5	Fire Extinguishers			71 Nos.	MR
	1 Total Numbers	71 Nos.		Provided	MR
	2 Types	ABC & CO2		Provided	MR
6	First-Aid Hose Reel				MR
	1 Total number on each floor	04 nos.		Provided	MR
	2 Length of hose reel hose	30 m		30 m	MR
	3 Nozzle diameter	05 mm		05 mm	
7	Automatic Fire Detection & Alarming System				MR
	1 Type of detectors	Smoke & Heat		Provided	MR
	2 Location of main panel	Required		Ground floor	MR
	3 Location of repeater panel	N/A		N/A	N/A
	4 Alternate source of power	Required		Provided	MR
	5 Hooter's Location	Required		Provided	MR
8	MOEFA	Required		Provided	MR
9	Public Address System	Required		Provided	MR
10	Automatic Sprinkler System				
	1 Basement	N/A		N/A	N/A
	2 Upper floors	Required		Provided	MR
11	Internal Hydrants				MR
	1 Size of riser/down-comer	100 mm		Provided	MR
	2 Number of hydrants per floor	04 nos.		02 nos.	MR
12	Yard Hydrants				MR
	1 Total number of hydrants	06 nos.		Provided	MR
	2 Hose box	06 nos.		Provided	MR
13	Pumping Arrangement				
	A Ground level				
	1 Discharge of main pump	2850 LPM		Provided	MR
	2 Head of main pump	60 m		80 m	MR
	3 Number of main pump	02		Provided	MR
	4 Jockey pump out put	180 LPM		Provided	MR
	5 Jockey pump head	60 m		80 m	MR
	6 Stand by pump output	2850 LPM		Provided	MR
	7 Stand by pump head	60 m		80 m	MR
	8 Auto starting/Manual stopping	Required		Provided	MR
	B Terrace level				
	1 Discharge of pump	N/A		N/A	N/A
	2 Head of pump	N/A		N/A	N/A
	3 Power supply	N/A		N/A	N/A
4 Auto starting of pump	N/A		N/A	N/A	
14	Capacity of Water Storage for Fire Fighting				
	1 Underground tank capacity	2,00,000 ltr.		Provided	MR
	2 Draw-off connection	Required		Provided	MR
	3 Fire service inlet				MR
		Required		Provided	MR

	4 Access to tank	Required	Provided	MR
	5 Over head tank capacity	20,000 ltr.	Provided	MR
		Required	Provided	MR
15	Exit Signage.			MR
16	Provision of Lifts.			MR
	1 Pressurization of lift shaft	Required	Provided	MR
	2 Pressurization of lift lobby	Required	Provided	MR
	3 Communication in lift car	Required	Provided	MR
	4 Fireman's switch	Required	Provided	MR
	5 Lift signage	Required	Provided	MR
17	Stand by Power Supply	N/A	N/A	N/A
18	Refuge Area	N/A	N/A	N/A
	Total area location			
19	Fire Control Room	N/A	Provided	MR
	1 Detector system panel	N/A	N/A	N/A
	2 Flow switch panel	N/A	Provided	MR
	3 PA system panel	Required	Provided	MR
	4 Battery backup	Required	Provided	MR
	5 Building floor plan	N/A	N/A	N/A
20	Special Fire Protection System for Protection of special Risk, if any: Co ₂ Manual Flooding in LT & HT Panels.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection and the system is common with whole building.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/Business/2022/SZ/40 dated 27/01/2022, renewal under Rule 35 of the Delhi Fire Service Rules 2010, is recommended.

M.K. Sharma
 Signature of the Inspection Officer
 Name :- M.K. Sharma
 Designation:- DO/SD

CFO/MQ
[Signature]
 02/01/2024

[Signature]
 9/1/24

DO/SD

[Signature]

R.L. letter to put up for reg-pl

[Signature]
 11/1/24

[Signature]
 03/1