



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/SZ/2024/ 15

Dated: 05 / 01 / 2024

FIRE SAFETY CERTIFICATE

Certified that the MCD Pratibha School, Sewa Nagar, N-Block at Redevelopment of GPRA Colony Kasturba Nagar, New Delhi-110003, comprised of Ground & two upper floors only, have complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of this department on 21/12/2023 in the presence of Sh. Subhasis Pal (Sr. Manager), ITD Cementation India Ltd and observed that the said premise is fit for occupancy class "Educational Group B" (School) with effect from 05 / 01 / 2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 05/01/2024 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer & Senior Manager (Elect.), Redevelopment Project Electrical Division-I, CPWD, Vidyut Bhawan, Shankar Market, New Delhi-110001
2. Project Manager, M/s ITD Cementation India Ltd, Beside Flat No. C-334, Sewa Nagar, Kotla Mubarakpur, Near Ram Leela Park/ Sewa Nagar Railway Station, New Delhi-110003

Conditions for the validity of Fire Safety Certificate:

1. This FSC is valid for half of the newly constructed school building as on date; intimation shall be given before occupancy of remaining part as and when constructed.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

N-9

INSPECTION REPORT

1.	Name & address of the building	MCD Pratibha School, Sewa Nagar, N-Block, Redevelopment of GPRA Colony Kasturba Nagar, New Delhi-110003		
2.	Type of Occupancy	Educational Group-B (School)		
3.	Building Comprised of	Ground plus two upper floors.		
4.	Type of Case	New		
5.	Details of previous NOC No.	Nil		
6.	Fire Safety directives Letter No.	F.6/DFS/MS/2020/BP/170 Dt. 21/04/2020		
7.	Date of inspection	21/12/2023		
8.	Name of the Inspecting Officer	DO (SD) M.K. Sharma & ADO (SJ) Santosh Kumar		
9.	Name and designation of Officer from the building side	Sh. Subhasis Pal (Sr. Manager), ITD Cementation India Limited		
10.	Year of Construction	2022 - 2023		
11.	Applicant's letter No	Outdoor diary No.8800 dated 17/11/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	NBC / UBBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building	School within GPRA Colony Kasturba Nagar		
	• Road width	6m	6m	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	6m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos	02 + 01 Ramp*	MR*
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m (each)	2m (each)	MR*
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	One	Provided	MR
	e. Width of Corridor	1.5m	2m	MR
	f. Door Size (Classroom / MP Hall)	1m / 1.5m	1.2m / 2m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 Nos	12 Nos	MR
	• Types	ABC/ W.CO ₂	ABC & CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	2 Nos	2 Nos	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	450+450 LPM	MR
	➤ Head of the pump	35m .	35m (each)	
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note: The width of ramp is not generated and shown as MR* as only half of the building is constructed at present. The existing school building shall be demolished and the ramp shall be constructed along with remaining part.

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, issuance of Fire Safety Certificate under rule 35 of Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

msd
 Signature of the Inspecting Officer
 Name: Manoj Kumar Sharma
 Designation: DO (SD)

Sharma
 29-12-23
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: ADO (SJ)

CFO (HO) on leave

Director
 3/1/24
Amr (S)

Sir, f.T letter is put up for your signature

Director
 5/1/24
msd

Sharma
 04-01-24