



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/CNG/2024/SZ/20

Dated: 08 / 01 / 2024

**FIRE SAFETY CERTIFICATE**

Certified that M/s **Indraprastha Gas Limited Retail Outlet (CNG Pump)** located at Sarojini Nagar, Ring Road, New Delhi, comprised of ground floor only, owned/occupied by Indraprastha Gas Limited was earlier issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/CNG/2021/31 dated 15/01/2021. The premises was re-inspected by the officer concerned of this department on 29/12/2023 in the presence of Mr. Rahul Kirar (Fire Officer) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with OISD-179/ rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Hazardous (Group 'J')** with effect from 08/01/2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 of Delhi Fire Service Rules, 2010 and subject to compliance of the conditions mentioned below.

Issued on 08/01/2024 at New Delhi by

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
MCSE

Copy to: -

1. Sh. Ajay Khatri, General Manager (Fire & Safety), IGL Bhawan, Plot No. 4, Community Centre, R.K. Puram, Sector-9, New Delhi-110022

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	Indraprastha Gas Ltd. Retail Outlet (CNG Pump) at Sarojini Nagar, Ring Road, New Delhi		
2	Type of Occupancy	Hazardous		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/CNG/2021/31 dated 15/01/2021		
6	Fire Safety Directives Letter No	F.5/DFS/3A/2000/BP/104 dated 23/03/2000 (C/20) F5/(3A)/DFS/2011/214 dated 26/09/2011 (C/38) F6/DFS/MS/CNG/2012/2095 dated 07/6/2012 (C/56) F6/DFS/MS/CNG/2013/2596 dated 27/11/2013 (C/89)		
7	Date of Inspection	29/12/2023		
8	Name of the Inspecting Officers	Santosh Kumar, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Rahul Kirar (Fire Officer)		
10	Year of construction	2000		
11	Applicant letter No.	Outdoor Diary No. 11145 dated 22/12/2023		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements/ Existing Fire Protection System	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	Required	30m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	N/A	N/A	N/A
	➤ Basement.	N/A	N/A	N/A
	<b>b) Width of Staircase</b>			
	➤ Upper floors	N/A	N/A	N/A
	➤ Basement	N/A	N/A	N/A
	<b>c) Protection of exits</b>			
	➤ Fire check door	N/A	N/A	N/A
	➤ Pressurization	N/A	N/A	N/A
	<b>d) No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e) Width of corridor</b>	N/A	N/A	N/A
	<b>f) Door size</b>	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	<b>Smoke Management system.</b>			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	20 Nos	DCP 75kg=7, 10kg=15nos. CO <sub>2</sub> 4.5kg=4 Total=26 nos.	MR
	• Types	CO <sub>2</sub> & DCP	CO <sub>2</sub> & DCP	MR
	• ISI Marking	ISI marked	Provided	MR
6.	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	N/A	N/A	N/A
	• Length of hose-reel hose.	N/A	N/A	N/A
	• Nozzle Diameter	N/A	N/A	N/A



19.	<b>Fire Control Room.</b>			
	<ul style="list-style-type: none"> <li>• Detector system panel.</li> <li>• Flow switch panel.</li> <li>• PA system panel.</li> <li>• Battery backup.</li> <li>• Building floor plan.</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	N/A	CO <sub>2</sub> flooding system connected through detectors provided in each compressor	N/A

The fire protection systems provided in the building/premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/CNG/2021/31 dated 15/01/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

*S Kumar*  
01.01.24

Signature of the Inspecting Officer  
Name: Santosh Kumar  
Designation: ADO (SJ)

DO (SD)

*Mull*  
03/1/24

Cfo on leave

Director *MV*  
4/1/24

*AD/SJ*

Sir, F.T letter is pending for your signature pl.

Director *by*  
8/1/24

*S Kumar*  
05.01.24

*AD/SJ* *Mull*