



No. F6/DFS/MS/EH/SZ/2024/09

Dated: 08/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Mughal Cuisine Foods Pvt. Ltd. located at D-23 & 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-25, was running on Ground floor of the building which is comprised of Basement + Ground + 3 upper floors & was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/EH/2021/SZ/17 dated 19.01.2021. The building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 02.01.2024 in the presence of Mr. Anas Khan (Owner) & Mr. Mehboob Alam (Manager) and found that the building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises/building (Ground floor only) is fit for occupancy of Group D "Assembly Building" (Restaurant) and valid upto 31.03.2027 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on08/01/2024.....at New Delhi by

(Atul Garg)
Director
Delhi Fire Service

Reference: MHA Portal Online application no. 2023122019770 dated 21.12.2023.

AL
02/1/24

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid for Ground floors only.
2. All the means of escape/entry/exit shall be kept free from any obstruction
3. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
4. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
5. The trained fire fighting staff should be available round the clock.
6. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
10. Basement shall be used as per NBC/UBBL.
11. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT


1	Name & address of the building	M/s Mughal Cuisine Foods Pvt. Ltd. located at D-23 & 24, Kalindi Kunj Road, Abul Fazal Enclave-I, Jamia Nagar, New Delhi-25.		
2	Building is comprised of	Basement + Ground + 03 upper floors Ground- Restaurant only Basement- Parking Upper floors- Residential (Restaurant running at ground floor of the building) Group-D, Assembly building, (Restaurant).		
3	Type of occupancy	Renewal		
4	Type of case	F6/DFS/MS/EH/2021/SZ/17 dated 19.01.2021		
5	Details of previous FSC	Delhi Fire Service Act-2007 & Rule 2010.		
6	Fire safety direction letter no.	02.01.2024		
7	Date of inspection	Rajesh Kumar Shukla, ADO (M. Road)		
8	Name of the inspecting officers	Mr. Anas Khan (Owner) & Mr. Mehboob Alam (Manager)		
9	Name of the designation of officer from the building side	2005		
10	Year of construction	Online ID no. 2023122019770 dated 21.12.2023		
11	Applicant's letter no.			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement as per Rule 35 (6)	Provided at Site	Remarks MR/NMR
1	Access To Building:			
	Road width	Required	6.0 mtrs	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	Restaurant at ground floor only			
	A	Number of staircases		
		a Upper floor	NA	NA
		b Basement	NA	NA
	B	Width of staircases		
		a Upper floor	NA	NA
		b Basement	NA	NA
	C	Protection of exits		
		a Fire check door	NA	NA
		b Pressurization	NA	NA
	D	No. of continuous staircases to terrace	NA	NA
	E	Width of corridor	NA	NA
	F	Door size (exits)	Required (2 nos.)	Provided
3	Compartmentation:			
	A	Fire check door	NA	NA
	B	Sealing of electrical shafts	NA	NA
	C	Fire rating of shaft door	NA	NA
	D	Water curtain	NA	NA
	E	Fire dampers	NA	NA
4	Smoke Management System:			
	A	Basement	NA	NA
	B	Upper floor	NA	NA

5.	Fire Extinguisher:				
	A	Total numbers	04 nos.	12 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	ISI marked	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	01no.	01no.	MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	NA	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	size of riser/down-comer	100 mm	100 mm	MR
	B	Number of hydrants per floor	01 no.	01 no.	MR
	C	Hose box at each floor	01 no.	01 no.	MR
12	Yard Hydrants:				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	Required	900 LPM	MR
	b)	Head of the pump	40 mtrs.	Provided	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	Required	10,000 ltrs MR
15	Exit Signage:		Required	Provided MR
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		Required	Provided MR
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room :			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	Pa system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/EH/2021/SZ/17 dated 19.01.2021 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name Rajesh Kumar Shukla
 Designation ADO (M. Road)

DO (SD)

M. S. Cell
03/1/24

Chf on leave
Director M. S. Cell
03/1/24

ADY/M. S. Cell

pls upload

08/1/23

M. S. Cell

Uploaded