

C7



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/EH/10

Dated 08/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s Udupi Darshini located at Property no. D-2/8, Ground Floor, Model Town-III, Delhi-110009 in a building comprised of ground & 02 upper floors owned/occupied by M/s Udupi Darshini have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 30.12.2023 in the presence of Mr. Naveen Bangera and that the building/ premise is fit for occupancy Class "Group D Assembly (Restaurant) for ground floor only" with effect from 08/01/2024 for a period of Valid up to 31.03.2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 08/01/2024..... at New Delhi by

(Atul Garg)
 Director

Ph-011-23414000

Copy to:-

1. M/s Udupi Darshini located at Property no. D-2/8, Ground Floor, Model Town-III, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

- 1 This Fire Safety Certificate is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
- 2 All the means of escape/entry/exit shall be kept free from any obstruction.
- 3 All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
- 4 Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
- 5 All the staff members must know the correct method of operation of firefighting system.
- 6 The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/vps/wcm/connect/doit/fire/FIRE/Home/Forms>.
- 7 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
- 8 "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : M/s Udipi Darshini at Property No. D-2/8, GF, Model Town-III, Delhi-9.
2. Composition of building : Ground & 02 upper floors, but restaurant proposed at ground floor only, 1st floor & 2nd floor- residence
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : New Case
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 30.12.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Naveen Bangera
10. Year of Construction/conversion : 2011 as per online mha application
11. Applicant's letter No. : Online MHA Portal ID. No-2023122019760 dated 22.12.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part- IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	12m approx...	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits (Restaurant at GF only)			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02 nos. of 1.50m	2.50m & 1.50m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors (Ground Floor)	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	04nos	04nos	MR
	• Types	ABC/Co2	ABC/Co2	MR
	• ISI marking	Yes	Provided	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> Hooters' Location 	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	01	MR
	<ul style="list-style-type: none"> Hose Box 	01	01	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	20,000 LTR	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
		N/A	N/A	N/A

	<ul style="list-style-type: none"> Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA	NA	NA
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	> Total Area	N/A	N/A	N/A
	> Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

Note:-

- The total covered area of the ground floor Restaurant is 157.99sqm (Approx) including seating area, toilet area, kitchen area,
- As per the NBC Part IV, the number of occupants comes out to be approx 88 person's i.e. (157.99/1.8=88)

The fire protection systems provided in the building were tested/ checked and found in working order at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

C.L. Meena
01/01/2024

Signature of the Inspecting Officer
Name :-C.L. Meena
Designation:- ADO/RN

[Signature]
Dy. Chief Fire Officer (WZ)

[Signature]
2/1/2024

[Signature]
2/01/2024

[Signature]
2/1/24

[Signature]

[Signature]

Conf. --- P.T.O.

NO. 17-MHA
02/01/24