



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2024/NDZ/16

Dated: 08/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M C D Primary School located at Subhash Park, Shahdara, Delhi-110032, comprised of ground plus one upper floor owned/occupied by M C D Primary School was issued FSC vide letter No. F.6/DFS/MS/School/2020/NDZ/139 dated 30/03/2020. The premises was re-inspected by the officer concerned of this department on dated 01/01/2024 in the presence of Mrs. Deepika Jain, Principal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from ..08/01/2024 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on ...08/01/2024... at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

To:-

The Principal,
M C D Primary School at Subhash Park, Shahdara, Delhi-110032

Copy to:-

1. The Director of Education, MCD, Udyod Sadan, Plot no.419, FIE, Patparganj Industrial Area, Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

INSPECTION REPORT

1. Name & address of the building : M C D Primary School, Subhash Park, Shahdara, Delhi-110032
2. Building is comprised of : Ground plus first floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2020/NDZ/139 dated 30/03/2020
6. Fire Safety direction letter No. : F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11
7. Date of Inspection : 01/01/2023
8. Name of the Inspecting officers : ADO (L.N.) Yashwant Singh Meena
9. Name and designation of Officer from the building side : Mrs. Deepika Jain, Principal
10. Year of Construction : 2005
11. Applicant's letter No : Nil dated 28/12/2023


| Sr. No. | Minimum Standards on Fire Prevention and Fire Safety U/R33 | Circular Requirement | Provided at Site | Remarks MR/NMR |
|---------|--|----------------------|----------------------|----------------|
| 01 | Access to Building | | | |
| | • Road width | 6.00mtr | 15.00 mtr | MR |
| | • Gate width | 4.50 mtr | 4.50 mtr | MR |
| | • Width of internal road | N/A | N/A | N/A |
| 02 | Number, Width, Type and Arrangement of Exits | | | |
| | a. Number of Staircases | | | |
| | • Upper floor | 02 nos. | 02 nos. | MR |
| | • Basement | N/A | N/A | N/A |
| | B. Width of Staircases | | | |
| | • Upper floor | 1.50 mtr | 1.65 mtr each | N/A |
| | • Basement | N/A | N/A | N/A |
| | c. Protection of Exits | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Pressurization | N/A | N/A | N/A |
| | d. No. of Continuous Staircases to Terrace | N/A | N/A | N/A |
| | e. Width of Corridor | 1.50mtr | 2.20 mtr | MR |
| | f. Door Size | 1.00 mtr | 1.00 mtr | MR |
| 03 | Compartmentation. | | | |
| | • Fire check door | N/A | N/A | N/A |
| | • Sealing of electrical shafts | N/A | N/A | N/A |
| | • Fire rating of shaft door | N/A | N/A | N/A |
| | • Water curtain | N/A | N/A | N/A |
| | • Fire dampers | N/A | N/A | N/A |
| 04 | Smoke Management System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper floor | N/A | N/A | N/A |
| 05. | Fire Extinguishers | | | |
| | • Total numbers | 06 nos. | 06 nos. | MR |
| | • Types | ABC/CO ₂ | ABC/ CO ₂ | MR |
| | • IS marking | ISI marked | ISI marked | MR |

| | | | | |
|----|---|-----|-----|-----|
| 06 | First-Aid-Hose Reels. | | | |
| | Total numbers on each floor | N/A | N/A | N/A |
| | • Length of hose reel hose | N/A | N/A | N/A |
| | • Nozzle diameter | N/A | N/A | N/A |
| 07 | Automatic Fire Detection and Alarming System. | | | |
| | • Type of detectors | N/A | N/A | N/A |
| | • Location of main panel | N/A | N/A | N/A |
| | • Location of repeater panel | N/A | N/A | N/A |
| | • Alternate source of power | N/A | N/A | N/A |
| | • Hooter | N/A | N/A | N/A |
| 08 | MOEFA | N/A | N/A | N/A |
| 09 | Public Address System. | N/A | N/A | N/A |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | N/A | N/A | N/A |
| | • upper floor | N/A | N/A | N/A |
| | • sprinkler above false ceiling | N/A | N/A | N/A |
| 11 | Internal Hydrants | | | |
| | • size of riser/down-comer | N/A | N/A | N/A |
| | • Number of hydrants per floor | N/A | N/A | N/A |
| | • Hose box | N/A | N/A | N/A |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | N/A | N/A | N/A |
| | • Hose box | N/A | N/A | N/A |
| 13 | Pumping Arrangements. | | | |
| | ➤ Ground Level | | | |
| | • Discharge of main pump | N/A | N/A | N/A |
| | • Head of main pump | N/A | N/A | N/A |
| | • Number of main pumps | N/A | N/A | N/A |
| | • Jockey pump out put | N/A | N/A | N/A |
| | • Jockey pump head | N/A | N/A | N/A |
| | • Standby pump out put | N/A | N/A | N/A |
| | • Standby pump head | N/A | N/A | N/A |
| | • Auto starting /manual stopping | N/A | N/A | N/A |
| | • Pump house access | N/A | N/A | N/A |
| | ➤ Terrace Level | | | |
| | • Discharge of pump | N/A | N/A | N/A |
| | • Head of the pump | N/A | N/A | N/A |
| | • Power supply | N/A | N/A | N/A |
| | • Auto starting of pump | N/A | N/A | N/A |
| 14 | Captive Water Storage for Fire Fighting. | | | |
| | • Underground tank capacity | N/A | N/A | N/A |
| | • Draw-off connection | N/A | N/A | N/A |
| | • Fire service inlet | N/A | N/A | N/A |
| | • Access to tank | N/A | N/A | N/A |
| | • Overhead tank capacity | N/A | N/A | N/A |
| 15 | Exit Signage. | | | |
| | | N/A | N/A | N/A |

| | | | | |
|----|--|-----|-----|-----|
| 16 | Provision of Lifts. | | | |
| | | | | |
| | • Pressurization of lift shaft | N/A | N/A | N/A |
| | • Pressurization of lift lobby | N/A | N/A | N/A |
| | • Communication in lift car | N/A | N/A | N/A |
| | • Firemen's grounding switch | N/A | N/A | N/A |
| | • Lift signage | N/A | N/A | N/A |
| 17 | Standby Power Supply | N/A | N/A | N/A |
| 18 | Refuge Area. | | | |
| | • Total area | N/A | N/A | N/A |
| | • Location | N/A | N/A | N/A |
| 19 | Fire Control Room | | | |
| | • Detector system panel | N/A | N/A | N/A |
| | • Flow switch panel | N/A | N/A | N/A |
| | • PA system panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building floor plans | N/A | N/A | N/A |
| 20 | Special Fire Protection Systems for Protection of Special Risks, if Any: | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rule. The FSC issued vide letter no. F.6/DFS/MS/School/2020/NDZ/139 dated 30/03/2020 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.


2/1/2024

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: - ADO (L.N)

Dy.CFO (NDZ)

RVP
03/1/24

C.F.O. on leave

~~Director~~
A/1/24

~~ADP/L~~

F. letter is put up for sign. Please

~~Director~~
3/1/24
m


5/1/2024