



FIRE SAFETY CERTIFICATE

Certified that the M/s Aarogya Hospital located at Plot No. 32, Chitra Vihar, Vikas Marg, Delhi-110092, comprised of basement, stilt, ground plus three upper floors, owned/occupied by Aarogya Hospital was inspected by the officer concerned of fire service on 28/12/2023 in the presence of Dr. Umesh Kumar (Owner) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Institutional" Class "C" with effect from 10/01/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 10/01/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Dr. Umesh Kumar , Aarogya Hospital at Plot No. 32, Chitra Vihar, Vikas Marg, Delhi-110092.
2. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3rd floor, Delhi Govt. Dispensary Building, S-1, School Block, Shakarpur, Delhi-110032.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
8. Basement shall be used as per NBC/UBBL.
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

1. Name & address of the building : Aarogya Hospital,
Plot No. 32, Chitra Vihar, Vikas Marg, Delhi-110092.
2. Building is comprised of :Basement + stilt + Ground plus three upper floors
3. Type of Occupancy :Institutional (Hospital Building)
4. Type of Case :New
5. Details of Previous FSC letter :Nil
6. Fire Safety directive letter No :F.6/DFS/MS/BP/2023/309 dated 15/09/2023
7. Date of Inspection :28/12/2023
8. Name of the Inspecting officers : Yashwant Singh Meena, ADO (LN.)
9. Name and designation of officer from the building side : Dr. Umesh Kumar (Owner)
10. Year of construction :2023
11. Applicant's letter No :Email dated 26/12/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirements	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtrs.	24 mtrs.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper floor	2.00 mtrs.	2.00 mtrs each	MR
	• Basement	2.00 mtrs.	2.00 mtrs each	MR
	c. Protection of Exits			
	• Fire check door	Required	Provided	MR
		N/A	N/A	N/A
	• Pressurization			
	d. No. of Continuous Staircases to Terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	2.40 mtrs.	2.40 mtr	MR
	f. Door Size	1.25 & 2.00 mtrs.	Provided	MR
03	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	30 a/c per hour	Provided	MR
	• Upper floor	12 a/c per hour	Provided	MR
05.	Fire Extinguishers.			
	• Total numbers	12 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Smoke	Provided	MR
	• Location of main panel	Ground	Provided	MR
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper floor	Required	Provided	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	• Head of main pump	70 mtrs.	70 mtrs.	MR
	• Number of main pumps	01 no.	01 no.	MR
	• Jockey pump out put	180 LPM	180 LPM	MR
	• Jockey pump head	70 mtrs.	70 mtrs.	MR
	• Standby pump out put	2280 LPM	2280 LPM	MR
	• Standby pump head	70 mtrs.	70 mtrs.	MR
	• Auto starting /manual stopping	Required	Provided	MR
	• Pump house access	Required	Provided	MR
	➤ Terrace Level			
	• Discharge of pump	N/A	N/A	N/A
	• Head of the pump	N/A	N/A	N/A
	• Power supply	N/A	N/A	N/A
	• Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,50,000 ltr.	1,50,000 ltr.	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	10,000 Ltr.	10,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of lift shaft	Required	Provided	MR
	• Pressurization of lift lobby	Required	Provided	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift signage	Required	Provided	MR
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if Any:	Required for HT/LT Panels	Provided in all HT & LT Panels	MR

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.



29/12/2023

Signature of the Inspecting Officer

Name :-YashwantSingh Meena

Designation :-ADO (LN)

~~Dy.CFO(NDZ)~~

~~Imp~~
01/01/24

~~c.f.o.~~
~~02/01/2024~~
~~Director~~
~~2/1/24~~

~~Amu HV~~

F.T Letter is put up for sign. Please

~~Director~~
~~9/1/24~~

3/1/2024

~~my~~