

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No. F6/DFS/MS/2024/ 30

Dated:-..11..01..2024

FIRE SAFETY CERTIFICATE

Certified that the **Patel Chowk Metro Station at New Delhi**, was inspected by the officer concerned of this department on 28 -12-2023 in the presence of Sh. OM Kar Singh, Fire inspector and found that the said Metro Station has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building** with effect from11.01.2024 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11.01.2024..... at New Delhi by.

(Anil Garg)
DIRECTOR

Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. Sh. Malya Saha GME & M/RC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

117

INSPECTION REPORT

- 1. Name & address of the building : Patel Chowk Metro Station at New Delhi
- 2. Type of Occupancy : Assembly building (D7as Per NBC Part IV 2005)
- 3. Type of Case : Fresh/Renewal
- 4. Details of previous inspection : F6/MS/DFS/DMRC/2005/1378 dated 29/06/2005.
- 5. Fire Safety directives Letter No. : N/A
- 6. Date of inspection : 28/12/2023
- 7. Name of the Inspecting Officer : Sh. Ravinder Singh ADO/CC
- 8. Name and designation of Officer
from the building side : Sh. Omkar Singh, Fire inspector
- 9. Year of Construction : 2010
- 10. Applicant's letter No. : DMRC/O&M/FIRE/NOC/L2/2023/12, dated 11.12.2023'

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements as per previous inspection	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	Provided .	MR
	2) Gate width	6 mtr.	Directly approachable	MR
	3)Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	08 nos	08 nos	MR
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	PF-CC 2.3m x04 nos , CC-ground 2.21m & 6.0 m (03 nos PF to ground 1.40mx1nos	PF-CC 2.3m x04 nos , CC-ground 2.21m & 6.0 m (03 nos PF to ground 1.40mx1nos	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided in Fire man & Emg. s/c	MR
	2. Pressurization	Required	Provided	MR
	D. No. of continuous staircase to terrace			
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor			
	E. Width of corridor	2.0 m	2.0 m	MR
	F. Door size			
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	Required	2 hr. & 4hr. Provided	MR
	2) Sealing of electrical shafts/opening	Required	Provided	MR
	3) Fire rating of shaft door	Required	02 hrs. Provided	MR
	4) Fire curtain	N/A	N/A	N/A
	5) Fire Dampers	Required	Provided	MR

118

4.	Smoke Management System			
	1) Basements	30 ACPH	Provided in ECS	MR
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	80 nos Nos.	89 Nos.	MR
	2) Types	CO2 & Water gas	6KG ABC+9L water+4.5 KG Co ₂	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number on floors	PF-05, CC-06 nos & 01nos at gr.	Provided	MR
	2) Length of hose reel hose	30 mtr.	30.5 mtr.	MR
	3) Nozzle diameter	06 mm	06 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Addressable multi sensor type and heat sensor	Provided	MR
	2) Location of main panel	Concourse	Station (C.R) Concourse	MR
	3) Location of repeater panel	Required	Fire man staircase (1 st Landing)	MR
	4) Alternate source of power	Required	UPS supply	MR
	5) Hooter's Location	Required	Floor wise	MR
8.	MOEFA	Required	Provided	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Required	Provided at platform	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	150 mm.	150 mm	MR
	2) Number of hydrants	PF-05, CC-06 & Gr.-01 Nos.	PF-05, CC-06 & Gr.-01 Nos.	MR
	3) Hose box floor	28 Nos.	28 nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	02 no	02 no	MR
	2) Hose box	02no	02 no	MR
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2850LPM	2850LPM	MR
	b) Head of main pump	110 mtr	110 mtr	MR
	c) Number of main pump	2 No.	2 No.	MR
	d) Jockey pump out put	240LPM	240LPM	MR
	e) Jockey pump head	110 m	110 m	MR
	f) Stand by pump output	2850LPM	2850LPM	MR
	g) Stand by pump head	110 m	110 m	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A

90/

N/A

	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	1,00,000liter	1,00,000liter ✓	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any: Clean. Agent flooding system for transformer & LT penal.			MR

The fire protection systems provided in the building as per previous inspection were randomly tested, checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may issue FSC to said building. Accordingly, DFA is prepared and put up for kind perusal and sig. please.

Signature of the Inspecting Officer

[Handwritten Signature] 2/11/24

Name:- Sh. Ravinder Singh
Designation :- ADO (CC)

[Handwritten Signature]

[Handwritten Signature]
3/1/24

[Handwritten Signature]
C.F.O.

[Handwritten Signature]
3/1/24

Director *[Handwritten Signature]* on leave

[Handwritten Signature]

ADDO CC