



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Metro/2024/SZ/ 34

Dated: 12/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Metro Station at Terminal-3 IGI Airport (Airport Express Line), New Delhi-110037, comprised of five level underground metro station (undercroft, platform, concourse, mezzanine and ground floor), owned/occupied by Delhi Metro Rail Corporation was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2021/46 dated 20/01/2021. The premises was re-inspected by the officer concerned of this department on 04/01/2024 in presence of Sh. Omkar Kumar (Fire Inspector) and observed that the said premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly Group-D" (Metro Station) with effect from 12/01/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/01/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Sh. Malay Saha (GM / Elect & Tech), Delhi Metro Rail Corporation Limited, Metro Bhawan, 13, Fire Brigade Lane, Barakhamba Road, New Delhi-110001

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc, may be got verified from concerned authorities.
5. The basement shall be used as per the provisions of BBL
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
7. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1.	Name & address of the building	Metro Station at Terminal-3 IGI Airport (Airport Express Line), New Delhi-110037		
2.	Type of Occupancy	Assembly (Group-D)		
3.	Building Comprised of	Five Level Underground Metro Station (Undercroft, Platform, Concourse, Mezzanine and Ground floor)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F6/DFS/MS/2021/46 dated 20/01/2021		
6.	Fire Safety directives Letter	F.6/DFS/MS/BP/2009/3889 dated 23/12/2009		
7.	Date of inspection	04/01/2024		
8.	Name of Inspecting Officer	ADO (SJ) Santosh Kumar		
9.	Name and designation of Officer from building side	Sh. Omkar Kumar (Sr. Fire Inspector)		
10.	Year of Construction	2010		
11.	Applicant letter No.	Outdoor Diary No. 10050 dated 24/11/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirement / Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Total=9 (UC to PF=6, PF to CC=7, CC to GF=9)	Total=9 (UC to PF=6, PF to CC=7, CC to GF=9)	MR
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	Required	1.5 (each)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	2m	2m(final exit)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 ACHP	Mechanical Ventilation	MR
	• Upper floors	12 ACHP	Mechanical Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	100 nos.	114 nos.	MR
	• Types	ABC, CO ₂ , DCP	ABC, CO ₂ , WCO ₂ , Foam & DCP	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	GF=01, PT=09 nos. & CC=05 nos.	GF=01, PT=09 nos. & CC=05 nos.	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR

81

7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke & Heat	Smoke & Heat	MR
	• Location of Main Panel	Required	Concourse Level	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	All Areas	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	NA	Provided	NA
10	Automatic Sprinkler System			
	• Basements	Provided	Provided in baggage handling area only	MR
	• Upper Floors	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	GF=01, PT=09 nos. & CC=05 nos.	GF=01, PT=09 nos. & CC=05 nos.	MR
	• Hose Box	GF=01, PT=09 nos. & CC=05 nos.	GF=01, PT=09 nos. & CC=05 nos.	MR
12	Yard Hydrants			
	• Total number of hydrants	08 nos.	Provided	MR
	• Hose Box	08 nos.	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	4500 LPM	Provided	MR
	➤ Head of main pump	80m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	80m	Provided	MR
	➤ Standby Pump out put	4500 LPM	Provided	MR
	➤ Standby Pump Head	80m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Underground tank capacity	200,000 Ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	ABC & CO ₂ Fire Extinguishers and inert gas flooding system provided for electric panels		MR

The Fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F6/DFS/MS/2021/46 dated 20/01/2021, renewal under rule 37 of Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
05-01-24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

msh
06/1/24

cto
8/01/2024

Director

[Signature]
D/1/24
AOD(S)

Sir, F.T letter is put up for your signature pl.

Director
[Signature]
11/1/24
mr

Santosh Kumar
10-01-24