



FIRE SAFETY CERTIFICATE

Certified that the M/s True Blue Class Room (A unit of EVS Green Energy Pvt. Ltd.) located at Plot No. 4, FF, SF, Atlantic Plaza, I.P. Extension Patparganj, Delhi -110092, running at first floor & second floor only, building comprised of ground plus three upper floor owned/occupied by A unit of EVS Green Energy Pvt. Ltd was granted FSC vide letter no. F6/DFS/MS/EH/2019/1497 dated 22.07.2019. The Premises was re-inspected by the officer concerned of this department on 05.01.2024 in the presence of Mr. Dharmbir (Owner) and found that the Industrial building have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and found that the building is fit for occupancy class "Assembly" (Group D) "Eating House" with effect from 11/01/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 and also conditions printed below.

Issued 11/01/2024 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE
o/c @

Copy to:-

1. The Owner, True Blue Class Room (A unit of EVS Green Energy Pvt. Ltd.) located at Plot No. 4, FF, SF, Atlantic Plaza, I.P. Extension Patparganj, Delhi - 110092.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24 w.e.f. - MHA portal ID - 2021090320084 dated 30/12/2023.

Conditions for the validity of Fire Safety Certificate:

1. Fire Safety Certificate is valid for first floor & second floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/25

INSPECTION REPORT

1	Name & address of the building	True Blue Class Room (A unit of EVS Green Energy Pvt. Ltd.) located at Plot No. 4, FF, SF, Atlantic Plaza, I.P. Extension Patparganj, Delhi -110092.
2	Building is comprised of	Ground + 03 upper floors only. (Restaurant is running at First floor & Second floor only)
3	Type of occupancy	Assembly Building (Restaurant)
4	Type of case	Renewal
5	Details of previous FSC	F6/DFS/MS/EH/2019/1497 dated 22.07.2019
6	Fire safety direction letter no.	F6/DFS/MS/2005/718 dated 04.04.2016
7	Date of inspection	05.01.2024
8	Name of the inspecting officers	Yashwant Singh Meena (ADO/LN)
9	Name of the designation of officer From the building side	Mr. Dharmbir (Owner)
10	Year of construction	2002
11	Applicant's letter no	MHA Application No. 2021090320084 dated 30/12/2023.

S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement	Provided at Site	Remarks MR/NMR		
1	Access to building					
	a	Road width	4.5 mtrs.	15 mtrs	MR	
	b	Gate width	NA	NA	NA	
	c	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	02 nos.	02 nos. ✓	MR
		b	Basement	NA	NA	NA
	B	Width of staircases				
		a	Upper floor	1.25 mtrs.	1.20 mtrs & 1.50 mtrs. ✓	MR (Old Case)
		b	Basement	NA	NA	NA
	C	Protection of exits				
		a	Fire check door	NA	NA	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace	NA	NA	NA	NA
	E	Width of corridor	NA	NA	NA	NA
	F	Door size	1.0 mtrs.	1.0 mtrs & 1.50 mtrs.	MR	
3	Compartmentation					
	a	Fire check door	NA	NA	NA	
	b	Sealing of electrical shafts	N/A	N/A	N/A	
	c	Fire rating of shaft door	N/A	N/A	N/A	
	d	Water curtain	N/A	N/A	N/A	
	e	Fire dampers	N/A	N/A	N/A	
4	Smoke Management System.					
	a	Basement	NA	NA	NA	
	b	Upper floor	12 a/c per hour	Natural	MR	

②

5.	Fire Extinguisher					
	a	Total numbers	08 nos.	10 nos.	MR	
	b	Types	CO ₂ & ABC	CO ₂ & ABC	MR	
	c	ISI marking	ISI marked	ISI marked	MR	
6	First-aid-Hose Reels.					
	a	Total numbers	01 no.	01 no.	MR	
	b	Length of hose reel hose	30 mtrs.	30 mtrs.	MR	
	c	Nozzle diameter	05 mm	05 mm	MR	
7	Automatic fire detection and alarming system.					
	a	Type of detectors	NA	NA	NA	
	b	Location of main panel	NA	NA	NA	
	c	Location of repeater panel	NA	NA	NA	
	d	Alternate source of power	NA	NA	NA	
	e	Hooter	Required	Provided	MR	
8	MOEFA		Required	Provided	MR	
9	Public address System.		Required	Provided	MR	
10	Automatic Sprinkler System.					
	a	Basement	NA	NA	NA	
	b	Upper floors	Required	Provided	MR	
	c	Sprinkler above false ceiling	NA	NA	NA	
11	Internal Hydrants					
	a	Size of riser	100 mm	100 mm	MR	
	b	Number of hydrants per floor	01 no.	01 no.	MR	
	c	Hose Box	01 no.	01 no.	MR	
12	Yard Hydrants.					
	a	Total number of hydrants	Required	Provided	MR	
	b	Hose Box	Required	Provided	MR	
13	Pumping Arrangements.					
	A	Ground Level				
		a	Discharge of main Pump	225 LPM	225 LPM	MR
		b	Head of Main Pump	35 mtrs.	35 mtrs.	MR
		c	Number of main pumps	NA	NA	NA
		d	Jockey pump out put	NA	NA	NA
		e	Jockey pump head	NA	NA	NA
		f	Standby pump out put	NA	NA	NA
		g	Standby pump head	NA	NA	NA
		h	Auto starting /manual stopping	NA	NA	NA
		i	Pump House Access	NA	NA	NA
	B	Terrace Level				
		a	Discharge of pump	450 LPM	450 LPM	MR
		b	Head of the Pump	35 mtrs.	35 mtrs.	MR
		c	Power supply	Required	Provided	MR
		d	Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.				
	a	Underground tank capacity	NA	NA	NA
	b	Draw-off connection	NA	NA	NA
	c	Fire service inlet	Required	Provided	MR
	d	Access to tank	NA	NA	NA
	e	Overhead Tank capacity	5,000 liters.	10,000 liters.	MR
15	Exit Signage.		Required	Provided	MR
16	Provision of Lifts.				
	a	Pressurization of Lift Shaft	NA	NA	NA
	b	Pressurization of Lift lobby	NA	NA	NA
	c	Communication in lift car	Required	Provided	MR
	d	Firemen's grounding switch	Required	Provided	MR
	e	Lift Signage	Required	Provided	MR
17	Standby power supply		Required	Provided	MR
18	Refuge Area.				
	a	Total area	NA	NA	NA
	b	Location	NA	NA	NA
19	Fire Control Room				
	a	Detector system panel	NA	NA	NA
	b	Flow switch panel	NA	NA	NA
	c	PA system panel	NA	NA	NA
	d	Battery backup	NA	NA	NA
	e	Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F.6/DFS/MS/EH/NDZ/2022/615 dated 14.10.2022 by this department have been rectified by the management.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in F6/DFS/MS/2005/718 dated 04.04.2016, the FSC issued vide letter no. F6/DFS/MS/EH/2019/1497 dated 22.07.2019 is recommended to be renewed.


 5/11/2024

Signature of the Inspecting Officer
 Name: - Yashwant Singh Meena
 Designation: - ADO (L.N)

Dy. CFO (NDZ) Rimp
08/10/24
 C.F.O. Vineet
9/11/2024
 Director R.K.
9/11/24

JF PS
 ADO/LN
 P.T.O