



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Storage/2024/SZ/ 39

Dated: 15/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Ware House (Delhi Cargo Service Center Pvt. Ltd.) at Cargo Terminal-II (Adjacent to existing ATC Gate-1), Air Cargo Complex, IGI Airport New Delhi-110037, comprised of Ground floor (Shed) only, owned/occupied by Delhi Cargo Service Center Pvt. Ltd was earlier issued FSC by this department vide letter No. F6/DFS/MS/SZ/Hotel/2021/254 dated 12/05/2021. The premises was re-inspected by the officers concerned of this department on 06/01/2024 in presence of Sh. Deepak Karki (Sr. Manger) and observed that the said premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Storage Group-H" with effect from 15/01/2024 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/01/2024 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. Authorized Signatory M/s DCSC Pvt. Ltd, Cargo Terminal-II (Adjacent to existing ATC Gate-1), Air Cargo Complex, IGI Airport, New Delhi-110037
2. The CEO, DIAL, Udaan Bhawan, IGI Airport, New Delhi-110037.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation with regard to construction, ventilation, occupancy, electric installation etc, may be got verified from concerned authorities.
5. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".

N/20

INSPECTION REPORT

1.	Name & address of the building	Ware House (Delhi Cargo Service Center Pvt. Ltd.) at Cargo Terminal-II, Adjacent to Existing Gate-1, Air Cargo Complex, IGI Airport, New Delhi-37		
2.	Type of Occupancy	Storage Building (Group-H)		
3.	Building Comprised of	Ground floor (Shed)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/SZ/Hotel/2021/254 Dt. 12/05/2021		
6.	Fire Safety directives/approval letter	F.6/DFS/MS/BP/2017/364 Dt. 21/12/2017		
7.	Date of inspection	06/01/2023		
8.	Name of Inspecting Officer	DO (SD) Manoj Kumar Sharma & ADO (SJ) Santosh Kumar		
9.	Name and designation of Officer from building side	Mr. Deepak Karki (Sr. Manager)		
10.	Year of Construction	2018		
11.	Applicant letter No.	Outdoor Diary No. 11346 dated 29/12/2023		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Requirements/ Existing Fire Protection System	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06m	Provided	MR
	• Gate width	4.5m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.5m x 14	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground floor	Annex. M	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	ISI marked	60 Nos	MR
	• Types		ABC/WCO ₂ /CO ₂ /Foam	MR
	• ISI marking		Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	Hose reels	17 Nos	MR
	• Length of hose reel hose		30m	MR
	• Nozzle diameter		5mm	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke/Heat/Beam	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	All Areas	MR
8.	MOEFA	Required	Provided	MR
9	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground Floor	Low Hazard as per clause 3.1.2 of UBBL2016 (Annexure-XIII)	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	17 Nos	Provided	MR
	• Hose Box	17 Nos	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	14 Nos	Provided	MR
	• Hose Box	14 Nos	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	1620 LPM	2280 LPM	MR
	➤ Head of main pump	70m	Provided	MR
	➤ Number of main pumps	One	Two	MR
	➤ Jockey pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	1620 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 Ltrs	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

N/22

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Manual Gas Flooding/ Liner heat sensing tubes with CO ₂ cylinder in HT & LT Panels	Provided	MR

The fire protection system provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/SZ/Hotel/2021/254 dated 12/05/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Manoj
9/1/24

Signature of the Inspecting Officer
Name: Manoj Kumar Sharma
Designation: DO (SD)

Santosh Kumar
08.01.24

Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (S.J.)

CFO (HQ)

Manoj
10/1/2024

Director

Manoj
14/1/24
ADDO/SJ

Sir,
F.T letter is put up for your signature pl.

Director
Manoj
15/1/24
man

Santosh Kumar
12/01/24