

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/2024/EH/20

Dated:- 15.01.2024

FIRE SAFETY CERTIFICATE

Certified that the M/S BURGER KING (Restaurant Brands Asia Limited) at PD area of Under Ground Rajiv Chowk, Line -2, Metro Station New Delhi. The restaurant premises was inspected by the officers concerned of this department on 28-12-2023 in the presence of Sh. K.K. Jain and found that the said restaurant in the Metro Station has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said restaurant premises is fit for occupancy class **Assembly Building** with effect from 15.01.2024 up to 31.03.2027 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15.01.2024 at New Delhi by.


 (Atul Garg)
 DIRECTOR
 Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra , New Delhi .
2. The Addl. Commissioner of Police , First floor, Defence colony, Police Station New Delhi ID no. 2023120219102 dated 19.12.23.
3. The GM/E & M/RC, Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi.
4. The Manager BURGER KING (Restaurant Brands Asia Limited) at PD area of Under Ground Rajiv Chowk, Line -2, Metro Station, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : **BURGER KING , Restaurant Brands Asia Limited at Rajiv Chowk, Line -2, Metro Station at New Delhi**
2. Type of Occupancy : **Assembly building (D-7)**
3. Type of Case : **fresh**
4. Details of previous FSC : **N/A**
5. Fire Safety directives Letter No. : **N/A (metro station guidelines)**
6. Date of inspection : **28/12/2023**
7. Name of the Inspecting Officer : **Sh. Ravinder Singh ADO/CC**
Sh. Rajinder Atwal , DO/CD
8. Name and designation of Officer from the building side : **Sh. K.K.Jain**
9. Year of Construction : **2005**
10. Applicant's letter No. : **online id no. 2023120219102 dated 19-12-2023.**

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements /existing arrangements as per metro station NOC	Provided at site	Remarks MR/NMR
1. Access to Building				
	1) Road width	06 m	Provided	MR
	2) Gate width	N/A	directly approach from main road	N/A
	3)Width of internal road	N/A	N/A	N/A
2. Number, Width Type & Arrangement of Exits				
A. Number of staircases				
	1. Concourse to Ground level	08 nos.	08 nos.	MR
	2. Concourse to Central Park(Ground Level) Emergency Staircase	04 nos.	04 nos.	MR
B. Width of staircase				
	1. Concourse to Ground	2.0 mtr	08 nos. 1) 2.25m, 2) 4.3m, 3) 2.60m, 4) 4.25m, 5) 4.3m, 6) 2.5m, 7) 2.25m, 8) 4.4m.	MR
	2. Concourse to Central Park(Ground Level) Emergency Staircase	2.0 mtr	4nos-2.3 mtrs each	MR
C. Protection of exits				
	1. Fire check door	Required	Provided	MR
	2. Pressurization (fire man staircase)	Required	Provided in Fire man & Emg. s/c	MR
	D. No. of continuous staircase to Ground	all	provided	MR

N/V

	E. Width of corridor	2.0 m	2.0 m	✓	MR
	F. Door size	2.0 m	2.0 m	✓	MR
3.	Compartmentation				
	1) Fire check door(fire man staircase)	Required	Provided		MR
	2) Sealing of electrical shafts/opening	Required	Provided		MR
	3) Fire rating of shaft door	Required	02 hrs. Provided		MR
	4) Fire curtain	N/A	N/A		N/A
	5) Fire Dampers	Required	Provided		MR
4.	Smoke Management System				
	1) Basements	Required	06 nos Tunnel ventilation fans & 12 nos. track way exhaust and 06 Booster fans provided		MR
	2) Upper floors	N/A	N/A		N/A
5.	Fire Extinguishers				
	1) Total numbers	02 nos	02 Nos.	✓	MR
	2) Types	ABC , CO2,	Provided		MR
	3) ISI marking	Required	Provided		MR
6.	First-Aid Hose Reel				
	1) Total number of each floor	01nos	Provided		MR
	2) Length of hose reel hose	30 mtr.	Provided		MR
	3) Nozzle diameter	06 mm	Provided		MR
7.	Automatic Fire Detection & Alarming System				
	1) Type of detectors	smoke	Provided		MR
	2) Location of main panel	Required	Provided at station control Room	✓	MR
	3) Location of repeater panel	Required	Provided in fireman staircase		MR
	4) Alternate source of power	Required	Provided		MR
	5) Hooter's Location	Required	Provided at platform, subway and concourse level		MR
8.	MOEFA	Required	Provided	✓	MR
9.	Public Address System	N/A	Provided		N/A
10.	Automatic Sprinkler System				
	1) Basement at PD area	Required	Provided	✓	MR
	2) Upper floors	N/A	N/A		N/A
	3) Sprinkler above false ceiling	N/A	N/A		N/A
11.	Internal Hydrants				
	1) Size of riser/down-comer	150 mm	Provided		MR
	2) Number of hydrants per floor	01nos	Provided		MR
	3) Hose box per floor	01 nos	Provided		MR
12.	Yard Hydrants				
	1) Total number of hydrants	N/A	N/A		N/A
	2) Hose box	N/A	N/A		N/A
13.	Pumping Arrangement				
	1) Ground level	feeding from main station pump house			
	a) Discharge of main pump	2839 LPM	2839 LPM		MR
	b) Head of main pump	110 mtr(HYD)	Provided	✓	MR

		42 MTRS (SPR)		
	c) Number of main pump	3 Nos (HYD) 3 Nos (SPR)	Provided	MR
	d) Jockey pump out put	240 LPM	Provided	MR
	e) Jockey pump head	42 m	Provided	MR
	f) Stand by pump output	2839 LPM	Provided	MR
	g) Stand by pump head	110 mtrs (HYD) 42 mtrs (SPR)	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	i) Pump House access	Required	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	200 KL.	Provided /	MR
	a) Draw-off connection	Required	Provided 01 no near fire tank /	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift	Required	Provided	MR
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	Required	Provided	MR
	c) PA system panel	Required	N/A	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	Provided	MR