

2/13

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/WZ/EH/2024/ 21

Dated: 15/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Ms. Karigari (A unit of Power Delight Hospitality Pvt. Ltd.) Located at Unit No. G4, Ground Floor, Punjabi Bagh West Metro Station, New Delhi-110026 in a building Comprised of (Ground + Platform + Interchange Passage). Owned/occupied by M/s. Karigari (A unit of Power Delight Hospitality Pvt. Ltd.) was inspected by the officer concerned of this department on 09/01/2024 in the presence of Sh. Amit and found that the premises have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the building /premises is fit for the occupancy class "Assembly" (Group- D) (Ground Floor Only) and validity upto 31<sup>st</sup> March 2027 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 15/01/2024..... at New Delhi by.

  
(Atul Garg)  
Director

Copy to:

1. The Joint Commissioner of Police, Licensing Unit, 1<sup>st</sup> floor, Police Station, Defence Colony, New Delhi. ([adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in))
2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi 110027. ([dhowestzone@gmail.com](mailto:dhowestzone@gmail.com))
4. The Owner/Occupier M/s Karigari (A unit of Power Delight Hospitality Pvt. Ltd.) Located at Unit No. G4, Ground Floor, Punjabi Bagh West Metro Station, New Delhi- 110026. (Online application ID No. 12101/2024)

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1. Name & address of the building	Ms. Karigari (A unit of Power Delight Hospitality Pvt. Ltd.) Located at Unit No. G4, Ground Floor, Punjabi Bagh West Metro Station, New Delhi-110026
2. Type of Occupancy	Assembly (Restaurant)
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	Nil
6. Date of inspection	09/01/2024
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Amit
9. Year of Construction	2018 (As per MHA portal)
10. Applicant's letter No.	Online application no. 2023122719974 dated 28/12/2023. 2023122319883 dated 30/12/2023 & 2023122319883 dated 26/12/2023

The said restaurant is running at basement & first floor in a building comprised of basement + stilt + upper ground + .

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL /NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 mts NA NA	Provided NA NA	MR NA NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	NA NA	NA NA	NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	NA NA	NA NA	NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	NA NA	NA NA	NA NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1.5 m X 1,2m X 1	Provided	MR
3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NA Required	NA Provided	NA MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 Nos. CO <sub>2</sub> , ABC type ISI marked	Provided Provided Provided	MR MR MR

88

6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01 Required	Common with the Metro Station	MR
	• Length of hose reel hose	30 m	Common with the Metro Station	MR
	• Nozzle diameter	5 mm	Common with the Metro Station	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	NA	Provided	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>	<b>Common with the Metro Station</b>		
	• Size of riser/down-comer	150 mm	Common with the Metro Station	MR
	• Number of hydrants per floor	Required	Common with the Metro Station	MR
	• Hose Box	Required	Common with the Metro Station	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>	<b>Common with the Metro Station</b>		
	• Ground Level			
	➤ Discharge of main Pump	2850 lpm	Common with the Metro Station	MR
	➤ Head of Main pump	70m	Common with the Metro Station	MR
	➤ Number of main pumps	1	Common with the Metro Station	MR
	➤ Jockey Pump out put	280 lpm	Common with the Metro Station	MR
	➤ Jockey pump head	70m	Common with the Metro Station	MR
	➤ Standby Pump out put	2850 lpm	Common with the Metro Station	MR
	➤ Standby Pump Head	70m	Common with the Metro Station	MR
	➤ Auto Starting/ Manual stopping	Required	Common with the Metro Station	MR
	➤ Pump House Access	Required	Common with the Metro Station	MR
	• Terrace level	<b>Provided by Metro Station</b>		
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>	<b>Common with the Metro Station</b>		
	• Underground tank capacity	100000 ltrs	Provided by Metro Station	MR
	➤ Draw-off connection	Required	Provided by Metro Station	MR
	➤ Fire service inlet	Required	Provided by Metro Station	MR
	➤ Access to tank	Required	Provided by Metro Station	MR
	• Overhead Tank capacity	10,000 ltrs	Provided by Metro Station	MR
15	<b>Exit Signage.</b>	Required	Provided	MR

16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*ADY (R/L/2) - on leave*  
DCFO/FPW

*[Signature]*  
 10/01/2023  
 Signature of the Inspecting Officer  
 Name: Sarabjeet Singh  
 Designation: ADO (MN)

*[Signature]*  
 11/01/2024  
 CFP

*[Signature]*  
 Director

*[Signature]*  
 ADY/MN

Sir, F.T is put up for your kind personal & signature please.

*[Signature]*  
 12/1/2024