

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/Indl./2024/SZ/12

Dated: 16/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **Plot No A-135**, located at **Okhla Industrial Area Phase-II, New Delhi 110020** comprised of Basement, Ground plus Two Upper Floors owned/ occupied by M/s Mukesh Sharma And Son have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 09/01/2024 in the presence of Mr. Avinash Raj (JE/Bldg) MCD and found that the said building / premises is fit for occupancy **class Industrial - Moderate Hazard G-2(B-ii)** with effect from 16/01/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 16.01. /2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Bldg) HQ, SDMC, 9th Floor Civic Centre, Minto Road, New Delhi 110002. (Ref. Online ID 10105871 dated 04/01/2024)

Conditions for the validity of the safety certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
3. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
4. The basement shall be strictly in accordance with the provision of UBBL- 2016.
5. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & Address of the Building	Plot No. A-135, Okhla Industrial Area, Phase-II, New Delhi 110020		
2	Type of Occupancy	"Industrial-Moderate Hazard G-2(b-ii)"		
3	Building Comprised of	Basement, Ground + 02 upper floor		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/2020/BP/370 Dated 22/08/2020		
7	Date of Inspection	09/01/2024		
8	Name of the Inspecting Officers	DO South & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Avinash Raj JE(Bldg)MCD		
10	Year of construction	2023		
11	Applicant letter No.	Online ID 10105871 dated 04/01/2024		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC /UBBL requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	12 mtr	13.72 mtr	MR
	• Gate width	6 mtr	6 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	02 Nos	MR
	➤ Basement floor.	02 Nos	02 Nos	MR
	b) Width of Staircase			
	➤ Upper floors	1.50 mtr each	1.50 mtr each	MR
	➤ Basement floor	1.50 mtr each	1.50 mtr each	MR
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d) No. of continuous staircase to terrace	Required	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.50 mtr	1.40m & 1.30m	MR
3.	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	12 ACPH	Exhaust fan Provided	MR
	• Upper floors	12 ACPH	Exhaust fan Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	20 No's	MR
	• Types	ABC / CO2	ABC & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	02 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR
7.	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-

-N/16-

	<ul style="list-style-type: none"> Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. 	1620 LPM	Provided	MR
		40m	Provided	MR
		02Nos	Provided	MR
		180 LPM	Provided	MR
		40m	Provided	MR
		1620 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	900 LPM	Provided	MR
		40 mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	1,50,000 ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 ltr	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.		Not required	
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> Detector system panel. Flow switch panel. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

✓


	<ul style="list-style-type: none"> PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	Provided	MR


The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 242 dated 08/12/2023.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010.


Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. M. K Sharma
 Design: DO South


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: ADO (BCP)

CFO (HQ)


 12/01/2024


 Director
 12/11/24
 Arun B (1)

As approved, F-1 letter is put up for
your signature pl


 15/1/24


 Director
 16/1/24

