



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

c 36



No F 6 / DFS / MS / 2024 / School / WZ / 30

Dated 15/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **R.K. International School** located at **Village Nizampur, Delhi-110081** comprised of **Single Block (Ground + one upper floor)** owned/occupied by **R.K. International School** was issued fire safety certificate vide letter no. **F-6/DFS/MS/2020/WZ/School/427** Dated-**15/10/2020**. The premises was re-inspected by the officer concerned of this department on 04.01.2024 in the presence of Sh. Sandeep and observed that the management has added one more block in existing building of 01 block and now the building is comprised of **Two Blocks (01 Block-Ground + One upper floor) & (01 Block-Ground + three upper floors)**. All the fire prevention & fire safety arrangement provided in the building was found as per Rules and in good working condition. The premises have therefore complied with the requirements under rule 33 of Delhi Fire Service Rules, 2010 and the building / premises is fit for occupancy of **Group B (Educational)** with effect from 15/01/2024 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..15/01/2024.. at New Delhi by


(Atul Garg)
Director
Ph. 011-23414000
ou R

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054
2. Principal, R.K. International School located at V.P.O Nizampur, Delhi-110081.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

INSPECTION REPORT

1. Name & address of the building : R.K. International School, located at V.P.O Nizampur, Delhi- 110081.
2. Type of Occupancy : Educational
3. Building Comprised of : 02 Blocks interconnected Ground + First floor & Ground+Three Upper floors.
4. Type of Case : Renewal (Addition/ Alteration)
5. Details of Previous NOC : F6/DFS/MS/2020/WZ/School/427 dated 15/10/2020
6. Fire Safety directives letter No : DOE circular No. 3298-3398 dated 01/03/2011 & NBC Part- IV
7. Date of inspection : 04/01/2024
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Sh. Sandeep Kumar
10. Year of Construction : 2013 & 2023
11. Applicant's letter No. : E Mail ID dated 04/01/2024

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DOE & NBC Part IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	G+1 Block- 01 G+3 Block- 02	G+1 Block- 01 G+3 Block- 02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	G+1 Block 1.5 m × 1 G+3 Block 1.5 m × 2	G+1 Block- 1.5 m × 1 G+3 Block- 1.7 m & 1.5 m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	G+1 Block -1 m G+2 Block- 1.20 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Naturally Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	1 @ 300 sqm	Provided	MR
	• Types	ABC Type	Provided	MR
	• IS marking	Required	Provided	MR

6.	First-Aid Hose Reels				
	• Total numbers on each floor	01	Provided		MR
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MOEFA	NA	NA		NA
9.	Public Address System	NA	NA		NA
10.	Automatic Sprinkler System				
	• Basement	NA	NA		NA
	• Ground Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants				
	• Size of riser/down-comer	NA	NA		NA
	• Number of hydrants per floor	NA	NA		NA
	• Hose Box	NA	NA		NA
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump	NA	NA		NA
	➤ Head of Main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey Pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto Starting/Manual Stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	450 lpm	Provided		MR

N-25

	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter number F6/DFS/MS/School/2023/WZ/516 dated 26/10/2023.

Note: The electric meter and electrical panel are not under the staircase.

The school management has added one more block of Ground plus three upper floors in the existing building of single block of Ground plus first floor now the school building is comprised of 02 Blocks (01 Block- Ground + First Floor & 01 Block- Ground + Three upper floors)

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to renew the Fire Safety Certificate of existing building issued vide letter number F6/DFS/MS/2020/WZ/School/427 dated 15/10/2020 and to grant FSC for new block under Rule 35 of the Delhi Fire Service Rules, 2010 .

24/10/23 - on leave
DCPS/HPW

ADO (B.W.)
9/11/24

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

P.S.O.