



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ 35

Dated:- 15/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Shiv Modern School, Located at A-3, Paschim Vihar, New Delhi-110063, is running at Ground + 03 Upper Floors in building comprised of Basement + Ground + 03 Upper Floors owned/occupied by Shiv Modern School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/MN/2021/14 dated 06/01/2021. The said premise was re-inspected by the officer concerned of this department on 06/01/2024 in the presence of Sh. P.P. Singh (Manager) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01.03.2011 and that the premises/building is fit for occupancy class "Educational Building" Group B (Ground + 03 upper floors) with effect from 15/01/2024 for a period of three years in accordance with Rule 36 unless renewal under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the DFS Rules, 2010, printed below.

Issued on 15/01/2024 at New Delhi by.

(Atul Garg)
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. Sh. P. P. Singh, Shiv Modern Sr. Sec. School, A-3, Paschim Vihar, New Delhi-110063.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The basement shall be used as per BBL.

INSPECTION REPORT

1. Name and address of the building: **Shiv Modern School Located at A-3, Paschim Vihar, New Delhi-110063.**
 2. Type of Occupancy : Educational,
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/School/MN/2021/14 dated 06/01/2021
 5. Fire Safety directives Letter No. : D.O.E Cr.no.3298-3398 dated 01-03-2011
 6. Date of inspection : 06/01/2024
 7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
 8. Name and designation of Officer
from the building side : Sh. P.P. Singh (Manager)
 9. Year of Construction : 2000-2001
 10. Applicant's letter No. : SMS/23/12/373 dated 28/12/2023
- The building complex is comprised of Basement + Ground + 03 Upper Floors but school is running at Ground + 03 Upper Floors only.

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 3298-3398 Dated 01.03.2011/ as per FSC dated 06/01/2021	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	05 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	02	NA(Kept Closed)
	b. Width of staircases			
	• Upper floors	1.25 m	1.55 m x 1 1.15 m x 1	MR(Old Case)
	• Basements	NA	1.35 m x 1 2.10 m x 1 (Ramp)	NA(Kept Closed)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace			
		01	Provided	MR
	e. Width Of Corridor			
		1.5 m	Provided	NA
	f. Door Size			
		1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	Exhaust Fan	NA
	• Upper floors	NA	Natural Ventilation	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 nos. ABC & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	Provided NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	150 mm 01 01	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA 450 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 5000 ltrs.	NA NA Provided NA Provided	NA NA NA NA MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA

18	Refuge Area			
	> Total area	NA	NA	NA
	> Location	NA	NA	NA
19	Fire control room			
	> Detector system panel	NA	NA	NA
	> Flow Switch Panel	NA	NA	NA
	> PA System Panel	NA	NA	NA
	> Battery backup	NA	NA	NA
	> Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 3298-3398 dated 01.03.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/MN/2021/14 dated 06/01/2021 is recommended.

Accordingly DFA is put up for approval please.

Aman Kumar Lathar
10/01/24
Aman Kumar Lathar
ADO (JWP)

OCFO (FPW)

10/11/24

11/01/2024

Director
11/11/24
ADP/JWP

Sir,
F.T. letter is put-up for signature 15/11/24

Director
15/11/24

15/01/24
ADP (JWP)

ADP