



**FIRE SAFETY CERTIFICATE**

Certified that the **The Goldan Dragon Restaurant (Unit of Royal Orchid Caterers)** running at ground floor only located at A- 5/11 Krishna Nagar, Shahdara, Delhi-110051, comprised of ground plus three upper floors, owned/occupied **The Goldan Dragon** have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 09/11/2023 in the presence of Mr. Pawan Kaumar (Manager) and found that the building/premises is fit for occupancy class "Asembly" (Group D) (Restaurant at Ground floor only) and valid up to 31/03/2026 (Three Years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules. 2010 printed below.

Issued 20/11/2023 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE  
o/c (u)

**Copy to: -**

1. The Manager, The Goldan Dragon Restaurant Unit of Royal Orchid Caterers located at A- 5/11 Krishna Nagar, Shahdara, Delhi-110051.
2. The Joint Commissioner of police (Lic.), Ist Floor, P.S Defence Colony, New Delhi-24 w.r.t.- MHA portal ID - 2023102817825 dated 28/10/2023.

**Condition for the validity of fire safety certificate**

- 1 FSC valid ground floor only.
- 2 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 3 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 4 The trained fire fighting staff should be available round the clock.
- 5 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 6 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 7 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 8 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 9 Basement shall be used strictly as per Building By-Laws 1983.
- 10 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

## INSPECTION REPORT

1	Name & address of the building	The Goldan Dragon Restaurant Unit of Royal Orchid Caterers located at A- 5/11 Krishna Nagar, Shahdara, Delhi-110051.			
2	Building is comprised of	Ground + 03 upper floors. (Restaurant is running on Ground floor of the building)			
3	Type of occupancy	Assembly Building (Restaurant)			
4	Type of case	New Case			
5	Details of previous FSC	Nil			
6	Fire safety directives letter no.	NBC Part IV			
7	Date of inspection	09.11.2023			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer from the building side	Mr. Pawan Kumar (Manager)			
10	Year of construction	2022			
11	Applicant's letter no.	Application No. I.D 2023102817825 -dated 28/10/2023			
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at site	Remarks MR/NMR	
1	<b>Access to Building:</b>				
	A	Road width	9.0 mtrs.	12 mtrs	MR
	B	Gate width	N/A	N/A	N/A
	C	Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type and Arrangement of Exits:</b>				
	A	Number of staircases			
	a	Upper floor	N/A	N/A	N/A
	b	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	N/A	N/A	N/A
	b	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	Required	Provided	MR
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	N/A	N/A	N/A
	E	Width of corridor	N/A	N/A	N/A
	F	Door size	1.50 mtrs x 2	1.50 mtrs. x 02	MR
3	<b>Compartmentation:</b>				
	A	Fire check door	Required	Provided	MR
	B	Sealing of electrical shafts	NA	NA	NA
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management System:</b>				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	Required	Exhaust Fan	MR

<b>5. Fire Extinguisher:</b>				
A	Total numbers	02 nos.	04 nos.	MR
B	Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
C	ISI marking	ISI Marked	ISI Marked	MR
<b>6 First-Aid-Hose Reel:</b>				
A	Total numbers	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs	30 mtrs	MR
C	Nozzle diameter	5 mm	5 mm	MR
<b>7 Automatic Fire Detection and Alarming System:</b>				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	<b>MOEFA:</b>	Required	Provided	MR
9	<b>Public Address System:</b>	N/A	N/A	N/A
<b>10 Automatic Sprinkler System:</b>				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
<b>11 Internal Hydrants:</b>				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
<b>12 Yard Hydrants:</b>				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
<b>13 Pumping Arrangements:</b>				
<b>1 Ground level</b>				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
<b>2 Terrace Level</b>				
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 M	40 M	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

40/

1103

The Golden Dragon Restaurant Unit Of Royal Orchid Caterers located at A- 5/11 Krishna Nagar, Shahdara, Delhi-110051.

14	<b>Captive Water Storage for Fire Fighting:</b>			
A	Underground tank capacity	20,000 ltrs	20,000 ltrs	MR
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	N/A	N/A	N/A
15	<b>Exit Signage:</b>	Required	provided	MR
16	<b>Provision of Lifts:</b>			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	<b>Standby Power Supply:</b>	Required	provided	MR
18	<b>Refuge Area:</b>			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	<b>Fire Control Room:</b>			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. *Start comming issues vide letter No F6/AS/MS/EH/NDZ/24 dated 12/10/23 have been completed.*

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.



Signature of the Inspecting Officer  
Name: Yashwant Singh Meena  
Designation: ADO (L.N)

Dy C.F.O. (NDZ)

*King*  
10/11/23

C.F.O.

As me think/remember there was a file of abovesaid restaurant, in which shortany were issued. Put up on same file after searching in F.P wing/ms cell or AC (Fire) office.

FO (NDZ)

P.T.O.

12/11/2023