

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/School/SZ/2024/46

Dated: 19/01/2024

FIRE SAFETY CERTIFICATE

Certified that **gds. D.A.V. Senior Secondary School located at Pusa Road, New Delhi-110005**, comprised of ground and first floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/SZ/2019/2007 dated 18.10.2019. The school building was re-inspected by the officer concerned of this department on 27.12.2023 in the presence of Sh. Rajinder Singh (Peon) and found that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from 19/01/2024 for a period of three years subject to compliance of the conditions printed below.

Issued on 19/01/2024 at New Delhi by.

(Atul Garg)
Director
Delhi Fire Service

Copy to :-

1. The H.O.S, gds. D.A.V. Senior Secondary School, Pusa Road, New Delhi- 110005.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. Basement used only for storage purpose as per BBL.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
9. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.

INSPECTION REPORT

1. Name & address of the building : gds. D.A.V. Sr. Sec. School, Pusa Road, New Delhi-05.
2. Type of Occupancy : Educational
3. Building Composition : School building is comprised of ground plus one upper floor
4. Type of Case : Renewal
5. Details of previous NOC : F.6/DFS/MS/School/SZ/2019/2007 dated 18.10.2019
6. Fire Safety directives letter No : N/A
7. Date of inspection : 27.12.2023
8. Name of the Inspecting Officers : Udai Vir Singh, Asstt. Div. Officer (DWK)
9. Name and designation of officers
from the building side : Sh. Rajinder Singh, Peon
9. Year of Construction : 1950
10. Applicant's letter No. : Form 'J' dated 14.12.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Dir. of Edu. circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mts	Provided	MR
		5.0 mts	Provided	MR, being old case
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	03	03	MR
		N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	<ul style="list-style-type: none"> • Upper Floors • Basements 	1.5 mts or less & 0.75 mt	1.40, 1.23 & 1.10 mts	MR, being old case
		N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	1.5 mts	Provided (2.40 mts)	MR
	h. Door Size	1.0 mt.	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A	N/A	N/A
		12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	06 nos.	Provided	MR
		ABC type	Provided	MR
		ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>----</p> <p>30 m</p> <p>5 mm</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>
7	Automatic fire detection and alarming system	Not required		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p>
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p>
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	<p>---</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>----</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>-----</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>	<p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p> <p>N/A</p>
15	Exit Signage.	N/A	N/A	N/A

[Handwritten signature]


2-20


16	Provision of Lifts.	Not Applicable		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 ABC type fire extinguisher is provided near elect. Panel.	MR



The fire protection systems provided in the building were tested / checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F.6/DFS/MS/School/SZ/2019/2007 dated 18.10.2019, renewal under the Directorate of Education circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 is recommended.

Accordingly, DFA is put up for approval & signature please


 Signature of the inspecting officer
 Name- Udai Vir Singh
 Asstt. Div. Officer (DWK)

D.O. (SW)  21/1/24

Cfo (S2)  21/01/2024
 Director  21/1/24
 AD of DWK

Sir FT letter is put up for sign plp
 "DIRECTOR"  21/1/23
 AD of DWK