

c96

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/School/SZ/2024/48

Dated: 19/01/2024

FIRE SAFETY CERTIFICATE

Certified that **New Holy Innocents Public School**, Plot No. PS/09, C-Block, Vikaspuri, New Delhi- 110018, comprised of basement, ground floor plus three upper floors, having total 39 rooms (including class rooms, office, Labs (Physics, Chemistry, Biology, Comp. room & store etc.) owned/occupied by New Holy Innocents Public School was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2020/SZ/388 dated 01.10.2020. The school building was re-inspected by the officers concerned of this department on 12.01.2024 in the presence of Sh. Ajay Arora (Chairman) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Educational** w.e.f. the date of issue of this certificate for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule -38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 19/01/2024 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The HOS, New Holy Innocents Public School, Plot No. PS/09, C-Block, Vikaspuri, New Delhi- 110018.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. There shall not be more than 45 children in the classrooms at second floor as width of second exit is less than 01 meter.
8. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

N/33

INSPECTION REPORT

1. Name & address of the building : Holy Innocents Public School, Plot No.-PS/09, C-Block, Vikaspuri, New Delhi-110018.
2. Building comprised of : Basement, Ground floor plus three upper floors
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ/388 dated 01/10/2020
6. Fire Safety directives letter No : F.6/DFS/MS/BP/2000/1241 dated 18.07.2000 & F.6/DFS/MS/BP/2002/2288 dated 28.11.2002
7. Date of inspection : 12.01.2024
8. Name of Inspecting Officer : Vedpal Chhikara, DO (SW) & A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Sh. Ajay Arora (Chairman)
10. Year of Construction : 2000-2002
11. Applicant's letter No. : HIPS/OFC/2023 dated 18.12.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible 06 m	12 m	MR
	• Gate width	4.5 m	5.15 & 3.9 m	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 No's	02 No's	MR
	• Basements	02 No's	02 No's	MR
	b. Width of staircases			
	• Upper Floor	1.5 m	1.50 & 1.53 m	MR
	• Basements	1.5 m	1.5 m each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	1.50 m	1.60m	MR
	f. Door Size	1.0 m	1.12 & 1.14 m (06 rooms single door)	MR, students are less than 45 in each classroom with single door
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	Required	Exhaust fans are provided	MR
	• Upper floors	Required	Natural ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	24 no.'s	Provided	MR
	• Types	ABC & CO ₂ type	Provided	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	02 no.'s	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR

(Handwritten signatures)

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System			
10.	Automatic Sprinkler System	Required	Provided	MR
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants	N/A	100 mm	N/A
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	Two	N/A
		N/A	Two	N/A
12.	Yard Hydrants	N/A	N/A	N/A
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 LPM & 180 LPM	Provided	MR
		30 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		8000 ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			
16.	Provision of Lifts.			No Lift
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A
18.	Refuge Area.			
	<ul style="list-style-type: none"> Total Area Location 	N/A	N/A	N/A
		N/A	N/A	N/A

Fire Control Room				
19.	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter number F6/DFS/MS/School/2020/SZ/388 dated 01/10/2020 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note- The school management given an undertaking (placed at C-) that they are not using 25 tin-sheds at ground floor as classrooms.

R. K. Yadav
 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Vedpal Chhikara
 Signature of Inspecting Officer
 Name- Vedpal Chhikara
 Designation- Divisional Officer (SW)

CFO (SZ)

Kings
 15/01/2024
~~*Dineta*~~
 15/11/24

D2/m
 16/11/24

ADD INVENTORY

F-T letter is put up for sign. please

DIRECTOR
 10/11/24

R. K. Yadav
 17/01/2024