

FT

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001


No.F6/DFS/MS/School/SZ/2024/ 38

Dated: 17/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Vidyalaya, GG-III, Vikas Puri, New Delhi-110018, Comprised of ground plus one upper floor, owned/occupied by Municipal Corporation Delhi was issued FSC vide letter no. 6/DFS/MS/school/NSZ/2020/585 dated 24.12.20. The school building was re-inspected by the officer concerned of this department on dated 11.01.2024 in the presence of Ms. Seema Kakkar (Incharge) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt.of NCT of Delhi, and found that the building is fit for occupancy class B 'Educational Building' with effect from ...17/01/2024 for a period of three years, subject to conditions printed below.

Issued on.....17/01/2024.....at New Delhi by


Atul Gargy
Director
Delhi Fire Service
9/1/24

Copy to-

1. The Principal, Nigam Pratibha Vidyalaya, GG-III, Vikas Puri, New Delhi-110018.
2. Director of Education, M.C.D, Civic Centre, Minto Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/21

INSPECTION REPORT

1. Name & address of the building : Nigam Pratibha Vidyalaya, GG-III, Vikas Puri, New Delhi-110018
 2. Building is comprised of : Ground plus one upper floor
 3. Type of Occupancy : Educational
 4. Type of Case : Renewal
 5. Details of Previous NOC : 6/DFS/MS/school/NSZ/2020/585 dated 24.12.2020
 6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011
 7. Date of Inspection : 11.01.2024
 8. Name of the Inspecting Officers: : ADO R.K. YADAV
 9. Name of the designation of Officer from the building side : Ms. Seema Kakkar (Incharge)
 10. Year of Construction : 1983, 2011
 11. Applicant's letter No : Nil dated 12.12.2023

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE CIR. Dated 1.3.2011	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 mtrs.	09 mtrs.	MR
	Gate width	5 mtrs.	Direct accessible from road	MR
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	Upper Floor	3 nos.	3 nos.	MR
	Basement	N.A.	N.A.	N.A.
	B. Width of Staircases	N.A.	N.A.	N.A.
	Upper Floor	1.5 m	1.5 m, 1.50 m, & 1.28 mtrs	MR being old case
	Basement	N.A.	N.A.	N.A.
	c. Protection of exits			
	Fire check door	N.A.	N.A.	N.A.
	Pressurization	N.A.	N.A.	N.A.
	e. No. of continuous staircases to terrace	2 nos.	2 nos.	MR
g. Width of Corridor	1.5	2 m	MR	
h. Door Size	1 m	1.05 m Double doors in each class room	MR	
3	Compartmentation.			
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	N.A.	N.A.	N.A.
	Upper floor	N.A.	N.A.	N.A.


15 h


M 22				
5.	Fire Extinguisher			
	Total numbers	06 Nos.	05 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	N.A.	N.A.
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.


14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as per rules. The FSC was issued vide letter no. 6/DFS/MS/school/NSZ/2020/585 dated 24.12.2020 renewal under the circular no. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 is recommended.


 Signature of the Inspecting Officer
 Name- R K YADAV
 Designation- ADO (JKP)

DO (South West) 
 15/1/24

Cfo (S2) 
 15/01/2024

~~Director~~ 
 13/1/24

