

C 46

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/School/NDZ/2024/39

Dated: 17/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Presentation Convent Sr. Sec. School, S.P. Mukherjee Marg, Delhi-06** comprised of Ground + 03 upper floors was granted FSC by this department vide letter no. F6/DFS/MS/School/NDZ/2020/562 dated 17.12.2020. The school premises was re-inspected by the officer concerned of this department on 12.01.2024 in the presence of Mr. Rattan Mishra (Admin.) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and the premises is fit for occupancy of class **Group-B 'Educational Building'** with effect from 17/01/2024 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules 2010 as printed below.

Issued on 17/01/2024 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
q/s

**Copy to:-**

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi
2. The Principal,  
Presentation Convent Sr. Sec. School, S.P. Mukherji Marg, Delhi-06

**Condition for the validity of fire safety certificate**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

- N/27 -

## INSPECTION REPORT

1	Name & address of the building	Presentation Convent Sr. Sec. School, S.P. Mukherji Marg, Delhi-06.		
2	Building is comprised of	School building is divided into two blocks: 1. G + 3 Main block (two interconnected sub - blocks) with auditorium at ground floor. 2. Administration & K.G. Block - Ground plus one upper floor.		
3	Type of Occupancy	Educational		
4	Type of Case	Renewal		
5	Details of Previous FSC	F6/DFS/MS/School/NDZ/2020/562 dated 17.12.2020		
6	Fire Safety direction letter No	262-362 dated 17.01.2005		
7	Date of Inspection	12.01.2024		
8	Name of the Inspecting Officers	Sumit Kumar, ADO (SPM)		
9	Name of the designation of Officer from the building side	Mr. Rattan Mishra Ji (Admin.)		
10	Year of Construction	1954-1973, 1984, 1989-1990		
11	Applicant's letter No	Letter no. PCS/Acc/2023-24/043 dated 20.12.2023		
S.No	Minimum Standards on fire safety requirements as per circular no. 262-362 dated 17.01.2005	Requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	Road width	06 m	06 m	MR
	Gate width	05 m	05 m	MR
	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits</b>			
	<b>A. Number of Staircases</b>			
	Upper Floor	Main Block- 04 nos. Admin & K.G. Block -2 nos.	Main Block- 04 nos. Admin & K.G. Block - 2 nos.	MR
	Basement	NA	NA	NA
	<b>B. Width of Staircases</b>			
	Upper Floor	Main Block- 1.5 m Admin & K.G. Block -1.5 m	Main block- 2.2m, 1.5m, 1.5m & 1.1 m Admin & K.G. Block- 1.5m & 1.0 m	MR
	Basement	NA	NA	NA
	<b>C. Protection of exits</b>			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	<b>D. No. of continuous staircases to terrace</b>	1 no. in each block	02 nos- Main Block 01 no- Admin block	MR
	<b>E. Width of Corridor</b>	1.5 m	2.5 m	MR
	<b>G. Door size</b>	1 m for class rooms	1 m	MR
3	<b>Compartmentation</b>			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire rating of shaft door	NA	NA	NA
	Water curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	Basement	NA	NA	NA
	Upper floor	12a/cper hour	Natural	MR

<b>5. Fire Extinguisher</b>			
Total numbers	40 no.	52 no.	MR
types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
IS marking	Required	Provided	MR
<b>6 First-aid-Hose Reels.</b>			
Total numbers of each floor	02 no in Main block at each floor 01 no. in KG block	Provided	MR
Length of hose reel hose	30 m	30 m	MR
Nozzle diameter	05 mm	05 mm	MR
<b>7 Automatic fire detection and alarming system.</b>			
Type of detectors	NA	NA	NA
Location of main panel	NA	NA	NA
Location of repeater panel	NA	NA	NA
Alternate source of power	NA	NA	NA
Hooters	NA	NA	NA
<b>8 MOEFA</b>	NA	NA	NA
<b>9 Public address System.</b>	NA	Provided	NA
<b>10 Automatic Sprinkler System.</b>			
basement	NA	NA	N.A
upper floor	N.A	N.A	N.A
Stage of auditorium	Required	Provided	MR
<b>11 Internal Hydrants</b>			
size of riser/down-comer	100 mm	100 mm	MR
Number of hydrants per floor	02 no.	02 nos. Main block 01 no.- Admin & K.G. Block	MR
Hose Box	01 no.	02 nos. - Main Block 01 no- Admin & K.G. Block	MR
<b>12 Yard Hydrants.</b>			
Total number of hydrants	NA	NA	NA
Hose Box	NA	NA	NA
<b>13 Pumping Arrangements.</b>			
• Ground Level	NA	NA	NA
➤ Discharge of main Pump	NA	NA	NA
➤ Head of Main Pump	NA	NA	NA
➤ Number of main pumps	NA	NA	NA
➤ Jockey pump out put	NA	NA	NA
➤ Jockey pump head	NA	NA	NA
➤ Standby pump out put	NA	NA	NA
➤ Standby pump Head	NA	NA	NA
➤ Auto Starting /Manual stopping	NA	NA	NA
➤ Pump House Access	NA	NA	NA
• Terrace Level			
➤ Discharge of terrace pump	450 (2 nos.) LPM & 180 LPM Jockey - Main Block 225 LPM- Admin & K.G. Block	450 (2 nos.) LPM & 180 LPM Jockey - Main Block 225 LPM- Admin & K.G. Block	MR
➤ Head of the Pump	40 m	40 m	MR
➤ Power supply	Required	Provided	MR
➤ Auto Starting of pump	Required	Provided	MR

<b>14</b>	<b>Captive Water Storage for Fire Fighting.</b>		
	Underground tank capacity	50000 ltrs	50000 ltrs ✓ <b>MR</b>
	Draw-off connection	NA	NA <b>NA</b>
	Fire service inlet	NA	NA <b>NA</b>
	Access to tank	Required	Provided <b>MR</b>
	Overhead Tank capacity		
		Main Block- 10000 Ltrs	Main Block- 15000 + 5000 ltrs ✓ <b>MR</b>
		Admin & K.G. Block - 2500 ltrs	Admin & K.G. Block - 2500 ltrs ✓ <b>MR</b>
<b>15</b>	<b>Exit Signage.</b>	Required	Provided <b>MR</b>
<b>16</b>	<b>Provision of Lifts.</b>	<b>1 lift provided in Main block</b>	
	Pressurization of Lift Shaft	NA	NA <b>NA</b>
	Pressurization of Lift lobby	NA	NA <b>NA</b>
	Communication in lift car	NA	NA <b>NA</b>
	Firemen's grounding switch	Required	Provided <b>MR</b>
	Lift Signage	Required	Provided <b>MR</b>
<b>17</b>	<b>Standby power supply</b>	Required	Provided <b>MR</b>
<b>18</b>	<b>Refuge Area.</b>		
	Total area	NA	NA <b>NA</b>
	Location	NA	NA <b>NA</b>
<b>19</b>	<b>Fire Control Room</b>		
	Detector system panel	NA	NA <b>NA</b>
	Flow switch panel	NA	NA <b>NA</b>
	PA system panel	NA	NA <b>NA</b>
	Batter backup	NA	NA <b>NA</b>
	Building Floor Plans	NA	NA <b>NA</b>
<b>20</b>	<b>Special Fire Protection systems for protection of special Risks, if any:</b>	The corridor end in main block should have sloped/ ramped to avoid stampede.	Provided adequately <b>MR</b>

The Fire Protection System provided in the school were tested, checked and random and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/School/NDZ/2023/542 dated 10.11.2023 has been rectified.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety required as per rules the FSC issued vide letter no. F6/DFS/MS/School/NDZ/2020/562 dated 17.12.2020 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

*Sumit Kumar*  
15/11/2024

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD)

*15/1/24*

*Dy. C.F.O. (NDZ)*

*C.F.O.*

*16/01/2024*

*Director*

*16/01/24*

*HT PS*

*DLF/1/24*

*P.T.O.*