

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No. F.6/DFS/MS/EH/2024/SZ/24

Dated: 18/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Eating House in the Name & Style of M/s "**Punjab Grill**" located at **Ground and First Floor**, Plot No M-82, Greater Kailash Part - II, Market, New Delhi 110048 comprised of Basement, Ground plus Three Upper Floors owned/occupied by **Lite Bite Foods Pvt Ltd** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 16/01/2024 in the presence of Mr. Avinash Kumar and found that the said building / premises is fit for **occupancy class Assembly Building** and **validity upto 31/03/2027** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 18/01/2024 at New Delhi by

  
(APUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

O/C

Copy to:

1. The Dy. Health Officer, MCD, Public Health Officer, Aurobindo Marg, Green Park, New Delhi 110016. (Ref. MHA Portal ID 2024010400116 dated 05/01/2024 )

**Conditions for the validity of the safety certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
2. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
3. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
4. The basement shall be strictly in accordance with the provision of UBBL- 2016.
5. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

INSPECTION REPORT

1	Name & Address of the Building	Lite Bite Foods Pvt Ltd "Punjab Grill" located at Ground and First Floor, Plot No M-82, Greater Kailash Part - II, Market, New Delhi 110048		
2	Type of Occupancy	Restaurant at Ground & First Floor only		
3	Building Comprised of	Basement, Ground plus Three Upper Floors		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/Mixed/2023/SZ/309 dated 27/06/2022 Bldg FSC		
7	Date of Inspection	16/01/2024		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Avinash Kumar		
10	Year of construction	2022		
11	Applicant letter No.	MHA Portal ID 2024010400116 dated 05/01/2024		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL-2016 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	12.19 mtr	MR
	• Gate width	05 mtr	05 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase			
	Upper floors	02 No's	Provided	MR
	Basement floor	02 No's	Provided	MR
	b. Width of Staircase			
	Upper floors	1.50 mtr each	Provided	MR
	Basement floor	1.50 mtr each	Provided	MR
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	Provided	MR
	e. Width of corridor	NA	NA	NA
	f. Door size	1.50 mtr	1.50m each (without doors)	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	12 ACPH	Exhaust fan Provided	MR
5	Fire Extinguishers			
	• Total numbers	06 Nos	06 Nos	MR
	• Types	ABC / Co2	Provided	MR
	• ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.			

	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	01 near restt.	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
<b>7</b>	<b>Automatic Fire Detection &amp; Alarming System.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	N/A	N/A	MR
<b>8.</b>	<b>MOEFA (Including Talk Back)</b>	Required	Provided	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> </ul>	150mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	02 No	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	02 No	Provided	MR
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	N/A	N/A	N/A
<b>13.</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Auto Starting / Manual Stopping.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	900 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	40 m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	N/A	NA	N/A
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	25,000 Ltrs	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	N/A	N/A	N/A
<b>17</b>	<b>Standby Power Supply</b>	Required	Provided (DG set)	MR
<b>18.</b>	<b>Refuge Area</b>			

n/11

MR  
IR

	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	<b>Fire Control Room.</b>			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	Required	Provided	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Further, the party has complied all the observation / Shortcoming already issued & communicated by this department vide letter of even no 688 dated 27/12/2023.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please.

*Manoj*

Signature of the Inspecting Officer  
Name: Sh. Manoj Kumar Sharma  
Design: DO (South)

*Rajesh*  
16/1/24

Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

CFO (HQ)

*Wagh*  
17/01/2024

Director

*[Large signature]*  
17/1/24

FI P 14

*ADY*

As approved, for letter is put up for your signature P1

*[Signature]*  
18/1/2024

*[Signature]*  
18/1/24

MR

Updated  
18/01/24  
DT.