

c32

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/School/NDZ/2024/36

Dated: 17/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that **Rajkiya Pratibha Vikas Vidyalaya** located at **Civil Lines, Delhi- 110054** (School ID - 1207113, comprised of three blocks having ground + 03 upper floors, Ground + 01 upper floor and Ground floor block was granted FSC by this department vide letter no. F6/DFS/MS/School/NDZ/2020/580 dated 22.12.2020. The premises was re-inspected by the officer concerned of this department on 08.01.2024 in the presence of Mr. Hardev Singh (Principal) and found that the school building have deemed complied with the fire prevention and fire safety requirement in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the building/ premises is fit for occupancy of class (Group B) "Educational Building" with effect from .....17/01/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on...17/01/2024.....at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service o/c  
Tel: 011-23414000  
BLS

**Copy to:-**

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Rajkiya Pratibha Vikas Vidyalaya at Civil Lines, Delhi- 110054 (School ID - 1207113).

**Conditions for the validity of Fire Safety Certificate:-**

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

**INSPECTION REPORT**

1	Name and address of the building:	Rajkiya Pratibha Vikas Vidyalaya, Civil Lines, Delhi 110054 (School ID - 1207113).
2	Type of occupancy with details of floors:	"Educational Building" (Group-B) School building is comprised of three blocks:- (G + 3 block & G+1 block & Ground floor only)
3	Type of case:	Renewal (old case)
4	Details of previous FSC:	F6/DFS/MS/School/NDZ/2020/580 dated 22.12.2020
5	Fire safety directives no.:	DOE letter no. F16/Estate/CC Fire Safety/2011/3298-3398 dated 01.03.2011
6	Date of inspection:	08.01.2024
7	Name of the inspecting officer:	Sumit Kumar, ADO (SPM)
8	Name and designation of the officer from the building side:	Mr. Hardev Singh (Principal)
9	Year of construction:	1961
10	Reference letter no.:	Email dated 26.12.2023

S. No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	As per Education Circular	Provide at site	Remarks MR/NMR
1	<b>Access to Building</b>			
	A Road width	06 mtrs.	12 mtrs. ✓	MR
	B Gate width	4.5 m	05 m ✓	MR
	C Width of internal roads	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	A No. of Staircase:			
	a) Upper floor	01 no. in each block	Provided ✓	MR
	b) Basements	NA	NA	NA
	B Width of the Staircase:			
	a) Upper floor	1.5 mtr.	G+1 block-1.5m G+3 block - 1.72 m ✓	MR
	b) Basements	NA	NA	NA
	C Protection of Exits			
	a) Fire check door	NA	NA	NA
	b) Pressurization	NA	NA	NA
	D No. of continuous staircase to terrace:	01 nos.	Provided in both blocks ✓	MR
	F Width of the corridor	NA	2.33 mtr.(G+1 block) ✓	NA
	E Door size	NA (as per previous inspection)	NA	NA
3	<b>Compartmentation:</b>			
	A Fire check doors	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft doors	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	<b>Smoke management System:</b>			
	A Basements	NA	NA	NA
	B Upper floors	12 ACPH	Natural ✓	MR
5	<b>Fire extinguishers</b>			
	A Total numbers	23 nos.	23 nos. ✓	MR
	B Types	Co2 & ABC	Co2 & ABC ✓	MR
	C ISI marking	Required	Provided	MR

82 11

6	<b>First Aid Hose reel</b>			
	A	Total no. at each floor	01 no.	01 no. / MR
	B	Length of Hose Reel	30 m	30 m / MR
	C	Nozzle diameter	05 mm	05 mm / MR
7	<b>Automatic Fire Detection and Alarm System (ADAS)</b>			
	A	Type of Detectors	NA	NA
	B	Location of main Panel	NA	NA
	C	Location of Repeater Panel	NA	NA
	D	Alternate power Source	NA	NA
	E	Hooter's location	NA	NA
8	<b>MOEFA</b>		NA	NA
9	<b>Public Address System</b>		NA	Provided NA
10	<b>Automatic Sprinkler System</b>			
	A	Basement	NA	NA
	B	Upper Floor	NA	NA
	C	Sprinklers above false ceiling	NA	NA
11	<b>Internal hydrants</b>			
	A	Size of the riser/down comer	NA	NA
	B	No. Of hydrants per floor	NA	NA
	C	Hose box	NA	NA
12	<b>Yard Hydrants</b>			
	A	Total no. of hydrants	NA	NA
	B	Hose box	NA	NA
13	<b>Pumping arrangements</b>			
	A	<b>Ground Level</b>		
		a) Discharge of main pump	NA	NA
		b) Head of main pump	NA	NA
		c) Number of main pump	NA	NA
		d) Discharge of jockey pump	NA	NA
		e) Head of jockey pump	NA	NA
		f) Discharge of Standby pump	NA	NA
		g) Head of Standby pump	NA	NA
		h) Auto starting/ manual stopping	NA	NA
	B	<b>Terrace Level</b>		
		a) Discharge of terrace pump	450 LPM /	450 LPM / MR
		b) Head of terrace pump	40 m	40 m / MR
		c) Alternate power supply	Required	Provided MR
		d) Auto starting of pump	Required	Provided MR
14	<b>Captive Water Storage for Fire Fighting</b>			
	A	Underground tank capacity	NA	NA
	B	Draw off connection	NA	NA
	C	Fire Service Inlet	NA	NA
	E	Access to tank	Required	Provided MR
	D	Overhead tank capacity	10,000 ltrs.	10,000 ltrs. / MR
15	<b>Exit Signage</b>		Required	Provided / MR
16	<b>Provision of lift</b>			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Fireman switch	NA	NA
	E	Lift signage	NA	NA
17	<b>Standby Power Supply</b>		NA	NA

18	Refuge Area			
A	location	NA	NA	NA
B	Total area	NA	NA	NA
19	Fire Control Room			
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20	Special Fire Protection for special risk if any:	None	04 sand buckets	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter No.F6/DFS/MS/School/NDZ/2023/616 dated 22/12/2023 has been rectified.

Keeping view of the deemed compliance of minimum standards of fire prevention and fire safety measures as per Director Education Circular, FSC issued vide letter no. F6/DFS/MS/School/NDZ/2020/580 dated 22.12.2020 is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

*Sumit Kumar*  
09/01/2024

Signature of the Inspecting Officer  
Name Sumit Kumar  
Designation ADO (SPM)

DO (CD)

*9/1/24*

*Dy. C.F.O. (CD2)*

*9/1/24*

*C.F.O.*

*10/1/2024*

*Director*

*ADP SPM*

F.T. letter is put up for signature, please.

*Sumit Kumar*  
15/01/2024

*Director (DPs)*  
*16/1/24*