

c/77

7. 
गणराज्य
दिल्ली

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/WZ/BNQT/2024/ 07

Dated: 15/01/2024

FIRE SAFETY CERTIFICATE

Certified that the M/s. S. and S. Hospitality Services INC Euphoria Mansion, located at Plot No. 16, Ground floor & First floor, Shivaji Marg, Main Najafgarh Road, New Delhi – 110015, comprised of Ground Floor + First Floor & (Terrace floor room for Kitchen) was issued FSC vide letter no. F6/DFS/MS/WZ/2020/364 dated 15/09/2020, The premises was re-inspected by the officer concerned of this department on 10-01-2024 in the presence of Sh. Bappi (Building Supervisor) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Assembly" (Group D) with effect from 15/01/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 15/01/2024.... at New Delhi by.


(Atul Garg)
Director


Copy to: -

1. The Owner/ Occupier, M/s. S. and S. Hospitality Services INC Euphoria Mansion, located at Plot No. 16, Ground floor & First floor, Shivaji Marg, Main Najafgarh Road, New Delhi – 110015. (Online Application ID No. 2023122419888 dated 25/12/2023)
2. The Dy. Health Officer, SDMC, West Zone, Vishal Enclave, Rajouri Garden, New Delhi – 110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT



Name & address of the building M/s. S. and S. Hospitality Services INC Euphoria Mansion,
Located at Plot No. 16, Ground floor & First floor, Shivaji
Marg, Main Najafgarh Road, New Delhi - 110015.

2. Type of Occupancy Assembly (Banquet Hall)

3. Type of Case Renewal

4. Details of previous NOC F6/DFS/MS/WZ/2020/364 dated 15/09/2020

5. Fire Safety directives letter No NBC (Part-IV)

6. Date of inspection 10/01/2024

7. Name of the Inspecting Officers Sarabjeet Singh ADO (MN)

8. Name and designation of officers from the building side Sh. Bappi (Building Supervisor)

9. Year of Construction 2012 (As per MHA Portal)

10. Applicant's letter No. Online Application ID No. 2023122419888 dated 25/12/2023

* The Said Banquet Hall is running at Ground + First Floor & (Terrace floor room for Kitchen) in a Building comprised of Ground + First Floor & (Terrace floor room for Kitchen).

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Required as per Rule 35(6) of DFS Rule 2010 | Provided at site | Remarks MR/NMR |
|--------|---|---|------------------|----------------|
|--------|---|---|------------------|----------------|

| | | | | |
|---|---------------------------|-------|--------------|----|
| 1 | Access to building | | | |
| | • Road width | 9 m | Provided | MR |
| | • Gate width | 4.5 m | On Main Road | MR |
| | • Width of internal road | NR | NR | NR |

2 **Number, Width, Type & Arrangement of Exits**

| | | | | |
|--|-----------|-----------------------------|--|-----------|
| a. Number of staircases | | | | |
| • Upper Floors | 02 | Provided | | MR |
| • Basements | NA | NA | | NA |
| b. Width of staircases | | | | |
| • Upper Floors | 2 x 2 mts | Provided | | MR |
| • Basements | NA | NA | | NA |
| c. Protection of exits | | | | |
| • Fire check door | Required | Provided | | MR |
| • Pressurization | NA | NA | | NA |
| e. No. of continuous staircases to terrace | 01 | 02 Provided | | MR |
| f. Width of Corridor | Hall Only | Hall Only | | Hall Only |
| g. Door Size | 2 x 2 mts | 2.10 mtr x 2 & 1.57 mtr x 1 | | MR |

3 **Compartmentation.**

| | | | | |
|--------------------------------|----------|----------|--|----|
| • Fire check door | Required | Provided | | MR |
| • Sealing of electrical shafts | NR | NR | | NR |
| • Fire Rating of shaft door | NR | NR | | NR |
| • Water Curtain | NR | NR | | NR |
| • Fire Dampers | NR | NR | | NR |

4 **Smoke Management System.**

| | | | | |
|----------------|----------|----------|--|----|
| • Basements | NA | NA | | NA |
| • Upper floors | Required | Provided | | MR |

5 **Fire Extinguishers**

| | | | | |
|-----------------|----------------------------|----------|--|----|
| • Total numbers | 15 nos. | Provided | | MR |
| • Types | CO ₂ , ABC type | Provided | | MR |
| • IS marking | ISI marked | Provided | | MR |



| | | | | |
|----|--|-------------------|----------|----|
| 6 | First-Aid Hose Reels. | | | |
| | • Total numbers on each floor | 02 | Provided | MR |
| | • Length of hose reel hose | 30m | Provided | MR |
| | • Nozzle diameter | 5mm | Provided | MR |
| 7 | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | NR | Provided | NR |
| | • Location of Main Panel | Ground Floor | Provided | MR |
| | • Location of Repeater Panel | Ground Floor | Provided | MR |
| | • Alternate source of power | Required | Provided | MR |
| | • Hooters' Location | Required | Provided | MR |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System. | NR | Provided | NR |
| 10 | Automatic Sprinkler System. | | | |
| | • Basement | NA | NA | NA |
| | • Upper Floor | NR | Provided | NR |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down-comer | 150 mm | Provided | MR |
| | • Number of hydrants per floor | 02 | Provided | MR |
| | • Hose Box | 02 | Provided | MR |
| 12 | Yard Hydrants. | | | |
| | • Total number of hydrants | NR | Provided | NR |
| | • Hose Box | NR | Provided | NR |
| 13 | Pumping Arrangements. | | | |
| | • Ground Level | | | |
| | ➤ Discharge of main Pump | NR | NR | NR |
| | ➤ Head of Main pump | NR | NR | NR |
| | ➤ Number of main pumps | NR | NR | NR |
| | ➤ Jockey Pump out put | NR | NR | NR |
| | ➤ Jockey pump head | NR | NR | NR |
| | ➤ Standby Pump out put | NR | NR | NR |
| | ➤ Standby Pump Head | NR | NR | NR |
| | ➤ Auto Starting/ Manual stopping | NR | NR | NR |
| | ➤ Pump House Access | NR | NR | NR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | 900 LPM & 180 LPM | Provided | MR |
| | ➤ Head of the pump | 25 MH | Provided | MR |
| | ➤ Power Supply | Required | Provided | MR |
| | ➤ Auto Starting of pump | Required | Provided | MR |
| 14 | Captive Water Storage for fire fighting. | | | |
| | • Underground tank capacity | NR | NR | NR |
| | ➤ Draw-off connection | NR | NR | NR |
| | ➤ Fire service inlet | NR | NR | NR |
| | ➤ Access to tank | NR | NR | NR |
| | • Overhead Tank capacity | 15,000 ltrs | Provided | MR |
| 15 | Exit Signage. | Required | Provided | MR |

| | | | | |
|----|--|----------|----------|----|
| 16 | Provision of Lifts. | | | |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of Lift lobby | NA | NA | NA |
| | • Communication In lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area. | | | |
| | ➤ Total Area | NR | NR | NR |
| | ➤ Location | NR | NR | NR |
| 19 | Fire Control Room | | | |
| | • Detector System Panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | NA | NA | NA |

The fire protection systems provided in the building were checked & found functional at the time of inspection. The shortcomings issued by this department vide letter No. F6/DFS/MS/BNQT/WZ/2023/203 dated 06/09/2023 have been complied.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2020/364 dated 15/09/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

Dy CRO (WZ)
[Signature]

[Signature]
12/11/24

CFO
[Signature]
12/01/2024

Director
[Signature]
15/11/24

[Signature]
ADOMW

[Signature]
11/01/2024
Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)