

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No.F6/DFS/MS/School/SZ/2024/ 45

Dated: 19/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the **Sarvodaya Kanya Vidyalaya (Id- 1821025)**, Vijay Enclave, New Delhi- 110045, Having 03 blocks comprised of ground plus one upper floor each.was issued FSC vide letter no. F.6/DFS/MS/2021/09 dated 05.01.2021.The school building was re-inspected by the officer concerned of this department on dated 15.01.2024 in the presence of Principal.The school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education,Govt.of NCT of Delhi, and found that the building is fit for occupancy class B 'Educational Building' with effect from 19/01/2024 for a period of threeyears, subject to conditions printed below.

Issued on.....19/01/2024.....at New Delhi by

(Atul Garg)

Director

Delhi Fire Service

Copy to-

1. The Principal,Sarvodaya Kanya Vidyalaya (Id- 1821025), Vijay Enclave, New Delhi- 110045.
2. The Principal,Sarvodaya Bal Vidyalaya (Eving Shift), Vijay Enclave, New Delhi- 110045
3. Deputy Director (Education) SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road,New Delhi.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

**INSPECTION REPORT**

1. Name & address of the building : Sarvodaya Kanya Vidyalaya, Vijay Enclave, New Delhi-110045  
 2. Building is comprised of : Having 3 blocks comprised of ground plus one upper floor each.  
 3. Type of Occupancy : Educational  
 4. Type of Case : Renewal  
 5. Details of Previous NOC : F.6/DFS/MS/2021/09 dated 05.01.2021  
 6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011  
 7. Date of Inspection : 10.01.2024  
 8. Name of the Inspecting Officers: : ADO R.K. YADAV  
 9. Name of the designation of Officer from the building side : Shashi Singh, Principal  
 10. Year of Construction : 2008  
 11. Applicant's letter No : SKV/VE/1903 dated 12.12.2023

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE CIR. Dated	Provided at Site	Remarks
1	<b>Access to building</b>			
	Road width	6 mtrs.	Provided	MR
	Gate width	5 mtrs.	Provided	MR
	Width of internal road	N.A.	N.A.	N.A.
2	<b>Number, Width, Type and Arrangement of Exits</b>			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size	2 nos. in each block	Blk-A =4, Blk-B=2, Blk-C=2		MR
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	1.5 m	Blk-A= 1.21, 1.27, 1.32 & 1.80 mtrs Blk-B= 1.81 & 1.60 mtrs Blk-C= 2.0 & 1.50 mtrs		MR being old case
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	2 nos.	2 nos.		MR
	1.5	1.55 m		MR
	1 m	1.0 m Double doors in each class room		MR
3	<b>Compartmentation.</b>			
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.
4	<b>Smoke Management System.</b>			
Basement Upper floor	N.A.	N.A.		N.A.
	N.A.	N.A.		N.A.


Handwritten marks and signatures at the bottom of the page.

<b>5.</b>	<b>Fire Extinguisher</b>			
	Total numbers	12 Nos.	05 Nos.	MR
	types	CO <sub>2</sub> & ABC	CO <sub>2</sub> & ABC	MR
	IS marking	ISI marked	ISI marked	MR
<b>6</b>	<b>First-aid-Hose Reels.</b>			
	Total numbers of each floor	N.A.	N.A.	N.A.
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
<b>7</b>	<b>Automatic fire detection and alarming system.</b>			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
<b>8</b>	<b>MOEFA</b>	N.A.	N.A.	N.A.
<b>9</b>	<b>Public address System.</b>	N.A.	N.A.	N.A.
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
<b>11</b>	<b>Internal Hydrants</b>			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>12</b>	<b>Yard Hydrants.</b>			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
<b>13</b>	<b>Pumping Arrangements.</b>			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

Fire Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.
	Draw-off connection	N.A.	N.A.
	Fire service inlet	N.A.	N.A.
	Access to tank	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.
15	Exit Signage.	Required	Provided
16	Provision of Lifts.		
	Pressurization of Lift Shaft	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.
	Communication in lift car	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.
	Lift Signage	N.A.	N.A.
17	Standby power supply	N.A.	N.A.
18	Refuge Area.		
	Total area	N.A.	N.A.
	Location	N.A.	N.A.
19	Fire Control Room		
	Detector system panel	N.A.	N.A.
	Flow switch panel	N.A.	N.A.
	PA system panel	N.A.	N.A.
	Batter backup	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	ABC Fire Extinguisher Provided near electric meter.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as per rules. The FSC was issued vide letter no.F.6/DFS/MS/2021/09 dated 05.01.2021 renewal under the circular no. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 is recommended.

  
 Signature of Inspecting Officer  
 Name:-R.K.Yadav  
 Designation:-Asstt. Divisional Officer

DO (South West)

CFO (S2)

Director

*[Handwritten signature]*  
16/1/24

*[Handwritten signature]*  
17/1/2024

*[Large handwritten signature]*  
17/1/24

*[Handwritten mark]*