

E-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/ 49

Dated: 19/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Sarvodaya Kanya Vidyalaya No.-2 (Id- 1821017), Sagarpur, New Delhi-110046, having A & B block (SPS Block) are comprised of G+3 floors & 3 blocks comprised of G+1 floor, owned/occupied by Sarvodaya Kanya Vidyalaya No.-2, was issued FSC by this department vide letter No. F.6/DFS/MS/School/2020/SZ dated 09/11/2020 & F.6/DFS/MS/School/2021/SZ/506 dated 16/07/2021 & F.6/DFS/MS/School/2022/SZ/197 dated 23/02/2022. The School building was re-inspected by the officer concerned of this department on 09.01.2024 in the presence of Smt. Nivedita Sachdeva (Principal) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....19/01/2024..... at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

9/1/24

Copy to:-

1. The Principal, Sarvodaya Kanya Vidyalaya No.-2, Sagarpur, New Delhi-110046.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/40

INSPECTION REPORT

1. Name & address of the building : Sarvodaya Kanya Vidyalaya No.-2, Sagarpur, New Delhi.
2. Building comprised of : A & B block (SPS Block) G+3 upper floors & 3 blocks G+1 floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/School/2020/SZ dated 09/11/2020 & F.6/DFS/MS/School/2021/SZ/506 dated 16/07/2021 & F.6/DFS/MS/School/2022/SZ/197 dated 23/02/2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 09/01/2024
8. Name of Inspecting Officer : A.D.O. R.K.Yadav
9. Name and designation of officers
From the building side : Smt. Nivedita Sachdeva (Principal)
10. Year of Construction : 1989, 2011, 2016-17 & 2018
11. Applicant's letter No. : Email Id skv1821017@gmail.com dated 31.12.2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/UBBL-16 requirements	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 m 4.5 m N/A	Provided 06 m N/A	M/R MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	05 No.'s in A SPS (G+3) blk 02 No.'s in B SPS (G+3) blk 02 No.'s in each G+1 floor block	Provided	M/R
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floor	1.5 M in A SPS (G+3) blk 1.5 M in B SPS (G+3) blk 1.5 & .75 M in each G+1 floor block	2x1.75, 2x1.85 & 1.73 m in A blk & 2x1.70 m in B blk & 1.6, 1.44, 1.43, 1.54, 1.41 & 1.49 m in G+1 floor blk	M/R
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	Required	Provided	M/R
	e. Width of Corridor	1.50 m	1.80/1.75 m	M/R
	f. Door Size	1.0 m	1.20 m (Double door) A & B block & .92/.87m	M/R
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Natural ventilation provided	M/R
5.	Fire Extinguishers			
	• Total numbers	45 no's	Provided	M/R
	• Types	ABC/CO ₂ type	Provided	M/R
	• IS marking	ISI marked	Provided	M/R

f h

N/4/

6.	First-Aid Hose Reels A&B (SPS block G+3 upper floor)			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Three & Two 30 mtrs 5 mm	Provided Provided Provided	M/R M/R M/R
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A N/A	N/A N/A	N/A N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		A&B (SPS	block G+3	upper floor)
		450 LPM	450 LPM (02 no.'s)	M/R
		30 m	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for firefighting A&B (SPS block G+3 upper floor)			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
		10,000 ltrs A&B block	Provided	M/R
15.	Exit Signage.			
		Required	Provided	M/R

[Handwritten signature]

N/42

		No Lift		
16.	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17.	Standby power supply			
18.	Refuge Area.	N/A	N/A	N/A
	➤ Total Area	N/A	N/A	N/A
	➤ Location			
19.	Fire Control Room	N/A	N/A	N/A
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2020/SZ dated 09/11/2020 & F.6/DFS/MS/School/2021/SZ/506 dated 16/07/2021 & F.6/DFS/MS/School/2022/SZ/197 dated 23/02/2022 renewal in accordance with the Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R. K. Yadav
 12/11/2024
 Signature of Inspecting Officer
 Name:- R.K. Yadav
 Designation:- Asstt. Divisional Officer

Divisional Officer (South West)
Asst 15/1/24
Cfo (S2) 15/01/2024
Director 13/1/24
13/1/24
13/1/24