

C 44

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/BNQT/NDZ/2024/08

Dated: 23/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **Malik Banquet Hall** situated at **Prop. No. 242, Fasil Road Bazar, Delhi Gate, Delhi**, comprised of **Ground + 01 upper floor** owned/ occupied by **Malik Banquet Hall** has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and verified the team of officers concerned of this department on 15.01.2024 in the presence of Mr. Jalaluddin (Owner) and that the premises is fit for occupancy of class **(Group-D) "Assembly Building"** with effect from **23/01/2024** for a period of **three years** in accordance with Rule 35 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on **23/01/2024** at New Delhi by


Atul Garg
Director
Delhi Fire Service o/c
Tel: 011-23414000

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2024010100013 dated 01.01.2024.
2. The Manager, Malik Banquet Hall at 242, Fasil Road, Delhi Gate, Delhi - 06.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	Malik Banquet Hall situated at Prop. No. 242, Fasil Road, Delhi Gate, Delhi - 06.
2.	Type of occupancy with details of floors:	Assembly Building (Group D) (Ground + 01 upper floor)
3.	Type of case:	New Case
4.	Details of previous NOC:	NA
5.	Fire safety directives no.:	UBBL & NBC Part IV
6.	Date of inspection:	15.01.2024
7.	Name of the inspecting officer:	Rajinder Atwal, DO (CD) & Sumit Kumar, ADO (SPM)
8.	Name and designation of the officer from the building side:	Mr. Jalaluddin (Owner)
9.	Year of construction:	1995
10.	Reference letter no.:	Online application ID No. 2024010100013 dated 01.01.2024

S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	09 m	Provided	MR
	B	Gate width	4.5 m	Directly accessible from road	MR
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits				
	A	No. Of Staircase:			
		a) Upper Floor	02 nos.	02 nos.	MR
		b) Basements	NA	NA	NA
	B	Width of the Staircase:			
		a) Upper floors	2.0 m & 1.5 m	01 nos.- 2.0 m 01 nos.- 1.5 m	MR
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire Check Door	NA	NA	NA
		b) Pressurization	NA	NA	NA
	D	No. Of continuous staircase to terrace:	02 nos.	02 nos.	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	2.0 m & 1.5 m	2.0 m & 1.5 m	MR
3	Compartmentation:				
	A	Fire Check doors	NA	NA	NA
	B	Sealing of Electrical Shafts	NA	NA	NA
	C	Fire rating of shaft Doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke management System:				
	A	Basements	NA	NA	NA
	B	Upper floors	12 ACPH	Exhaust fans	MR
5	Fire extinguishers				
	A	Total numbers	04 nos.	04 nos.	MR
	B	Types	CO2 , ABC	CO2, ABC	MR
	C	ISI marking	Required	Provided	MR

52

6	First Aid Hose reel				
	A	Total no. at each floor	01 no	01 no.	MR
	B	Length of Hose Reel	30 mtrs	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of Detectors (Smoke & Heat)	NA	NA	NA
	B	Location of main Panel	NA	NA	NA
	C	Location of Repeater Panel	NA	NA	NA
	D	Alternate power Source	NA	NA	NA
	E	Hooter's location	NA	NA	NA
8	MOEFA		Required	Provided	MR
9	Public Address System		Required	Provided	MR
10	Automatic Sprinkler System				
	A	Basement	NA	NA	NA
	B	Upper Floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal hydrants				
	A	Size of the riser/down comer	100 mm	100 mm	MR
	B	No. Of hydrants per floor	01 nos.	01 nos.	MR
	C	Hose box per floor	01 nos.	01 nos.	MR
12	Yard Hydrants				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements				
	A	Ground Level			
		a) Discharge of main pump	NA	NA	NA
		b) Head of main pump	NA	NA	NA
		c) Number of main pump	NA	NA	NA
		d) Discharge of jockey pump	NA	NA	NA
		e) Head of jockey pump	NA	NA	NA
		f) Discharge of Diesel Standby pump	NA	NA	NA
		g) Head of Standby pump	NA	NA	NA
		h) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	450 LPM	02 nos.- 450 LPM	MR
		b) Head of terrace pump	40 mtr.	40 mtrs.	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire Service Inlet	Required	Provided	MR
	E	Access to tank	Required	Provided	MR
	D	Overhead tank capacity	25,000 Ltrs	25,000 ltrs.	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
17	Standby Power Supply		Required	Provided	MR

82 6 90

18 Refuge Area				
A	Location	NA	NA	NA
B	Total area	NA	NA	NA
19 Fire Control Room:				
A	Fire Detection System panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	P A system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plan	NA	NA	NA
20 Special Fire Protection for special risk if any				

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Shortcomings communicated vide letter no. F6/DFS/MS/BNQT/NDZ/2023/262 dated 22.12.2023 has been rectified.

Keeping in view of the substantial compliance of minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate, under rule 35 of the Delhi Fire Service Rules, 2010.

Raj
15/01/24
Signature of the Inspecting Officer
Name Rajinder Atwal
Designation DO (CD)

Sumit
15/01/2024
Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

Dy. C.F.O. (Ops)
14/01/24

C.F.O.
18/01/2024

Director
19/11/24

AD/ED

F.T. letter is put up for signature, please.

Director (Ops)
22/01/24

Sumit
20/01/2024

Under Secy
24/01/24