

27

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No.F.6 DFS/MS/School/2024/SZ/60

Dated: 24/01/2024

FIRE SAFETY CERTIFICATE

Certified that the **M/s Shiv Shakti Model School**, located at Khasra No 1183-1252-1245, Rangpuri, New Delhi 110037 Comprised of Ground plus One upper floor owned/occupied by M/s Shiv Shakti Model School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2019/SZ/852 Dated 18/04/2019. The said premises was re-inspected by officer concerned of this department on 16/01/2024 in presence of Mr. Nitin Kumar and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "**Group - B Educational Building**" with effect from 24/01/2024 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 24/01/2024 at New Delhi by

(ATUL BARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Manager, M/s Shiv Shakti Model School, located at Khasra No 1183-1252-1245, Rangpuri, New Delhi 110037
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The basement shall be used as per the provisions of UBBL-2016 /NBC Part- IV.
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."
8. This FSC is valid only for old block. The New block of building will be dealt separately.

INSPECTION REPORT

1	Name & Address of the Building	M/s Shiv Shakti Model School, Khasra No 1183-1252-1245, Rangpuri, New Delhi 110037		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Old Block, Ground plus One upper floor		
4	Type of Case	New Building Block- Basement, Ground & First floor		
5	Details of Previous NOC	Renewal		
6	Fire Safety Directives Letter No	F6/DFS/MS/School/2019/SZ/852 Dt 18/04/2019		
7	Date of Inspection	Ground plus one upper floor only		
8	Name of the Inspecting Officers	DOE Circular date 01/03/2011		
9	Name & Designation of Officers from the building side	16/01/2024		
10	Year of construction	DO (South) & ADO (BCP)		
11	Applicant letter No.	Mr. Nitin Kumar		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	2000, 2015 & 2023		
		Outdoor diary no 7150 dated 10/10/2023		
		As per Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	06 mtr	MR
	• Gate width	-NA-	NA	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 No	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.50m/0.90m	1.27 mtr & 1.50 mtr	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	08 Nos	MR
	• Types	ABC	ABC & Co2 Type	MR
	• ISI Marking	ISI mark	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-
7	Automatic fire detection & alarming system.			

NA-
A-

N/118

	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2019/SZ/852 Dt 18/04/2019 Ground plus one upper floor only, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

mevl

16/11/24

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)
+

17/01/2024
Director
17/11/24
ADU/OLD

As approved, F-1. return is put up for your signature pl.

19/1/2024

Director
22/11/24
mevl