

e 13

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2024/EH/27

Dated: 25/01/2024

**FIRE SAFETY CERTIFICATE**

Certified that the The Beer Cafe A Unit of Hoppy Trails Brewing Pvt. Ltd. Located at Shop No. F-162, 163 & 164, Block-B, 1<sup>st</sup> Floor Plot No. 6 Sector-14, Vegas Mall Dwarka Delhi-110075, in a building comprised of 4 tier Basement + Ground + 11 Upper Floors Fire Safety Certificate issued to mall vide letter No. F6/DFS/MS/SZ/2022/62 dated 09/12/2022 owned/ occupied by **Hoppy Trails Brewing Pvt. Ltd** have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned from this department on 16/01/2024 in the presence of Mr. Rajesh Sharma & Saurabh Mehta (Manager) and found that the said premises is fit for occupancy class "Assembly" Group D (Second Floor) with effect from 25/01/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/01/2024 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service  
23/1/24

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS, Defence Colony, N Delhi.
2. The Manager, The Beer Cafe A Unit of Hoppy Trails Brewing Pvt. Ltd. Located at Shop No. F-162, 163 & 164, Block-B, 1<sup>st</sup> Floor Plot No. 6 Sector-14, Vegas Mall Dwarka Delhi-110075.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building: The Beer Café A Unit of Hoppy Trails Brewing Pvt. Ltd. Located at Shop No. F-162, 163 & 164, Block-B, 1<sup>st</sup> Floor Plot No. 6 Sector-14, Vegas Mall Dwarka Delhi-110075.
2. Type of Occupancy : Class-D (Assembly)( At 1<sup>st</sup> Floor in the Mall)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/SZ/2022/62 dated 09/12/2022 (Issued to mall)
5. Fire Safety directives L. No. :F6/DFS/MS/BP/2016/326 dated 16/12/2016 (issued to mall)
6. Date of inspection : 16-01-2024
7. Name of the Inspecting Officer ; ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Rajesh Sharma & Saurabh Mehta (Manager)
9. Year of Construction :
10. Applicant's letter No. : 2024010200030, dated 04/01/2024

S No	Minimum standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12mtrs	Provided	MR
	• Gate width	06mtr	Provided	MR
	• Width of internal road	06 mtr	Provided	MR
2.	Number, width, Type & Arrangements of exits( Common With Mall)			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Provided (by Mall)	MR
	• Basements	NA	12 Provided by Mall	NA
	b. Width of staircases			
	• Upper floors	1.5m	2x1.5M Provided	MR
	• Basements	NA	Provided	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	1.5m	Provided	MR
	f. Door Size	1.5 M	2.1.5 M Provided	MR
3.	Compartmentation( Common With Mall)			
	• Fire check door	Required	Provided by Mall	MR
	• Sealing of electrical shafts	Required	Provided by Mall	MR
	• Fire Rating of shaft door	Required	Provided by Mall	MR
	• Water Curtain	Required	Provided by Mall	MR
	• Fire Dampers	Required	Provided by Mall	MR
4.	Smoke managements System			
	• Basements	NA	Provided	NA
	• Upper floors	12 a/c per hour	Provided by Mall	MR

N/2

5.	Fire Extinguishers			
	• Total numbers	03 nos. each	Provided	MR
	• Types	typeABC, CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reel	Common with mall		
	• Total numbers on each floor	Required	Provided by Mall	MR
	• Length of hose reel hose	36 m	Provided by Mall	MR
	• Nozzle diameter	5 mm	Provided by Mall	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke/ Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided by Mall	MR
9.	Public Address System	Required	Provided by Mall	MR
10.	Automatic Sprinkler System (Common with mall)			
	• Basements	Required	Provided by Mall	MR
	• Upper Floor	Required	Provided by Mall	MR
	• Sprinkler above false ceiling	Required	Provided by Mall	MR
11.	Internal Hydrants: (common with the mall)			
	• Size of riser/down- comer	150 mm	Provided by Mall	MR
	• Number of hydrants per floor	1	Provided by Mall	MR
	• Hose Box	Required	Provided by Mall	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	Provided by Mall	NA
	• Hose Box	NA	Provided by Mall	NA
13.	Pumping Arrangements: Common with Mall			
	• Ground Level	NA	2850 LPM Provided By Mall	NA
	• Discharge of main pump	NA	120 mtr Provided By Mall	NA
	➤ Head of main pump	NA	2 electri Provided By Mall	NA
	➤ Number of main pumps	NA	180 LPM 2 Nos+Water Curtain Pump 2280 LPM Provided By Mall	NA
	➤ Jockey pump out put	NA	120 mtr+Water Curtain 60 mtrs Provided By Mall	NA
	➤ Jockey pump head	NA	2850 LPM Provided By Mall	NA
	➤ Standby Pump out put	NA	120mtr Provided By Mall	NA
	➤ Standby Pump Head	NA	Provided By Mall	NA
	➤ Auto Staring/Manual stopping	NA	Provided By Mall	NA
	➤ Pump House Access	NA	Provided By Mall	NA
	• Terrace level			
	➤ Discharge of pump	900lpm	Provided By Mall	MR
	➤ Head of the pump	40 m	Provided By Mall	MR
	➤ Power supply	Required	Provided By Mall	MR
	➤ Auto starting of pump	Required	Provided By Mall	MR
14.	Captive water Storage for fire fighting: Common with Mall			
	• Under ground tank capacity	NA	400000 l ( By Mall)	NA
	➤ Draw off connection	NA	Provided By Mall	NA
	➤ Fire service inlet	NA	Provided By Mall	NA
	➤ Access to tank	NA	Provided By Mall	NA
	• Overhead Tank capacity	20, 000 litres	Provided By Mall	MR


W 2


N/3


15	Exit Signage	Required	Provided By Mall	MR
16	Provision of Lifts Common with Mall			
	➤ Pressurization of Lift Shaft	NA	Provided By Mall	NA
	➤ Pressurization of lift lobby	NA	Provided By Mall	NA
	➤ Communication in lift Car	NA	Provided By Mall	NA
	➤ Fireman's Grounding Switch	NA	Provided By Mall	NA
	➤ Lift Signage	NA	Provided By Mall	NA
17	Standby power supply	Required	Provided By Mall	MR
18	Refuge Area			
	➤ Total area	NA	Provided	NA
	➤ Location	6 <sup>th</sup> & 9 <sup>th</sup> Floor	Provided	NA
19	Fire control room(Common with Mall)			
	➤ Detector system panel	NA	Provided By Mall	NA
	➤ Flow Switch Panel	NA	Provided By Mall	NA
	➤ PA System Panel	NA	Provided By Mall	NA
	➤ Battery backup	NA	Provided By Mall	NA
	➤ Building Floor Plans	NA	Provided By Mall	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	Provided By Mall	NA


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rules 2010.

  
Signature of the Inspecting Officer  
Name: Uday Vir Singh  
Designation: ADO/DWK

 16/1/24

CFO(SV)   
17/1/2024

Director   
17/1/24

Ado/DWK

Sir FY letter is put up for sig file

DIRECTOR   
24/1/24

Uploaded  
24/1/24 