

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110001

No.F6/DFS/MS/School/SZ/2024/76

Dated: 30/01/2024

FIRE SAFETY CERTIFICATE

Certified that the Goodwill Public school, Surakhpur More, Gopal Nagar, Najafgarh, New Delhi- 110043 Comprised of ground plus one upper floor owned/occupied by Goodwill Public School was issued FSC vide letter no. F.6/DFS/MS/school/NDZ/2020/03 dated 04.01.2021. The school building was inspected by the officer concerned of this department on dated 14/12/2020 in the presence of Manager. The building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No.F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011 issued by Directorate of Education, Govt.of NCT of Delhi, and found that the building is fit for occupancy class B 'Educational Building' with effect from 30/01/2024 for a period of three years, subject to conditions printed below.

Issued on.....30/01/2024..... at New Delhi.


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Principal, Goodwill Public School, Surakhpur More, Gopal Nagar, Najafgarh, New Delhi- 43.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi -54.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/6
INSPECTION REPORT

- 1 Name & address of the building : Goodwill Public school, Surakhpur More, Gopal Nagar, Najafgarh, New Delhi- 110043
2. Building is comprised of : **Ground plus one upper floor**
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/school/NDZ/2020/03 dated 04.01.2021
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011
7. Date of Inspection : 18.01.2024
8. Name of the Inspecting Officers: : ADO R.K. YADAV
9. Name of the designation of Officer from the building side : Ujjwal Rishi, Manager
10. Year of Construction : 1996
11. Applicant's letter No : Nil dated 10.01.2024

S.No	Minimum Standards on fire prevention and fire safety requirements U/R 33	DOE Dated 1.3.2011	CIR.	Provided at Site	Remarks MR/NMR
1	Access to building				
	Road width	6 mtrs.		08 mtrs.	MR
	Gate width	4.5		Direct accessible from road	MR
	Width of internal road	N.A.		N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits				
	a. Number of Staircases				
	Upper Floor	2 nos.		2 nos.	MR
	Basement	N.A.		N.A.	N.A.
	B. Width of Staircases	N.A.		N.A.	N.A.
	Upper Floor	1.5 m & .75 m		1.43 m & 1.10 m	MR, old case
	Basement	N.A.		N.A.	N.A.
	c. Protection of exits				
	Fire check door	N.A.		N.A.	N.A.
	Pressurization	N.A.		N.A.	N.A.
	e. No. of continuous staircases to terrace	1 no.		1 no.	MR
		1.5		1.55 m	MR
	g. Width of Corridor	1 m		1.05 m	MR
h. Door Size					
3	Compartmentation.				
	Fire check door	N.A.	N.A.		N.A.
	Sealing of electrical shafts	N.A.	N.A.		N.A.
	Fire rating of shaft door	N.A.	N.A.		N.A.
	Water curtain	N.A.	N.A.		N.A.
	Fire Dampers	N.A.	N.A.		N.A.
4	Smoke Management System.				
	Basement	N.A.	N.A.		N.A.
	Upper floor	Required	Natural ventilation		MR

1/6

N/17

5.	Fire Extinguisher			
	Total numbers	08 Nos.	08 Nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A.	01 no. provided	MR
	Length of hose reel hose	N.A.	N.A.	N.A.
	Nozzle diameter	N.A.	N.A.	N.A.
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A.	N.A.	N.A.
	Location of main panel	N.A.	N.A.	N.A.
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	N.A.	N.A.	N.A.
	Hooters	N.A.	N.A.	N.A.
8	MOEFA	N.A.	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	N.A.	N.A.	N.A.
	Number of hydrants per floor	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	N.A.	N.A.	N.A.
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main Pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level			
	➤ Discharge of pump	N.A.	220 LPM	N.A.
	➤ Head of the Pump	N.A.	30 mtrs	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	N.A.	N.A.	N.A.

gk

N/A

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	2500 ltrs	N.A.
15	Exit Signage.	N.A.	N.A.	N.A.
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	N.A.	N.A.	N.A.
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules the FSC issued vide letter no. F.6/DFS/MS/school/NDZ/2020/03 dated 04.01.2021 renewal under the circular no. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 is recommended.

R K Yadav
22/11/2024

Signature of the Inspecting Officer
Name R K YADAV
Designation ADO (JKP)

DO (South West)

ad
23/11/24

CPD (S2)
23/01/2024

Director
24/11/24

Ady JKP