



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 84

Dated: 01/02/2024

**FIRE SAFETY CERTIFICATE**

Certified that the Nav Jyoti Public School located at C-6, Shardha Nand Colony, Bhalaswa Dairy, Delhi-110042 is comprised of ground + 02 upper floors but School is running at Ground & first floor only owned/ occupied by the Nav Jyoti Public School was issued Fire Safety Certificate vide letter no. F6/DFS/MS/2021/88 dated 02.02.2021. The premises was inspected by the officer concerned of this department on 24.01.2024 in presence of Sh. Ram Avtar Sharma (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class Group B Educational with effect from ..01/02/2024.. for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..01/02/2024..... at New Delhi by

(Atul Garg)  
Director  
Ph:-011-23414000

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Manager, Nav Jyoti Public School located at C-6, Shardha Nand Colony, Bhalaswa Dairy, Delhi- 110042.

**Conditions for the validity of Fire Safety Certificate:**

1. This fire safety certificate is valid ground & first floor for educational occupancy only and the second floor use for residence purpose only in case of any violation this FSC will be treated as null & void.
2. All the means of escape/entry/exit shall be kept free from any obstruction.
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

**INSPECTION REPORT**

1. Name & address of the building : Nav Jyoti Public School at C-6, Shardha Nand Colony, Bhalaswa, Delhi-42.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 02 upper floors but school is running on ground & first floor only, second floor used for residence purpose
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2021/School/88 Dated: 02.02.2021
6. Fire Safety directives letter No : Director of Education Circular dated 01.03.2011
7. Date of inspection : 24.01.2024
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Sh. Ram Avtar Sharma( Manager )
10. Year of Construction : 1998
11. Applicant's letter No. : Letter No. NJPS/Fire Safety/2024 Dated-18.01.2024

Sr. no	Minimum Standards on fire prevention and fire safety U/R 33	Director of Education Circular of dated 01.03.2011	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	6m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits.</b>			
	<b>a. Number of staircases</b>			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	<b>b. Width of staircases</b>			
	• Upper Floors	1.50m	1.12m & 0.82 m	MR (old case)
	• Basements	NA	NA	NA
	<b>c. Protection of exits</b>			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
e. Width of Corridor	NA	NA	NA	
f. Door Size	01m	01m	MR	
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	07nos	08nos	MR
	• Types	ABC/CO2	ABC-08	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			




	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	01			
		30m	30m			
		5mm	5mm			
7	<b>Automatic fire detection and alarming system.</b>					MR
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
8	<b>MOEFA</b>	NA	NA		NA	
9	<b>Public Address System.</b>	NA	NA		NA	
10	<b>Automatic Sprinkler System.</b>					
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
11	<b>Internal Hydrants</b>					
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
12	<b>Yard Hydrants.</b>					
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA		NA	
		NA	NA		NA	
13	<b>Pumping Arrangements.</b>					
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		N/A	N/A		N/A	
		220 LPM	220 LPM		MR	
		40m	40m		MR	
		N/A	NA		N/A	
		N/A	NA		N/A	
14	<b>Captive Water Storage for fire fighting.</b>					
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		NA	NA		NA	
		2500 LTR	2500 LTR		MR	
15	<b>Exit Signage.</b>	N/A	N/A		N/A	
16	<b>Provision of Lifts.</b>					
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A		N/A	

	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/DFS/MS/2021/88 dated 02.02.2021.

Dy. Chief Fire Officer (WZ)

Signature of the Inspecting Officer  
 Name :-C.L. Meena  
 Designation:- ADO/RN

~~At...~~  
 Dated... 28/1/2024

~~dy~~ 23/1/2024

CFO WZ  
 29/1/2024

Director  
 30/1/24

ADO/RN

As approved, F.T. letter is setup for your signature please.

31/01/2024  
 ADO(RN)